

BOK1/283 BE4 Assessment and Inspection Report

A104, Dalston Lane, Hackney, London

Document no: 0451956

Revision no: Form BA/BAA

National Highways – Historical Railways Estate

VAR9/7410

HRE Assessment Programme

1 April 2025



BOK1/283 BE4 Assessment and Inspection Report

Client name: National Highways – Historical Railways Estate
Project name: HRE Assessment Programme
Client reference: VAR9/7410 **Project no:** B38380BA
Document no: 0451956 **Project manager:** [REDACTED]
Revision no: Form BA/BAA **Prepared by:** [REDACTED]
Date: 1 April 2025 **File name:** BOK1-283 BE4 Assessment and Inspection Report_Final

Document history and status

Revision	Date	Description	Author	Checked	Reviewed	Approved
Form AA	Feb-24	BOK1/283 BE4 Assessment and Inspection Report	[REDACTED]			
Form BA/BAA	Mar-25	BOK1/283 BE4 Assessment and Inspection Report	[REDACTED]			

Distribution of copies

Revision	Issue approved	Date issued	Issued to	Comments

Jacobs U.K. Limited

20, George Hudson Street
York YO1 6WR
United Kingdom

T +44 (0)190 455 9900
www.jacobs.com

Copyright Jacobs U.K. Limited © 2025.

All rights reserved. The concepts and information contained in this document are the property of the Jacobs group of companies. Use or copying of this document in whole or in part without the written permission of Jacobs constitutes an infringement of copyright. Jacobs, the Jacobs logo, and all other Jacobs trademarks are the property of Jacobs.

NOTICE: This document has been prepared exclusively for the use and benefit of Jacobs' client. Jacobs accepts no liability or responsibility for any use or reliance upon this document by any third party.

Executive summary

Structure Type: Single span cut and cover tunnel

Superstructure Form: Cast iron girders and jack arches, concrete encased steel girders

Substructure Form: brick side walls

Span: Square Span: 7.54m (24' – 9")

Assessment Code: BE4

Live Load Capacity: 8 ton axle loads

Capacity Critical Element: Cast iron girders

Restriction: 8 ton axle

Condition: Fair/poor

Local Authority: Hackney

OS Reference: TQ 336 847

This report presents the load carrying capacity for the bridge and identifies the data used to derive the assessment. The load carrying capacity of the bridge is based only on the assessment of visible spans that were amenable to inspection. It has been prepared by Jacobs for the exclusive use by HRE and should not be relied on by third parties. It has been based on site measurements and investigation by Jacobs or historical information provided by HRE, as appropriate.

The description of condition does not represent a principal inspection, nor should it be relied on for the development of maintenance works. Close inspection of members was limited by the constraints of safe access possible within the site visits described.

Identification of defects is principally based on ground level observation of visible members. The structural arrangement of the bridge meant that the following elements were not examined as part of the inspection for assessment:

- Cast iron girders – Due to the jack arch construction and infill at both ends of the tunnel, only the underside of the bottom flanges of the girders were visible. The webs and top flanges of the girders were considered as built-in parts protected by the deck construction and not amenable for inspection.
- Concrete encased girders – The girders were considered as built-in parts protected by the deck construction and not amenable for inspection.
- Propping columns – the columns are formed from channel sections welded together to form a 'square' section. The inside faces are not amenable to inspection and are therefore considered as built-in parts.

The dimensions of all hidden elements have been based upon the available historical information. No intrusive investigations have been completed at this structure and therefore the deck makeup has been assumed to comprise of the concrete shown on the historical drawings, 100mm of tar macadam road surfacing and miscellaneous fill. The deck makeup over the footpaths/pedestrian areas is assumed to be miscellaneous fill with concrete paving slabs.

Contents

Executive summary	i
1. General Description and Structural Details	1
1.1 Introduction	1
1.2 Location and General Description	1
1.3 Construction Type.....	1
1.3.1 Girder Dimensions	1
1.3.2 Deck Construction.....	7
1.3.3 Propping	8
1.3.4 Substructure.....	9
2. Information Search	10
2.1 Services Search	10
2.2 Site Investigation Description and Results.....	10
2.3 Existing Drawings	10
3. Structure Condition	11
3.1 General.....	11
3.2 Structure Condition	11
3.2.1 Girders	11
3.2.2 Columns.....	11
3.2.3 Jack Arches.....	11
3.2.4 Side Walls	12
3.2.5 Formation.....	12
3.2.6 Road Surface and Traffic Flow	12
4. Assessment to BE4.....	13
4.1 Methodology.....	13
4.2 Results	13
5. Conclusions and Recommendations	18

Appendices

Appendix A. Photographs

Appendix B. Form AA

Appendix C. Form BA

Appendix D. Historical Information

Appendix E. Survey Sketches

Appendix F. Calculations

Appendix G. Services Search Results

1. General Description and Structural Details

1.1 Introduction

Jacobs was appointed by National Highways – Historical Railways Estate (HRE) to undertake a BE4 assessment of structure BOK1/283.

1.2 Location and General Description

Structure BOK1/283 carries the A104 'Dalston Lane' over the former Broad Street to Dalston West Junction line within the borough of Hackney, London.

The structure carries a single lane carriageway with two marked lanes over the structure. There is a bus stop partially supported by the structure on the north side of the carriageway and another bus stop to the west of the structure on the south carriageway. The width of the surfaced carriageway is 10.5m (34' – 5 3/8") over the tunnel. The remainder of the structure supports paved pedestrian areas but there are no barriers preventing vehicle loading.

Traffic flow over the structure is high with regular HGV use and there is a bus route over the structure.

The OS Grid reference is TQ 336 847.

The Broad Street to Dalston West railway line was opened circa 1865. The cast iron elements of the structure likely date from this time. The section which carries the road was reconstructed accommodating tram lines along Dalston Lane, most likely in the early 1900s.

1.3 Construction Type

The structure is a cut and cover tunnel lying on a slight curve. The square span between the side walls generally remains the same at 7.54m (24' – 9"). The overall length along the centreline is approximately 53m.

For the purpose of this assessment the girders have been labelled 1 to 42 from north to south corresponding with historical information. Refer to Appendix D.

The majority of the superstructure comprises cast iron girders (1 to 19 and 36 to 42) which span between the side walls. The superstructure beneath Dalston Lane comprises 16 concrete encased steel girders. Two span square between the abutments, seven span skew between the side walls but parallel to the road and the remainder span between the side walls and the edge girders of the skewed section.

1.3.1 Girder Dimensions

Girders 1 and 40

These girders are cast iron with an overall height of 1' – 9". The bottom flange is 1' – 4" x 1 7/8". The details of the web thickness and top flange are not known. Both span square between the side walls.




Figure 1. Girders 1 and 40 cross section

Girders 2 to 19 and 36 to 39

These girders are cast iron with an overall depth of 1' – 9" at midspan. Historical information indicates that they have a hogback profile and that the depth at the supports is approximately 16 5/8". The bottom flanges are 1' – 8" x 1 1/2". The top flanges are 6" x 2 1/16". The thickness of the web is 1 3/4". All span square between the side walls.




Figure 2. Girders 2 to 19 and 36 to 39 cross section (midspan)

Girders 41 and 42

Historical information indicates that they are probably cast iron channels with an overall height of 1' – 9" a width of 12" and the bottom flanges have a thickness of 1 3/4". They are placed with their open sides facing and the void between is shown on the historical drawing as filled. They spanned skew between the side walls at the south end with a clear span of 27' – 10 1/2". Only the outside web faces and part of the bottom flanges are visible due to the concrete retaining wall constructed at the south end.




Figure 3. Girders 41 and 42 (North London Railway Drawing)

Girders 20 and 35

4" x 4" x 5/8" angles attach 14" x 1/2" flange plates to a 5/8" thick web plate. There are two flange plates both top and bottom. The web increases in depth from 12" at the ends to 16" at midspan. The girders span square between the side walls and have an overall length of 29' - 3". There are 3" x 3" x 1/2" angles as stiffeners along the length of the girders. 7/8" rivets are used throughout but the pitch changes from 3" near to the ends to 4" across the central section of the girder.




Figure 4. Girders 20 and 35 cross sections (Midspan left, support right)

Girders 21 and 34

They have the same angles and flanges as girder 21 and 35. The web is also 5/8" thick and increases from 11 1/2" at the ends to 16" at midspan. The girders span perpendicular to the side wall between the side wall and the edge girders of the skewed section. Girder 21 is supported on Girder 25 and Girder 34 is supported on Girder 31. They have an overall length of 25' - 3". There are 3 1/2" x 3 1/2" x 1/2" angles as stiffeners along the length of the girders. 7/8" rivets are used throughout but the pitch changes from 3" near to the ends to 4" across the central section of the girder.




Figure 5: Girders 21 and 34 cross sections (midspan left, support right)

Girders 22 and 33

3" x 3" x 1/2" angles attach 12" x 1/2" flange plates to a 12" x 5/8" web plate. There are curtailment plates on both top and bottom flanges also 12" x 1/2". The lengths of the additional plate are approximately 9' - 10" for girder 22 and 9'-0" for girder 33. The girders span perpendicular to the side walls between the side walls and edge skewed girders. The overall lengths are 19' - 3" and 18' - 6 1/4" for girders 22 and 33 respectively. There are angles as stiffeners along the length of the girders but the size is not known. 7/8" rivets are used throughout but the pitch changes from 3" near to the ends to 4" across the central section of the girder.




Figure 6: Girders 22 and 33 cross section (midspan)

Girders 23 and 32

3" x 3" x 1/2" angles attach 9" x 1/2" flange plates to a 12" x 1/2" web plate. These girders also span between the side walls and edge skewed girders. The overall lengths are 12' - 10" and 11' - 2 1/4" for girders 23 and 32 respectively. Historical drawings show that there are angles as stiffeners along the girder though the dimensions are not known. 7/8" rivets are used throughout but the pitch is not known.




Figure 7: Girders 23 and 32 cross section (midspan)

Girder 24

2 1/2" x 2 1/2" x 1/2" angles attach 9" x 1/2" flange plates to a 9" x 1/2" web plate. This girder spans between the west side wall and girder 25. The overall length is 7' – 1". 7/8" rivets are used throughout but the pitch is not known.




Figure 8: Girder 24 cross section (midspan)

Girder 25 and 31

4" x 4" x 5/8" angles attach 16" x 1/2" flange plates to a 24" x 5/8" web plate. Both girders have two additional 16" x 1/2" curtailment plates on both the top and bottom flanges. The lengths of additional plates are 18' – 8" and 12' – 0". The girders span skewed between the side walls with a clear span of 29' – 6". The overall length of the girders is 33' – 9". There are 4" x 4" x 1/2" angles as stiffeners along the length of the girder but the spacing is not known. 7/8" rivets are used throughout but the pitch changes from 3" near to the ends to 4" across the central section of the girder.




Figure 9: Girders 25 and 31 cross section (midspan)

Girders 26, 27, 29 and 30

4" x 4" x 5/8" angles attach 1/2" thick flange plates to a 5/8" thick web plate. The bottom flange is 14" wide with an additional plate also 14" x 1/2" approximately 18' - 2" long. The top flange is formed from two plates 18" wide. The plates are positioned so that the edges of the flange are 7" and 11" from the centreline of the girder. The girders are positioned in pairs, 26 1/2" centre to centre, so that the extended flange edges are towards each other. The depth of the web increases from 2' - 0 7/8" at one end to 2' - 6 7/8" at the other. There are cut outs at two locations in each girder on the top flanges 7 3/4" wide. The top flanges and angles are removed from the wider side of the flange and additional plate 12" x 5/8" (also with a cut out) is attached to the top of the girders. The cut outs are approximately 7' - 1" and 12' - 2" from the supports, refer to Figure 12 below.




Figure 10: Girder cross section at midspan




Figure 11: Plan on cut out sections




Figure 12: Girder elevation

Girder 28

4" x 4" x $\frac{5}{8}$ " angles attach 14" x $\frac{1}{2}$ " flange plates to a 25" x $\frac{5}{8}$ " web plate. There are additional flange plates also 14" x $\frac{1}{2}$ " and approximately 18' – 3" long. 4" x 4" x $\frac{1}{2}$ " angles are used as stiffeners but the spacing is not known. $\frac{7}{8}$ " rivets are used throughout but the pitch changes from 3" near to the ends to 4" across the central section of the girder.




Figure 13: Girder 28 cross section (midspan)

1.3.2 Deck Construction

Jack Arches

Between girders 1 and 2 is a 9" thick brick jack arch with a span of 3' – 9 $\frac{1}{4}$ ".

Between girders 2 to 19 are 9" thick brick jack arches with an average span of 4' – 3 $\frac{1}{2}$ ".

Between girder 39 and 40 there is an assumed 9" thick brick jack arch with a span of 4' – 7".

Concrete Encasement

Girders 36 to 39 have been placed adjacent to each other and encased in concrete.

All of the steel girders are encased in concrete. The deck between the bottom flanges of the steel girders is formed from 9" thick concrete encasing 3" x 3" x $\frac{1}{2}$ " angles at 12" centres and a metal mesh 1" from the soffit. There are 1 $\frac{1}{4}$ " x $\frac{1}{16}$ " 'hoop iron hangers' between the angles and mesh. Between girder 25 and 26 there is no angle between the bottom flanges as these girders are placed close together.

Girder 25 has been tied to girder 26 using 1" bolts in 2" 'gas tubing' placed at 5' – 0" centres near to the top of the web. Girders 27, 28 and 29 and 30 and 31 have also been tied together but using 3" x 3" x $\frac{1}{2}$ " angles fixed to the stiffener angles near to the top of the webs.

Between the girder pairs, 26-27 and 29-30, there was a void which used to be part of the 'conduit current collection' system for the electric tram lines, see Figure 14 below. As no intrusive investigations have been undertaken it is assumed these were backfilled after removal of the tram lines.




Figure 14: Section from North London Rly City Extension drawing – Girders 29 and 30

Girder 40 to 41

Between girder 40 and 41, 11 3/4" x 6" rolled joists span between the top flanges at 3' – 8" centres. There was originally 4 1/2" thick brick jack arches spanning between the joists. Most of the jack arches have been removed and metal sheets are now visible between the top flanges of the joists. It is not known what the deck make up is above the metal formwork.

1.3.3 Propping

Girders 11 and 12 have been propped. Both girders had fractures whilst the railway was still in use. The existing drawings show that the girders were overbridged with RSJs and the location of the fractures supported from above. Girder 12 appears to have been repaired at an earlier date (prior to 1920) with notes on the historical drawings noting girder 11 was found to be cracked in November 1920. There are now columns formed from two 8" x 3" channels welded together along the ends of the flanges at the locations of the fractures on both. It is not clear if the overbridging RSJs have remained in-situ after demolition of the building above, though the plates and bolts from the repairs can still be seen at the girder soffits.




Figure 15: Section from LM&SR Road and Rail Traffic Act 1933 drawing




Figure 16: Girder 12 repair section from North London Rly. City Extension drawing (circa 1900-1920)

1.3.4 Substructure

The substructure comprises side walls constructed from brick. There are no longer parapets on the structure and the wingwalls have been completely buried.

Sketches of the plan at road level, sections of the deck and elevation are included in Appendix E.

2. Information Search

2.1 Services Search

A services search was carried out by Jacobs in 2021. Information is supplied in Appendix G.

2.2 Site Investigation Description and Results

No intrusive investigations were undertaken as part of the survey for assessment.

HRE Framework Contractor AMCO set up a confined space entry safe system of work to allow entry into the tunnel. A ladder was used to complete the close visual inspection of the structure soffit as the size of the manhole used for access into the tunnel limits the options for high level access equipment.

2.3 Existing Drawings

A North London Rly – City Extension drawings contains a plan, sections and elevations of the steel girders. A L.M & S.R (Eastern Division) Road and Rail Traffic Act 1933 drawing also contains the same sketches with some levelling data included and the repair to girder 11 added to the long cross section.

3. Structure Condition

3.1 General

Jacobs undertook survey for inspection for BE4 assessment on Tuesday 12th and Wednesday 13th December 2023. Access to the underside was gained via the manhole at the south end of the structure. AMCO set up and maintained a confined space entry space system of work for the duration of the survey. Weather conditions on both days was raining with a temperature of 10°C.

3.2 Structure Condition

Appraisal of the condition was limited to the areas accessible by use of a ladder due to the constrained manhole access to the underside. The soffit of the entire structure was wet at the time of the survey with dripping water throughout particularly on the cast iron girders. Based on previous examination reports the soffit appears to remain wet throughout the year.

3.2.1 Girders

3.2.1.1 Cast Iron

The cast iron internal girders are generally in fair condition. There is surface corrosion across all girders. All girders had some pitting corrosion visible between 2 and 3mm deep. Section loss will be taken as 3mm to all exposed areas for all girders as a conservative assessment. (Photographs 6, 8 and 16)

The north end edge girder could not be inspected due to the tyres blocking the north end (Photograph 1). The south end 'edge' girder (Girder 40) has section loss up to 2mm due to pitting corrosion. Section loss will be taken as 2mm throughout the exposed faces as a conservative assessment.

The visible areas of the channel sections are in similar condition to Girder 40 with 2mm section loss (Photograph 22).

3.2.1.2 Concrete Encased Steel

There are areas of spalled concrete across the underside of this section (Photograph 21). There are four areas where the concrete has spalled exposing the girders. The remaining areas of spalling to the concrete have exposed the mesh only.

Towards the east support of girders 25 and 26 the exposed soffits are damp and there is corrosion throughout. The additional plate on girder 26 is laminated but residual thickness at this location was not possible to determine as there was no safe access (Photograph 20). There is up to 2mm section loss on the exposed areas.

3.2.1.3 RSJs

The RSJs at the south end of the tunnel are in fair condition (Photograph 22). There is surface corrosion on all surfaces with 3mm section loss to the bottom flanges.

3.2.2 Columns

The columns are in fair condition (Photograph 18). There is surface corrosion throughout both and spots of 1mm pitting corrosion across all exposed faces. Section loss is considered to be negligible.

3.2.3 Jack Arches

The jack arches are in fair condition (Photograph 17). There is some minor spalling on isolated bricks and minor mortar loss throughout. Some softening of the mortar is expected due to the damp present across the structure soffit.

The jack arch between girders 18 and 19 has a larger area of spalling covering 0.3m² up to ½ brick deep on the south side at midspan (Photograph 19).

3.2.4 Side Walls

The sidewalls are in fair condition (Photographs 12 – 14). There is soot staining throughout and some isolated patches of damp and leachate staining extending from the bearing shelves. There is mortar loss particularly on the upper sections. Around several bearing stones there are missing and spalled bricks (Photograph 15).

3.2.5 Formation

The formation to the north has been infilled and is now part of Dalston Eastern Curve Garden. The formation to the south is also infilled and forms part of Dalston Square.

The north end of the tunnel has been filled with tyres (Photographs 1 and 25). At the south end of the tunnel there is a mass concrete retaining wall with rubble fill behind blocking the end (Photographs 2, 11, 23 and 26). The access shaft at the south west corner is also formed from mass concrete.

Within the tunnel there are various discarded materials including palisade fence panels, tower scaffold decks and bits of wood. Approximately a third of the way along the tunnel is a manhole cover for a drain which flows from west to east.

3.2.6 Road Surface and Traffic Flow

The road surface over the structure is in poor condition (Photographs 3 to 5). There is cracking in the surfacing above the side walls of the tunnel (Photograph 24).

Traffic flow across the structure is high. Regular HGV use was observed during the survey and there are bus stops both east and west of the tunnel. A speed limit of 20mph applies over the structure.

4. Assessment to BE4

4.1 Methodology

Capacities of elements were calculated using estimates of reduced section sizes where corrosion is present. A general condition factor was not applied.

Resistance capacities of the cast iron girders were determined in accordance with BE4 Part I Clause 305(b)(ii). The capacity of the internal girders on the north side of the carriageway was not enhanced by D/d as the embedment details of the girders are not known.

The concrete encased girders are assumed to be steel due to the likely date of construction. The capacities of the steel girders were checked using the permissible stress given in BE4 Part I Clause 304(b).

All of the internal girders are considered to be fully restrained against lateral torsional buckling, the effective lengths were therefore taken as zero.

Loading was applied by simple statics with the load train applied transversely and longitudinally for maximum effect at the girder location under consideration within the carriageway positioning limits as indicated in BE4 Part I Clause 302.

The girders at the edges of the carriageway were checked for vehicles running both parallel to the kerb as per the requirements of BE4 but an additional check for a vehicle running parallel to the girders was also undertaken.

Determination of the adequacy of the jack arches was based upon the empirical method described in Bridgeguard 3 Current Information Sheet No. 22 (Pro-forma for the empirical assessment of brick, masonry and concrete jack arches and associated ties).

The substructure was assessed qualitatively.

4.2 Results

Element: Cast Iron edge girders

For the 'edge' cast iron girders not enough information is available from historical sources for a quantitative assessment and access on site to these girders was limited. The visible sections of the south girder appears to be in fair condition with no visible distress and therefore suitable for the imposed dead loads by qualitative assessment.

Element: Girder 8 – Cast Iron Girder beneath north footway

Action	Location	DL & SDL Effect	Live Loads	Total Load Effect ($5f_L + 2.2f_d$)	Allowable Resistance	Capacity
Bending	Girder 8 midspan	154.3 ton.ft 3.67 ton/sq.in	N/A	154.3 ton.ft 3.67 ton/sq.in	126 ton.ft 3 ton/sq.in	Theoretically overstressed under dead load.

Girder 8 was checked as the girder with the greatest dead load determined by the topographical survey completed. Not all of the cast iron girders have been checked as part of this assessment and therefore there may be other potentially overstressed girders present supporting the pedestrian area north of the carriageway. D/d enhancement was not applied as the embedment details were not investigated during the inspection for assessment.

Element: Girder 19 – Cast Iron Girder at north edge of carriageway

Action	Location	DL & SDL Effect	Live Loads	Total Load Effect ($5f_L + 2.2f_d$)	Allowable Resistance	Capacity
Bending	Girder 19 midspan	55.2 ton.ft 1.31 ton/sq.in	51.2 ton.ft 1.12 ton/sq.in	8.99 ton/sq.in	8 ton/sq.in	Not adequate for twin 9 ton axle
Bending	Girder 19 midspan	55.2 ton.ft 1.31 ton/sq.in	39.5 ton.ft 0.94 ton/sq.in	7.59 ton/sq.in	8 ton/sq.in	Adequate for twin 8 ton axle on 24 ton vehicle

Element: Steel Girders 20 & 35 (load effects for girder 20 worst case)

Action	Location	DL & SDL Effect	Live Loads	Total Load Effect	Assessed Resistance	Live Load Capacity*
Bending	Midspan	45.6 ton.ft	57.9 ton.ft	103.4 ton.ft	302.5 ton.ft	Full C&U loading
Shear	Support	6.5 ton	7.4 ton	13.9 ton	51.6 ton	Full C&U loading

Element: Steel Girders 21 & 34 (load effects for girder 34 worst case)

Action	Location	DL & SDL Effect	Live Loads	Total Load Effect	Assessed Resistance	Live Load Capacity*
Bending	Midspan	72.2 ton.ft	42.6 ton.ft	114.8 ton.ft	302.5 ton.ft	Full C&U loading
Shear	Support	12.2 ton	6.7 ton	18.9 ton	49.4 ton	Full C&U loading

Element: Steel Girders 22 & 33 (load effects for girder 33 worst case)

Action	Location	DL & SDL Effect	Live Loads	Total Load Effect	Assessed Resistance	Live Load Capacity*
Bending	Midspan	36.2 ton.ft	29.1 ton.ft	65.3 ton.ft	170.1 ton.ft	Full C&U loading
Shear	Support	8.7 ton	6.6 ton	15.3 ton	49.4 ton	Full C&U loading

Element: Steel Girders 23 & 32 (girder 23 worst case for bending, girder 32 worst case for shear)

Action	Location	DL & SDL Effect	Live Loads	Total Load Effect	Assessed Resistance	Live Load Capacity*
Bending	Midspan	13.4 ton.ft	18.8 ton.ft	32.2 ton.ft	91.2 ton.ft	Full C&U loading
Shear	Support	4.0 ton	7.1 ton	11.1 ton	41.3 ton	Full C&U loading

Element: Steel Girder 24

Action	Location	DL & SDL Effect	Live Loads	Total Load Effect	Assessed Resistance	Live Load Capacity*
Bending	Midspan	2.6 ton.ft	8.2 ton.ft	10.8 ton.ft	58.5 ton.ft	Full C&U loading
Shear	Support	1.8 ton	4.5 ton	6.3 ton	30.9 ton	Full C&U loading

Element: Steel Girders 25 & 31

Action	Location	DL & SDL Effect	Live Loads	Total Load Effect	Assessed Resistance	Live Load Capacity*
Bending	Midspan (31)	174.6 ton.ft	100.7 ton.ft	275.3 ton.ft	703.3 ton.ft	Full C&U loading
Shear	Support (31)	31.8 ton	12.1 ton	43.9 ton	103.1 ton	Full C&U loading
Bending	Curtailement point (25)	139.7 ton.ft	76.8 ton.ft	216.5 ton.ft	539.6 ton.ft	Full C&U loading
Shear	Curtailement point (25)	9.5 ton	5.1 ton	14.6 ton	103.1 ton	Full C&U loading

Element: Steel Girders 26, 27, 29 & 30 (load effects for girders 27 and 29 worst case)

Action	Location	DL & SDL Effect	Live Loads	Total Load Effect	Assessed Resistance	Live Load Capacity*
Bending	Midspan	86.2 ton.ft	73.6 ton.ft	159.8 ton.ft	602.9 ton.ft	Full C&U loading
Shear	Support	11.1 ton	11.2 ton	22.3 ton	106.9 ton	Full C&U loading
Bending	Cut out	79.1 ton.ft	67.2 ton.ft	146.3 ton.ft	403.1 ton.ft	Full C&U loading
Bending	Curtailement point	60.3 ton.ft	53.7 ton.ft	114.0 ton.ft	228.4 ton.ft	Full C&U loading
Bending	Curtailement point	53.0 ton.ft	47.9 ton.ft	100.9 ton.ft	453.2 ton.ft	Full C&U loading
Bending	Cut out	46.6 ton.ft	42.5 ton.ft	89.1 ton.ft	453.2 ton.ft	Full C&U loading

Element: Steel Girder 28

Action	Location	DL & SDL Effect	Live Loads	Total Load Effect	Assessed Resistance	Live Load Capacity*
Bending	Midspan	97.8 ton.ft	72.9 ton.ft	170.7 ton.ft	517.4 ton.ft	Full C&U loading
Shear	Support	12.7 ton	11.2 ton	23.8 ton	107.4 ton	Full C&U loading
Bending	Curtailement point	63.7 ton.ft	50.1 ton.ft	113.8 ton.ft	373.2 ton.ft	Full C&U loading
Shear	Curtailement point	7.5 ton	7.9 ton	15.4 ton	107.4 ton	Full C&U loading

Element: Concrete Deck - Angles

Action	Location	DL & SDL Effect	Live Loads	Total Load Effect	Assessed Resistance	Live Load Capacity*
Bending	Midspan	1.0 ton.ft	0.6 ton.ft	1.6 ton.ft	2.4 ton.ft	Full C&U loading
Shear	Support	0.6 ton	0.4 ton	1.0 ton	6.9 ton	Full C&U loading

Element: Jack Arches

The jack arches are compliant with Bridgeguard 3 Current Information Sheet No. 22 and are therefore deemed suitable for the imposed loading.

Element: Substructure

By qualitative assessment, the substructure appears to be satisfactory for full C&U loading. The defects described in Section 3.2 of this report are not considered to be detrimental to the load bearing capacity.

5. Conclusions and Recommendations

The steel girders under the central section of the carriageway, which was reconstructed to accommodate tram loading in the early 1900s, remain adequate for BE4 C&U loading with considerable reserves of capacity. There are, however, original cast iron girders under the edges of the carriageway that have reduced or barely sufficient capacity. Also, some of the cast iron girders beyond the edge of the carriageway under the extensive paved areas are potentially overstressed by dead load alone.

All elements of the concrete encased steel section of the deck are sufficient for full C&U loading in accordance with 'The Motor Vehicles (C&U) Regulations 1963 as amended up to 1969'. This includes any 4 axle vehicles to 24 tons and specific 4 axle 28 ton vehicles and specific 4 axle articulated vehicles to 32 tons. There are sections of concrete missing on the bottom flanges with corrosion evident on the exposed girders but the excess capacity shown indicates that even with some section loss, the girders will still be adequate with the worst case showing a maximum of 50% utilisation.

As determined by this assessment, the cast iron girder at the north edge of the carriageway (girder 19) does not have sufficient capacity for full C&U loading in accordance with 'The Motor Vehicles (C&U) Regulations 1963 as amended up to 1969'. It falls short of the full BE4 required capacity of loading from a twin 9 ton axle. It is adequate though for a twin 8 ton axle.

Girder 8 was checked for the imposed dead loads as it was shown to have the greatest fill depth within the pedestrianised section north of the road. The stress due to the dead loads is greater than the permissible stress in cast iron. Fill levels over this northern section appear to have increased significantly (approximately doubled) since the closure of the line. If the embedment conditions could be confirmed, i.e. embedded in concrete, D/d enhancement may be applied which would allow an increase in the capacity and the cast iron girders could be deemed suitable for the dead loads north of the carriageway.

A BD21 assessment completed by Balfour Beatty Rail on behalf of HRE (BRB) in 2013 also found the cast iron girders (as well as certain sections of the steel deck) unsuitable for unrestricted traffic loading. The road over the structure is part of a bus route and there is regular HGV use as well. There also appears to be vehicles regularly parking on the pedestrian areas both north and south of the road, these were not for live loading as part of this assessment. BE4 does not require checks on accidental vehicle loading.

Supporting the northern cast iron section of the deck should be considered as a minimum, with complete infill of the whole structure recommended as the most appropriate solution. There are two already fractured cast iron girders identified and other potentially overstressed girders due to the significant dead loads within the pedestrianised northern section. The girders at the edge of the carriageway under a bus stop are also not adequate for unrestricted live loading and will also require support. Consideration will need to be given to the close proximity of buildings and the presence of manhole access into a water main from the former track bed when considering the infill. The restricted access will significantly limit options for supporting the deficient sections of the structure.

Appendix A. Photographs



1. Blocked north portal (girders 1 to 7 visible)



2. Blocked south portal (girder 41 visible at top of concrete wall)



3. Road approach looking east



4. Road approach looking west




5. View along structure looking north



6. General soffit view of north end cast iron girders (girder 18 at top of photo)



7. General soffit view of concrete encased steel girder section (girder 19 at top of photo)



8. Soffit view of concrete encased cast iron girders 36 to 39



9. Soffit view of RSJs between girders 40 and 41



10. Visible section of south edge girder 41



11. Concrete retaining wall at south end



12. West sidewall beneath concrete encased steel girders



13. West sidewall at north end



14. East sidewall at north end



15. Condition at girder 8 east bearing stone



16. Typical cast iron girder condition (girder 16 in photo)



17. Typical jack arch condition (between girders 14 and 15 shown)



18. Propping columns (girder 11 right, girder 12 left)



19. Spalling to jack arch between girders 18 and 19



20. Spalled concrete and corrosion at east end of girders 25 and 26



21. Spalling concrete along west thirdspan



22. Typical RSJ and channel section condition (girder 41 on left of photo)



23. Backfill behind concrete retaining wall



24. Cracking in surfacing above sidewalk



25. Formation looking north



26. Formation looking south



27. Manhole within formation

Appendix B. Form AA

FORM 'AA' (BRIDGES)**GC/TP0356**

ELR/ Bridge No BOK1/283

Appendix: 4

Issue: 1

Revision: B (Nov 2000)

APPROVAL IN PRINCIPLE FOR ASSESSMENT**Bridge/Line Name: Dalston Junction / Broad Street to Dalton West Junction****ELR/Bridge No. BOK1/283****Brief Description of Existing Bridge:**

Dimensions and condition are obtained from site measurements and inspection. (See Jacobs report "VAR9/7410 Assessment Programme – Assessment and Inspection Report – Bridge Ref.: "BOK1/283" – February 2024).

(a) Span Arrangement

The structure is a cut and cover tunnel lying on a slight curve. The square span between the side walls generally remains the same at 7.54m (24' – 9"). The overall length along the centreline is approximately 53m.

(b) Superstructure Type

The majority of the superstructure comprises cast iron girders which span between the sidewalls. The superstructure beneath Dalston Lane comprises 16 concrete encased steel girders. Two span square between the side walls, seven span skew between the side walls but parallel to the road and the remainder span between the side walls and the edge girders and skewed section.

Between the cast iron girders there are 9" thick brick jack arches with varying spans.

The deck between the concrete encased girders is formed from 9" thick concrete encasing 3" x 3" x 1/2" angles at 12" centres and a metal mesh 1" from the soffit.

At the south end of the tunnel there are 11 3/4" x 6" rolled joists placed at 3' – 8" centres. There were originally 4 1/2" thick brick jack arches spanning between the joists. Most of the jack arches have been removed and metal sheets are now visible between the top flanges of the joists.

Two of the cast iron girders have been propped. Both girders had fractures when the railway was still in use. The existing drawings show that they were overbridged with RSJs and the locations of the fractures supported from above. They are now supported by columns formed from

FORM 'AA' (BRIDGES)**GC/TP0356**

ELR/ Bridge No BOK1/283

Appendix: 4

Issue: 1

Revision: B (Nov 2000)

APPROVAL IN PRINCIPLE FOR ASSESSMENT

two 8" x 3" channels welded together along the ends of the flanges at the locations of the fractures.

Refer to section 1.3 of the report for further details on the girders and structure arrangement.

(c) Substructure Type

The substructure comprises side walls constructed from brick. There are no longer parapets on the structure and the wingwalls have been completely buried.

(d) Planned highway works/modifications at this site

None.

(e) Road designation class and whether classed as a heavy load route

The structure carries a single lane carriageway with two marked lanes over the structure. There is a bus stop partially supported by the structure on the north side of the carriageway and another bus stop to the west of the structure on the south carriageway. The width of the surfaced carriageway is 10.5m over the tunnel. The remainder of the structure supports pedestrian areas but there are no barriers preventing vehicle loading.

Traffic flow across the bridge is high with regular HGV use and there is a bus route over the structure.

Assessment Criteria

(a) Loadings and Speed

The bridge is to be assessed for standard BE4 loading representative of 24 ton vehicles, with reduced loading being determined where this capacity is not reached.

(b) Codes to be used

BE4 – The Assessment of Highways Bridges for Construction and Use Vehicles, Ministry of Transport 1967 (with amendments to 1969)

BS 153: Parts 3B & 4: 1958 – Steel Girder Bridges, British Standards Institution (with amendments to 12 Sept. 1968)

(c) Proposed Method of Structural Analysis

FORM 'AA' (BRIDGES)**GC/TP0356**

ELR/ Bridge No BOK1/283

Appendix: 4

Issue: 1

Revision: B (Nov 2000)

APPROVAL IN PRINCIPLE FOR ASSESSMENT

Capacities of the elements will be calculated using estimates of reduced section sizes where corrosion is present. A general condition factor will not be applied.

Resistance capacities of the cast iron girders will be determined in accordance with BE4 Part I Clause 305(b)(ii). The capacity of the internal girders on the north side of the carriageway will not be enhanced by D/d as the embedment details of the girders are not known.

The concrete encased girders are assumed to be steel due to the likely date of construction. The capacities of the steel girders will be checked using the permissible stress given in BE4 Part I Clause 304(b).

All of the internal girders are considered to be fully restrained by the deck constructions, the effective lengths will therefore be taken as zero.

Loading will be applied by simple statics with the load train applied transversely and longitudinally for maximum effect at the girder location under consideration within the carriageway positioning limits as indicated in BE4 Part I Clause 302.

Determination of the adequacy of the jack arches will be based upon the empirical method described in Bridgeguard 3 Current Information Sheet No. 22 (Pro-forma for the empirical assessment of brick, masonry and concrete jack arches and associated ties).

The substructure will be assessed qualitatively.

FORM 'AA' (BRIDGES)

GC/TP0356

ELR/ Bridge No BOK1/283

Appendix: 4

Issue: 1

Revision: B (Nov 2000)

APPROVAL IN PRINCIPLE FOR ASSESSMENT

Senior Civil Engineer's Comments

None

.....
.....
.....
.....
.....

Proposed Category for Independent Check 1


Superstructure 1

Substructure 1

Name of Checker suggested if Cat 2 or 3 Not applicable

Category 1

The above assessment, with amendments shown, is approved in principle:

Signed .. 
Title Senior Civil Engineer
Date 09/02/2024

Category 2 and 3

The above assessment, with amendments shown, is approved in principle:

Signed
Title
Date

Signed
Title
Date

Appendix C. Form BA

FORM 'BA' (BRIDGES)

GC/TP0356

ELR/ Bridge No BOK1/283

Appendix: 4

Issue: 1

Revision: A (Dec 2005)

CERTIFICATION FOR ASSESSMENT CHECK

Assessment Group: Jacobs UK Ltd
Bridge/Line Name: Dalston Lane / Broad Street to Dalston West Junction
Category of Check: 1
ELR/ Bridge No: BOK1/283




We certify that reasonable professional skill and care have been used in the assessment of the above structure with a view to securing that:

- (1) It has been assessed in accordance with the Approval in Principle as recorded on the Form AA approved on 9th February 2024.
- (2) It has been checked for compliance with the following principal British Standards, Codes of Practice, BRB (Residuary) Limited technical notes and Assessment standards:
 - BE4 – The Assessment of Highway Bridges for Construction and Use Vehicles 1967 (with amendments to 1969)
 - BS153: Parts 3B and 4 – Steel Girder Bridges (with amendments to 12th September 1968)

List any departures from the above and additional methods or criteria adopted, with reference and justification for their acceptance.

None

Category 1

<u>Name</u>	<u>Signature</u>	<u>Date</u>	
.....		Assessor
.....		Assessment Checker
.....		Authorised signatory of the firm of Consulting Engineers to whom Assessor/Checker is responsible.

FORM 'BA' (BRIDGES)

GC/TP0356

ELR/ Bridge No BOK1/283

Appendix: 4

Issue: 1

Revision: A (Dec 2005)

CERTIFICATION FOR ASSESSMENT CHECK

Category 2 and 3 (Note: Category 1 check must also be signed)


(a) Assessment

<u>Name</u>	<u>Signature</u>	<u>Date</u>	
.....			Assessor
.....			Assessment Checker
.....			Authorised signatory of the firm of Consulting Engineers to whom Assessor/Checker is responsible.

(b) Check

<u>Name</u>	<u>Signature</u>	<u>Date</u>	
.....			Assessor
.....			Assessment Checker
.....			Authorised signatory of the firm of Consulting Engineers to whom Assessor/Checker is responsible.

This Certificate is accepted by..



FORM 'BAA' (BRIDGES)

GC/TP0356

ELR/ Bridge No BOK1/283

Appendix: 4

Issue: 1

Revision: A (Dec 2005)

CERTIFICATION FOR ASSESSMENT CHECK

Notification of Assessment Check

Assessment Group	Jacobs UK Ltd
Bridge Name/Road No.	Dalston Lane / A104
Line Name	Broad Street to Dalston West Junction
ELR Code/Structure No.	BOK1/283

The above structure has been assessed and checked in accordance with Standards which are listed on the appended Form BA. A summary of the results of the assessment in terms of capacity and restrictions are as follows:-

STATEMENT OF CAPACITY

Concrete encased steel girders	Full C&U Loading* 24 tons GVW
Cast iron girders (carriageway)	8 ton axle load
Cast iron girder (pedestrian)	Fail dead loads
Jack Arches	Full C&U Loading* 24 tons GVW
Masonry Substructure	Full C&U Loading* (by qualitative assessment)

*The Motor Vehicles (Construction and Use) Regulations 1969

Recommended Loading Restrictions

Maximum axle weight of 8 tons.

Description of Structural Deficiencies and Recommended Strengthening

The cast iron girders at the north edge of the carriageway are not adequate for unrestricted live loads. There are also potentially overstressed girders due to just the imposed dead loads at the north end. Permanent support to the cast iron girders as a minimum should be considered a priority with complete infill of the structure recommended as the most appropriate solution.

<u>Name</u>	<u>Signature</u>	<u>Date</u>
.....	
		Assessor
.....	
		Assessment Checker
.....	
		Authorised signatory of the firm of Consulting Engineers to whom Assessor/Checker is responsible.

FORM 'BAA' (BRIDGES)

GC/TP0356

ELR/ Bridge No BOK1/283

Appendix: 4

Issue: 1

Revision: A (Dec 2005)

CERTIFICATION FOR ASSESSMENT CHECK

This Certificate is accepted by...



..



Appendix D. Historical Information

The following pages are North London Rly – City Extension Drawings and an LM&SR Road and Rail Traffic Act drawing.


NORTH LONDON R.R.—CITY EXTENSION.—BRIDGE NO. 283.

DALSTON LANE — PUBLIC —

Plan.



Elevation A.B.



Cross Section C.D.




Stress in Tons per Sq. Inch.

	Motor Vehicle & Trailer	Motor Vehicle	Moving Load of	Moving Load of
	8 Tons on	4 Tons on	120 lbs. per	140 lbs. per
	horizontal	horizontal	sq. ft. on	sq. ft. on
	axle	axle	Office Floor	Office Floor &
			per Sq. Foot on	Covered Way
			Footpath.	
C.I. Girder No. 1	1.90	1.83	1.76	1.77
3	1.62			1.60
19			1.34	1.26
40			2.18	
41 & 42			2.68	

Blue figures refer to tables.

Appendix E. Survey Sketches

The following drawings are from a topographical survey undertaken by Central Alliance on behalf on AMCO



ABBREVIATIONS

AL	As Level	BS	British Standard
AS	As Shown	CD	Construction Drawings
AW	As Worked	CG	Construction Grid
BA	Building Area	CH	Chamber
BB	Building Boundary	CI	Construction Information
BC	Building Code	CL	Construction Line
BD	Building Detail	CM	Construction Method
BE	Building Element	CO	Construction Order
BF	Building Footing	CP	Construction Plan
BG	Building Grid	CS	Construction Schedule
BH	Building Height	CT	Construction Table
BI	Building Information	CU	Construction Unit
BJ	Building Junction	CV	Construction View
BK	Building Key	CA	Construction Area
BL	Building Level	CB	Construction Block
BM	Building Material	CC	Construction Code
BN	Building Note	CD	Construction Detail
BO	Building Opening	CE	Construction Element
BP	Building Part	CF	Construction Form
BQ	Building Point	CG	Construction Grid
BR	Building Reference	CH	Chamber
BS	British Standard	CI	Construction Information
BT	Building Type	CL	Construction Line
BV	Building Volume	CM	Construction Method
BW	Building Wall	CO	Construction Order
BX	Building X-axis	CP	Construction Plan
BY	Building Y-axis	CS	Construction Schedule
BZ	Building Z-axis	CT	Construction Table
CA	Construction Area	CU	Construction Unit
CB	Construction Block	CV	Construction View
CC	Construction Code	CA	Construction Area
CD	Construction Detail	CB	Construction Block
CE	Construction Element	CC	Construction Code
CF	Construction Form	CD	Construction Detail
CG	Construction Grid	CE	Construction Element
CH	Chamber	CF	Construction Form
CI	Construction Information	CG	Construction Grid
CL	Construction Line	CH	Chamber
CM	Construction Method	CI	Construction Information
CO	Construction Order	CL	Construction Line
CP	Construction Plan	CM	Construction Method
CS	Construction Schedule	CO	Construction Order
CT	Construction Table	CP	Construction Plan
CU	Construction Unit	CS	Construction Schedule
CV	Construction View	CT	Construction Table
CA	Construction Area	CU	Construction Unit
CB	Construction Block	CV	Construction View
CC	Construction Code	CA	Construction Area
CD	Construction Detail	CB	Construction Block
CE	Construction Element	CC	Construction Code
CF	Construction Form	CD	Construction Detail
CG	Construction Grid	CE	Construction Element
CH	Chamber	CF	Construction Form
CI	Construction Information	CG	Construction Grid
CL	Construction Line	CH	Chamber
CM	Construction Method	CI	Construction Information
CO	Construction Order	CL	Construction Line
CP	Construction Plan	CM	Construction Method
CS	Construction Schedule	CO	Construction Order
CT	Construction Table	CP	Construction Plan
CU	Construction Unit	CS	Construction Schedule
CV	Construction View	CT	Construction Table

DISCLAIMER:
 All drawings are obtained by conventional surveying methods and are not intended to be used for any purpose other than that for which they were prepared. The user of these drawings shall be responsible for their use and for any consequences arising therefrom.

TOPOGRAPHICAL LEGEND

Diagonal Line	Diagonal Line
Staircase	Staircase
Roof	Roof
Foundation	Foundation
Structure	Structure
Structure Overlaid	Structure Overlaid
Structure Underlaid	Structure Underlaid
Vegetation	Vegetation
Drainage Channel	Drainage Channel
Center Line	Center Line
Division	Division

DATE	DATE
REV	REV
Amalgamated Construction Limited Renew Holdings plc 3175 Century Way, Thorpe Park Leeds LS15 8ZB	
Daisson Lane London E8 3DF	
Line and level survey 3D Perspective	
DESIGNED BY	DATE
CHKD BY	DATE
APPROVED BY	DATE


CENTRAL ALLIANCE
 GEOTECHNICAL ENGINEERING SERVICES

RSK
 Alliance House, South Park Way
 Wetherby WF8 2BU

Appendix F. Calculations

CALCULATION COVER SHEET

Jacobs
York

Project Title: HRE Assessment Programme		Calc. No.: 0451956
Job No:	B38380BA	File: VAR9/7410
Project Manager	██████████	Subject: BOK1/283 Dalston Lane, London BE4 Assessment
Assessor	██████████	
Project Group	31200	


	Total Sheets	Made by	Date	Checked by	Date	Reviewed by	Date		
Original	116	████	Mar-25	████	Mar-25	████	Mar-25		
Rev									
Rev									
Rev									
Rev									
Rev									

Superseded by Calculation No.	Date
-------------------------------	------

For assessment criteria, refer to Approval in Principle (Form AA) document


Office	York Office	Page No.	1	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	
Section	Sketches	Checker		Date	

Girder layout at south end (under road)




The following sections show the assumed deck make up based on the available historical information assuming voids have been filled with miscellaneous fill and the metal tramline rails removed.

Section A-A




Section B-B




Office	York Office	Page No.	2	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	
Section	Sketches	Checker		Date	

Section C-C



Office	York Office	Page No.	3	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Section Properties	Checker		Date	Mar-25

Cast Iron Internal Girders



Section	b	d	A	y	A·y	A(y-yt) ²	I _{xx}
	in	in	in ²	in	in ³	in ³	in ⁴
Flange	6.00	2.06	12.4	1.03	12.76	1779.57	4.39
Web	1.75	17.44	30.5	10.78	329.00	153.36	773.23
Flange	20.00	1.50	30.0	20.25	607.50	1566.86	5.63
Net Area			72.9		949.26	3499.79	783.24

Depth of full section	D =	21.00	in
Depth of web	d _{we} =	17.44	in
Distance to NA from top of section	y _t =	13.02	in
Distance to NA from bottom of section	y _b =	7.98	in
Second moment of area of section	I _{xx} =	4283.03	in ⁴
Elastic section modulus (top flange)	Z _{xc} =	328.88	in ³
Elastic section modulus (bott. flange)	Z _{xt} =	536.93	in ³

Corroded section properties (3mm SL to soffit and edges of bottom flange)

Section	b	d	A	y	A·y	A(y-yt) ²	I _{xx}
	in	in	in ²	in	in ³	in ³	in ⁴
Flange	6.00	2.06	12.4	1.03	12.76	1691.71	4.39
Web	1.75	17.44	30.5	10.78	329.00	115.09	773.23
Flange	19.76	1.38	27.3	20.19	551.44	1523.04	4.35
Net Area			70.2		893.20	3329.84	781.96

Depth of full section	D =	20.88	in
Depth of web	d _{we} =	17.44	in
Distance to NA from top of section	y _t =	12.72	in
Distance to NA from bottom of section	y _b =	8.16	in
Second moment of area of section	I _{xx} =	4111.81	in ⁴
Elastic section modulus (top flange)	Z _{xc} =	323.17	in ³
Elastic section modulus (bott. flange)	Z _{xt} =	503.98	in ³

Office	York Office	Page No.	4	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by	KD	Date	Mar-25
Section	Section Properties	Checker	JLR	Date	Mar-25

The girder will also be checked at third span.
Using linear interpolation to estimate the depth of the girder

Depth at support = 16.625 in
Girder span = 297 in
Depth at third span = 19.5 in

Section	b in	d in	A in ²	y in	A·y in ³	A(y-yt) ² in ³	I _{xx} in ⁴
Flange	6.00	2.06	12.4	1.03	12.76	1535.02	4.39
Web	1.75	15.94	27.9	10.03	279.78	127.42	590.36
Flange	20.00	1.50	30.0	18.75	562.50	1299.42	5.63
Net Area			70.3		855.04	2961.86	600.37

Depth of full section D = 19.50 in
Depth of web dwe = 15.94 in
Distance to NA from top of section yt = 12.17 in
Distance to NA from bottom of section yb = 7.33 in
Second moment of area of section I_{xx} = 3562.23 in⁴
Elastic section modulus (top flange) Z_{xc} = 292.74 in³
Elastic section modulus (bott. flange) Z_{xt} = 485.89 in³


Corroded section properties

Section	b in	d in	A in ²	y in	A·y in ³	A(y-yt) ² in ³	I _{xx} in ⁴
Flange	6.00	2.06	12.4	1.03	12.76	1457.28	4.39
Web	1.75	15.94	27.9	10.03	279.78	95.63	590.36
Flange	19.76	1.38	27.3	18.69	510.48	1265.84	4.35
Net Area			67.6		803.01	2818.75	599.09

Depth of full section D = 19.38 in
Depth of web dwe = 15.94 in
Distance to NA from top of section yt = 11.88 in
Distance to NA from bottom of section yb = 7.50 in
Second moment of area of section I_{xx} = 3417.85 in⁴
Elastic section modulus (top flange) Z_{xc} = 287.63 in³
Elastic section modulus (bott. flange) Z_{xt} = 455.78 in³

Office	York Office	Page No.	5	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Section Properties	Checker		Date	Mar-25

Girders 20, 21, 34 and 35 at Midspan



Rivets are 7/8" diameter, therefore rivet holes are 15/16" diameter

Section	b in	d in	A in ²	y in	A·y in ³	A(y-yt) ² in ³	I _{xx} in ⁴
Flange	14.00	1.00	14.00	0.50	7.00	903.35	1.17
Angle H	8.63	0.63	5.39	1.31	7.08	281.02	0.18
Angle V	1.88	3.38	6.33	3.31	20.96	172.45	6.01
Web	0.63	8.00	5.00	9.00	45.00	1.09	26.67
Angle V	1.88	3.38	6.33	14.69	92.94	239.71	6.01
Angle H	8.63	0.63	5.39	16.69	89.96	358.48	0.18
Flange	14.00	1.00	14.00	17.50	245.00	1125.76	1.17
Rivets	-1.88	1.63	-3.05	17.19	-52.37	-228.22	-0.67
		Net Area	53.39		455.57	2853.64	40.69
		Gross Area	56.44				


Depth of full section
 Depth of web panel
 Depth of web panel between ends of angles
 Distance to NA from top of section
 Distance to NA from bottom of section
 Second moment of area of section
 Elastic section modulus (top flange)
 Elastic section modulus (bott. flange)
 Radius of Gyration

D	=	18.0	in
dw	=	16.0	in
dwe	=	8.0	in
yt	=	8.5	in
yb	=	9.5	in
I _{xx}	=	2894.34	in ⁴
Z _{xc}	=	339.20	in ³
Z _{xt}	=	305.72	in ³
R _x	=	7.4	in

Girders 20 and 35 have a 12 in deep web plate at support
 Girders 21 and 34 have a 11.5 in deep web plate at support

Office	York Office	Page No.	6	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Section Properties	Checker		Date	Mar-25

Girders 22 and 33



Rivets are 7/8" diameter, therefore rivet holes are 15/16" diameter


Section	b in	d in	A in ²	y in	A·y in ³	A(y-yt) ² in ³	I _{xx} in ⁴
Flange	12.00	1.00	12.00	0.50	6.00	440.26	1.00
Angle H	6.63	0.50	3.31	1.25	4.14	93.30	0.07
Angle V	1.63	2.50	4.06	2.75	11.17	58.88	2.12
Web	0.63	6.00	3.75	7.00	26.25	0.74	11.25
Angle V	1.63	2.50	4.06	11.25	45.70	89.47	2.12
Angle H	6.63	0.50	3.31	12.75	42.23	127.04	0.07
Flange	12.00	1.00	12.00	13.50	162.00	578.45	1.00
Rivets	-1.88	1.50	-2.81	13.25	-37.27	-125.99	-0.53
		Net Area	39.69		260.23	1262.15	17.09
		Gross Area	42.50				

Depth of full section
 Depth of web panel
 Depth of web panel between ends of angles
 Distance to NA from top of section
 Distance to NA from bottom of section
 Second moment of area of section
 Elastic section modulus (top flange)
 Elastic section modulus (bott. flange)
 Radius of Gyration

D	=	14.0	in
dw	=	12.0	in
dwe	=	6.0	in
yt	=	6.6	in
yb	=	7.4	in
I _{xx}	=	1279.24	in ⁴
Z _{xc}	=	195.09	in ³
Z _{xt}	=	171.87	in ³
R _x	=	5.7	in

Office	York Office	Page No.	7	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Section Properties	Checker		Date	Mar-25

Girders 23 and 32



Rivets are 7/8" diameter, therefore rivet holes are 15/16" diameter


Section	b in	d in	A in ²	y in	A·y in ³	A(y-yt) ² in ³	I _{xx} in ⁴
Flange	9.00	0.50	4.50	0.25	1.13	150.53	0.09
Angle H	6.50	0.50	3.25	0.75	2.44	90.73	0.07
Angle V	1.50	2.50	3.75	2.25	8.44	53.69	1.95
Web	0.50	6.00	3.00	6.50	19.50	0.65	9.00
Angle V	1.50	2.50	3.75	10.75	40.31	83.41	1.95
Angle H	6.50	0.50	3.25	12.25	39.81	125.59	0.07
Flange	9.00	0.50	4.50	12.75	57.38	202.99	0.09
Rivets	-1.88	1.00	-1.88	12.50	-23.44	-78.40	-0.16
		Net Area	24.13		145.56	629.19	13.07
		Gross Area	26.00				

Depth of full section
 Depth of web panel
 Depth of web panel between ends of angles
 Distance to NA from top of section
 Distance to NA from bottom of section
 Second moment of area of section
 Elastic section modulus (top flange)
 Elastic section modulus (bott. flange)
 Radius of Gyration

D	=	13.0	in
dw	=	12.0	in
dwe	=	6.0	in
yt	=	6.0	in
yb	=	7.0	in
I _{xx}	=	642.26	in ⁴
Z _{xc}	=	106.45	in ³
Z _{xt}	=	92.20	in ³
R _x	=	5.2	in

Office	York Office	Page No.	8	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Section Properties	Checker		Date	Mar-25

Girder 24



Rivets are 7/8" diameter, therefore rivet holes are 15/16" diameter


Section	b in	d in	A in ²	y in	A·y in ³	A(y-yt) ² in ³	I _{xx} in ⁴
Flange	9.00	0.50	4.50	0.25	1.13	84.80	0.09
Angle H	5.50	0.50	2.75	0.75	2.06	40.57	0.06
Angle V	1.50	2.00	3.00	2.00	6.00	20.14	1.00
Web	0.50	4.00	2.00	5.00	10.00	0.33	2.67
Angle V	1.50	2.00	3.00	8.00	24.00	34.87	1.00
Angle H	5.50	0.50	2.75	9.25	25.44	59.69	0.06
Flange	9.00	0.50	4.50	9.75	43.88	119.77	0.09
Rivets	-1.88	1.00	-1.88	9.50	-17.81	-45.19	-0.16
		Net Area	20.63		94.69	314.99	4.81
		Gross Area	22.50				

Depth of full section
 Depth of web panel
 Depth of web panel between ends of angles
 Distance to NA from top of section
 Distance to NA from bottom of section
 Second moment of area of section
 Elastic section modulus (top flange)
 Elastic section modulus (bott. flange)
 Radius of Gyration

D	=	10.0	in
dw	=	9.0	in
dwe	=	4.0	in
yt	=	4.6	in
yb	=	5.4	in
I _{xx}	=	319.80	in ⁴
Z _{xc}	=	69.66	in ³
Z _{xt}	=	59.12	in ³
R _x	=	3.9	in

Office	York Office	Page No.	9	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Section Properties	Checker		Date	Mar-25

Girders 25 and 31 at Midspan



Rivets are 7/8" diameter, therefore rivet holes are 15/16" diameter


Section	b in	d in	A in ²	y in	A·y in ³	A(y-y _t) ² in ³	I _{xx} in ⁴
Flange	16.00	1.50	24.00	0.75	18.00	3519.76	4.50
Angle H	8.63	0.63	5.39	1.81	9.77	657.93	0.18
Angle V	1.88	3.38	6.33	3.81	24.13	518.02	6.01
Web	0.63	16.00	10.00	13.50	135.00	4.09	213.33
Angle V	1.88	3.38	6.33	23.19	146.73	674.92	6.01
Angle H	8.63	0.63	5.39	25.19	135.78	819.17	0.18
Flange	16.00	1.50	24.00	26.25	630.00	4302.89	4.50
Rivets	-1.88	2.13	-3.98	25.94	-103.34	-681.39	-1.50
			Net Area	77.45	996.06	9815.40	233.20
			Gross Area	81.44			

Depth of full section
 Depth of web panel
 Depth of web panel between ends of angles
 Distance to NA from top of section
 Distance to NA from bottom of section
 Second moment of area of section
 Elastic section modulus (top flange)
 Elastic section modulus (bott. flange)
 Radius of Gyration

D = 27.0 in
 dw = 24.0 in
 dwe = 16.0 in
 yt = 12.9 in
 yb = 14.1 in
 I_{xx} = 10048.60 in⁴
 Z_{xc} = 781.37 in³
 Z_{xt} = 710.66 in³
 R_x = 11.4 in

Office	York Office	Page No.	10	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Section Properties	Checker		Date	Mar-25

Girders 25 and 31 at first curtailment point



Rivets are 7/8" diameter, therefore rivet holes are 15/16" diameter


Section	b in	d in	A in ²	y in	A·y in ³	A(y-yt) ² in ³	I _{xx} in ⁴
Flange	16.00	1.00	16.00	0.50	8.00	2267.59	1.33
Angle H	8.63	0.63	5.39	1.31	7.08	663.26	0.18
Angle V	1.88	3.38	6.33	3.31	20.96	523.15	6.01
Web	0.63	16.00	10.00	13.00	130.00	3.54	213.33
Angle V	1.88	3.38	6.33	22.69	143.57	669.10	6.01
Angle H	8.63	0.63	5.39	24.69	133.08	813.25	0.18
Flange	16.00	1.00	16.00	25.50	408.00	2743.74	1.33
Rivets	-1.88	1.63	-3.05	25.19	-76.74	-497.85	-0.67
		Net Area	62.39		773.94	7185.78	227.69
		Gross Area	65.44				

Depth of full section
 Depth of web panel
 Depth of web panel between ends of angles
 Distance to NA from top of section
 Distance to NA from bottom of section
 Second moment of area of section
 Elastic section modulus (top flange)
 Elastic section modulus (bott. flange)
 Radius of Gyration

D	=	26.0	in
dw	=	24.0	in
dwe	=	16.0	in
yt	=	12.4	in
yb	=	13.6	in
I _{xx}	=	7413.48	in ⁴
Z _{xc}	=	597.63	in ³
Z _{xt}	=	545.30	in ³
R _x	=	10.9	in

Office	York Office	Page No.	11	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Section Properties	Checker		Date	Mar-25

Girders 25 and 31 at second curtailment point



Rivets are 7/8" diameter, therefore rivet holes are 15/16" diameter


Section	b in	d in	A in ²	y in	A·y in ³	A(y-y _t) ² in ³	I _{xx} in ⁴
Flange	16.00	0.50	8.00	0.25	2.00	1098.48	0.17
Angle H	8.63	0.63	5.39	0.81	4.38	670.83	0.18
Angle V	1.88	3.38	6.33	2.81	17.80	530.44	6.01
Web	0.63	16.00	10.00	12.50	125.00	2.83	213.33
Angle V	1.88	3.38	6.33	22.19	140.41	660.90	6.01
Angle H	8.63	0.63	5.39	24.19	130.39	804.91	0.18
Flange	16.00	0.50	8.00	24.75	198.00	1307.05	0.17
Rivets	-1.88	1.13	-2.11	24.44	-51.55	-327.99	-0.22
		Net Area	47.33		566.42	4747.46	225.81
		Gross Area	49.44				

Depth of full section
 Depth of web panel
 Depth of web panel between ends of angles
 Distance to NA from top of section
 Distance to NA from bottom of section
 Second moment of area of section
 Elastic section modulus (top flange)
 Elastic section modulus (bott. flange)
 Radius of Gyration

D = 25.0 in
 dw = 24.0 in
 dwe = 16.0 in
 yt = 12.0 in
 yb = 13.0 in
 I_{xx} = 4973.27 in⁴
 Z_{xc} = 415.55 in³
 Z_{xt} = 381.62 in³
 R_x = 10.3 in

Office	York Office	Page No.	12	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Section Properties	Checker		Date	Mar-25

Girder 28 at Midspan



Rivets are 7/8" diameter, therefore rivet holes are 15/16" diameter


Section	b in	d in	A in ²	y in	A·y in ³	A(y-yt) ² in ³	I _{xx} in ⁴
Flange	14.00	1.00	14.00	0.50	7.00	2133.57	1.17
Angle H	8.63	0.63	5.39	1.31	7.08	716.94	0.18
Angle V	1.88	3.38	6.33	3.31	20.96	575.02	6.01
Web	0.63	17.00	10.63	13.50	143.44	4.56	255.89
Angle V	1.88	3.38	6.33	23.69	149.90	743.94	6.01
Angle H	8.63	0.63	5.39	25.69	138.47	889.08	0.18
Flange	14.00	1.00	14.00	26.50	371.00	2610.44	1.17
Rivets	-1.88	1.63	-3.05	26.19	-79.79	-542.41	-0.67
		Net Area	59.02		758.05	7131.14	269.91
		Gross Area	62.06				

Depth of full section
 Depth of web panel
 Depth of web panel between ends of angles
 Distance to NA from top of section
 Distance to NA from bottom of section
 Second moment of area of section
 Elastic section modulus (top flange)
 Elastic section modulus (bott. flange)
 Radius of Gyration

D	=	27.0	in
dw	=	25.0	in
dwe	=	17.0	in
yt	=	12.8	in
yb	=	14.2	in
I _{xx}	=	7401.05	in ⁴
Z _{xc}	=	576.18	in ³
Z _{xt}	=	522.86	in ³
R _x	=	11.2	in

Office	York Office	Page No.	13	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Section Properties	Checker		Date	Mar-25

Girder 28 at curtailment point



Rivets are 7/8" diameter, therefore rivet holes are 15/16" diameter

Section	b in	d in	A in ²	y in	A·y in ³	A(y-yt) ² in ³	I _{xx} in ⁴
Flange	14.00	0.50	7.00	0.25	1.75	1038.31	0.15
Angle H	8.63	0.63	5.39	0.81	4.38	727.44	0.18
Angle V	1.88	3.38	6.33	2.81	17.80	585.22	6.01
Web	0.63	17.00	10.63	13.00	138.13	3.46	255.89
Angle V	1.88	3.38	6.33	23.19	146.73	732.44	6.01
Angle H	8.63	0.63	5.39	25.19	135.78	877.47	0.18
Flange	14.00	0.50	7.00	25.75	180.25	1242.13	0.15
Rivets	-1.88	1.13	-2.11	25.44	-53.66	-356.95	-0.22
		Net Area	45.95		571.16	4849.52	268.32
		Gross Area	48.06				

Depth of full section
 Depth of web panel
 Depth of web panel between ends of angles
 Distance to NA from top of section
 Distance to NA from bottom of section
 Second moment of area of section
 Elastic section modulus (top flange)
 Elastic section modulus (bott. flange)
 Radius of Gyration


D	=	26.0	in
dw	=	25.0	in
dwe	=	17.0	in
yt	=	12.4	in
yb	=	13.6	in
I _{xx}	=	5117.84	in ⁴
Z _{xc}	=	411.76	in ³
Z _{xt}	=	377.12	in ³
R _x	=	10.6	in

Office	York Office	Page No.	14	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Section Properties	Checker		Date	Mar-25

Girders 26, 27, 29 and 30

The girders will be checked at midspan, curtailment points of the additional bottom flange plate and the locations of the cut outs. It is assumed that the west end is the deeper end of the girder.

At west cutout and curtailment point



Rivets are 7/8" diameter, therefore rivet holes are 15/16" diameter

Section	b in	d in	A in ²	y in	A·y in ³	A(y-yt) ² in ³	I _{xx} in ⁴
Flange	7.31	1.00	7.31	0.50	3.66	1842.40	0.61
Angle H	4.63	0.63	2.89	1.31	3.79	655.65	0.09
Angle V	1.25	3.38	4.22	3.31	13.97	719.62	4.00
Web	0.63	21.63	13.52	15.81	213.72	4.25	526.70
Angle V	1.88	3.38	6.33	28.31	179.17	902.08	6.01
Angle H	8.63	0.63	5.39	30.31	163.40	1047.45	0.18
Flange	14.00	0.50	7.00	30.88	216.13	1472.15	0.15
Rivets	-1.88	1.13	-2.11	30.56	-64.47	-424.71	-0.22


Net Area **44.55**
Gross Area **46.66**

Depth of full section
Depth of web panel
Depth of web panel between ends of angles
Distance to NA from top of section
Distance to NA from bottom of section
Second moment of area of section
Elastic section modulus (top flange)
Elastic section modulus (bott. flange)
Radius of Gyration

D = **31.1** in
dw = **29.6** in
dwe = **21.6** in
yt = **16.4** in
yb = **14.8** in
I_{xx} = **6756.42** in⁴
Z_{xc} = **412.66** in³
Z_{xt} = **458.00** in³
Rx = **12.3** in

Office	York Office	Page No.	15	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Section Properties	Checker		Date	Mar-25

At midspan



Rivets are 7/8" diameter, therefore rivet holes are 15/16" diameter

Section	b in	d in	A in ²	y in	A·y in ³	A(y-yt) ² in ³	I _{xx} in ⁴
Flange	18.00	1.00	18.00	0.50	9.00	2989.40	1.50
Angle H	8.63	0.63	5.39	1.31	7.08	785.93	0.18
Angle V	1.88	3.38	6.33	3.31	20.96	642.29	6.01
Web	0.63	19.88	12.42	14.94	185.55	29.86	408.90
Angle V	1.88	3.38	6.33	26.56	168.09	1098.50	6.01
Angle H	8.66	0.63	5.41	28.56	154.54	1246.02	0.18
Flange	14.00	1.00	14.00	29.38	411.25	3578.57	1.17
Rivets	-1.88	1.63	-3.05	29.06	-88.55	-748.67	-0.67


Net Area **64.83**
Gross Area **67.88**

Depth of full section
Depth of web panel
Depth of web panel between ends of angles
Distance to NA from top of section
Distance to NA from bottom of section
Second moment of area of section
Elastic section modulus (top flange)
Elastic section modulus (bott. flange)
Radius of Gyration

D = 29.9 in
dw = 27.9 in
dwe = 19.9 in
yt = 13.4 in
yb = 16.5 in
I_{xx} = 10045.18 in⁴
Z_{xc} = 750.36 in³
Z_{xt} = 609.25 in³
R_x = 12.4 in

Office	York Office	Page No.	16	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Section Properties	Checker		Date	Mar-25

At east cutout



Rivets are 7/8" diameter, therefore rivet holes are 15/16" diameter


Section	b in	d in	A in ²	y in	A·y in ³	A(y-yt) ² in ³	Ixx in ⁴
Flange	7.31	1.00	7.31	0.50	3.66	1540.64	0.61
Angle H	4.63	0.63	2.89	1.31	3.79	542.74	0.09
Angle V	1.25	3.38	4.22	3.31	13.97	577.75	4.00
Web	0.63	19.00	11.88	14.50	172.19	3.15	357.24
Angle V	1.88	3.38	6.33	25.69	162.55	720.78	6.01
Angle H	8.63	0.63	5.39	27.69	149.25	865.69	0.18
Flange	14.00	0.50	7.00	28.25	197.75	1226.15	0.15
Rivets	-1.88	1.13	-2.11	27.94	-58.93	-352.25	-0.22
		Net Area	42.91		644.24	5124.67	368.05
		Gross Area	45.02				

Depth of full section
 Depth of web panel
 Depth of web panel between ends of angles
 Distance to NA from top of section
 Distance to NA from bottom of section
 Second moment of area of section
 Elastic section modulus (top flange)
 Elastic section modulus (bott. flange)
 Radius of Gyration

D = 28.5 in
 dw = 27.0 in
 dwe = 19.0 in
 yt = 15.0 in
 yb = 13.5 in
 Ixx = 5492.72 in⁴
 Zxc = 365.81 in³
 Zxt = 407.32 in³
 Rx = 11.3 in

Office	York Office	Page No.	17	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Section Properties	Checker		Date	Mar-25

At east curtailment point



Rivets are 7/8" diameter, therefore rivet holes are 15/16" diameter

Section	b in	d in	A in ²	y in	A·y in ³	A(y-yt) ² in ³	I _{xx} in ⁴
Flange	18.00	1.00	18.00	0.50	9.00	708.10	1.50
Angle H	8.63	0.63	5.39	1.31	7.08	160.68	0.18
Angle V	1.88	3.38	6.33	3.31	20.96	75.74	6.01
Web	0.63	7.88	4.92	8.94	43.99	23.08	25.44
Angle V	1.88	3.38	6.33	14.56	92.15	384.06	6.01
Angle H	8.66	0.63	5.41	16.56	89.61	518.62	0.18
Flange	14.00	0.50	7.00	17.13	119.88	750.28	0.15
Rivets	-1.88	1.13	-2.11	16.81	-35.46	-212.65	-0.22
Net Area			51.27		347.20	2407.91	39.22
Gross Area			53.38				

Depth of full section
 Depth of web panel
 Depth of web panel between ends of angles
 Distance to NA from top of section
 Distance to NA from bottom of section
 Second moment of area of section
 Elastic section modulus (top flange)
 Elastic section modulus (bott. flange)
 Radius of Gyration

D	=	17.4	in
dw	=	15.9	in
dwe	=	7.9	in
yt	=	6.8	in
yb	=	10.6	in
I _{xx}	=	2447.14	in ⁴
Z _{xc}	=	361.36	in ³
Z _{xt}	=	230.80	in ³
R _x	=	6.9	in

Office	York Office	Page No.	18	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Effective Span	Checker		Date	Mar-25

BE4 303(a)

303(a)(i)

303(a)(iv)

Effective Spans

The effective span of a beam shall be taken as the distance between points of support.

Where the beam is supported by other beams, the web of the supporting beam. Where there are no bearing stiffeners and the beam rests directly on masonry, concrete or brick, the reaction shall be assumed to be distributed linearly from a maximum at the front edge of the support to zero at the back of the bearing area.

The effective span should be taken as the distance between the centroids of the bearing pressure diagrams.

The lengths of the bearing areas and steel girders has been taken from the North London Rly. City Extension drawing.

Cast Iron Girders

The length of the bearing areas on the existing drawings as in

Clear span between sidewalls = in

Effective span = $297 + (2/3)24$
= in

Girders 20 and 35

The length of the bearing areas are in

The clear span is in

Effective span = $300 + (2/3)25.5$
= in

Girders 21 and 34

These girders bear onto the sidewalls and girders 25 and 31 respectively.

Overall length = in
Clear span between sidewall and girder 25/31 flange = in

Length of bearing = $303 - 264 - (16/2)$
= in

Effective span = $264 + 8 + (31/3)$
= in

Office	York Office	Page No.	19	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Effective Span	Checker		Date	Mar-25

Girder 22

The girder bears onto a sidewall and girder 25

$$\begin{aligned} \text{Overall length} &= 231 \text{ in} \\ \text{Clear span between sidewall and girder 25 flange} &= 192 \text{ in} \\ \text{Length of bearing} &= 231 - 192 - (16/2) \\ &= 31.00 \text{ in} \\ \text{Effective Span} &= 192 + 8.00 + (31/3) \\ &= 210.33 \text{ in} \end{aligned}$$

Girder 23

The girder bears onto a sidewall and girder 25

$$\begin{aligned} \text{Overall length} &= 154 \text{ in} \\ \text{Clear span between sidewall and girder 25 flange} &= 124 \text{ in} \\ \text{Length of bearing} &= 154 - 124 - (16/2) \\ &= 22.00 \text{ in} \\ \text{Effective Span} &= 124 + 8.00 + (22/3) \\ &= 139.33 \text{ in} \end{aligned}$$

Girder 24

The girder bears onto a sidewall and girder 25

$$\begin{aligned} \text{Overall length} &= 85 \text{ in} \\ \text{Clear span between sidewall and girder 25 flange} &= 55 \text{ in} \\ \text{Length of bearing} &= 85 - 55 - (16/2) \\ &= 22.00 \text{ in} \\ \text{Effective Span} &= 55 + 8.00 + (22/3) \\ &= 70.33 \text{ in} \end{aligned}$$

Girders 25, 28 and 31

The length of the bearing areas are 25.5 in

$$\begin{aligned} \text{The clear span is} &= 354 \text{ in} \\ \text{Effective span} &= 354 + (2/3)25.5 \\ &= 371.0 \text{ in} \end{aligned}$$

Office	York Office	Page No.	20	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Effective Span	Checker		Date	Mar-25

Girders 26, 27, 29 and 30

The lengths of the bearing are different at each end 37.5 in & 19.5 in

$$\text{Clear span} = \text{354} \text{ in}$$

$$\begin{aligned} \text{Effective span} &= 354 + (37.5/3) + (19.5/3) \\ &= \text{373.0} \text{ in} \end{aligned}$$

Girder 32

The girder bears onto a sidewall and girder 31

$$\text{Overall length} = \text{134.25} \text{ in}$$

$$\text{Clear span between sidewall and girder 31 flange} = \text{102.5} \text{ in}$$

$$\begin{aligned} \text{Length of bearing} &= 134.25 - 102.5 - (16/2) \\ &= \text{23.75} \text{ in} \end{aligned}$$

$$\begin{aligned} \text{Effective Span} &= 102.5 + 8 + (23.75/3) \\ &= \text{118.42} \text{ in} \end{aligned}$$

Girder 33

The girder bears onto a sidewall and girder 31

$$\text{Overall length} = \text{222.25} \text{ in}$$

$$\text{Clear span between sidewall and girder 31 flange} = \text{181.5} \text{ in}$$

$$\begin{aligned} \text{Length of bearing} &= 222.25 - 181.5 - (16/2) \\ &= \text{32.75} \text{ in} \end{aligned}$$

$$\begin{aligned} \text{Effective Span} &= 181.5 + 8 + (32.75/3) \\ &= \text{200.42} \text{ in} \end{aligned}$$

Office	York Office	Page No.	21	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Dead Loads

Unit Weights of Materials

BE4

Material	lb/cu.ft
Steel	490
Cast Iron	450
Concrete	150
Brickwork	140
Masonry	144
Miscellaneous Fill	135
Macadam (tar)	144

1 ton	=	2240	lb
1 ft	=	12	in
1 sq.ft	=	144	sq.in
1 cu.ft	=	1728	cu.in

Self Weight

Gross midspan used for a conservative assessment

Area of steel girders increased by 12% to account for fixings

Cast Iron Girders

Area of girder

Girder self weight UDL

$$\begin{aligned}
 &= 72.89 \text{ sq.in} \\
 (72.89/144) \times 450 &= 227.78 \text{ lb/ft} \\
 &= 0.102 \text{ ton/ft}
 \end{aligned}$$

Girders 20, 21, 34 and 35

Area of girder

Girder self weight UDL

$$\begin{aligned}
 56.44 \times 1.12 &= 63.21 \text{ sq.in} \\
 (63.21/144) \times 490 &= 215.09 \text{ lb/ft} \\
 &= 0.096 \text{ ton/ft}
 \end{aligned}$$

Girders 22 and 33

Area of girder

Girder self weight UDL

$$\begin{aligned}
 42.50 \times 1.12 &= 47.60 \text{ sq.in} \\
 (47.60/144) \times 490 &= 161.97 \text{ lb/ft} \\
 &= 0.072 \text{ ton/ft}
 \end{aligned}$$

Girders 23 and 32

Area of girder

Girder self weight UDL

$$\begin{aligned}
 26.00 \times 1.12 &= 29.12 \text{ sq.in} \\
 (29.12/144) \times 490 &= 99.09 \text{ lb/ft} \\
 &= 0.044 \text{ ton/ft}
 \end{aligned}$$

Girder 24

Area of girder

Girder self weight UDL

$$\begin{aligned}
 22.50 \times 1.12 &= 25.20 \text{ sq.in} \\
 (25.20/144) \times 490 &= 85.75 \text{ lb/ft} \\
 &= 0.038 \text{ ton/ft}
 \end{aligned}$$

Girders 25 and 31

Area of girder

Girder self weight UDL

$$\begin{aligned}
 81.44 \times 1.12 &= 91.21 \text{ sq.in} \\
 (91.21/144) \times 490 &= 310.37 \text{ lb/ft} \\
 &= 0.139 \text{ ton/ft}
 \end{aligned}$$

Office	York Office	Page No.	22	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Girders 26, 27, 29 and 30

Area of girder

$$67.88 \times 1.12 = 76.02 \text{ sq.in}$$

Girder self weight UDL

$$(76.02/144) \times 490 = 258.70 \text{ lb/ft}$$

$$= 0.115 \text{ ton/ft}$$

Girder 28

Area of girder

$$62.06 \times 1.12 = 69.51 \text{ sq.in}$$

Girder self weight UDL

$$(69.51/144) \times 490 = 236.53 \text{ lb/ft}$$


$$= 0.106 \text{ ton/ft}$$

Girders 1 to 7

The cover levels and deck make up are not known for these girders as there was no access into the Dalston Curve Garden at the north end of the tunnel at the time of the survey and inspection.

Girder 8

Girder 8 will be checked for dead loads as the survey found the fill depth to be the most onerous for the cast iron section.



Paving Stones

Width supported by girder

$$= 71.5 \text{ in}$$

Depth of paving stones (assumed)

$$= 2.5 \text{ in}$$

Area of paving stones

$$71.50 \times 2.5 = 178.75 \text{ sq.in}$$

Paving stones UDL

$$(178.75/144) \times 144 = 178.75 \text{ lb/ft}$$

$$= 0.080 \text{ ton/ft}$$

1" Asphalt Layer

Area of asphalt layer

$$= 71.5 \text{ sq.in}$$

Asphalt layer UDL

$$(71.50/144) \times 144 = 71.5 \text{ lb/ft}$$

$$= 0.032 \text{ ton/ft}$$

Office	York Office	Page No.	23	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Jack Arch

Arch Barrel Thickness		darch=	9.00	in
Arch Barrel Rise		a=	9.00	in
Jack Arch Span		2b=	51.50	in
		b=	25.75	in
Jack Arch Radius	R(Intrados)	$(a^2+b^2)/2a$	=	41.34 in
	R(Extrados)	$R(\text{Intrados})+darch$	=	50.34 in
		$\theta=$	38.53	°
	$\text{Sin}\theta=(b/R(\text{Intrados}))$			
Area of sector		$(2\theta/360) \times \pi \times R(\text{Intrados})^2$	=	1149.10 sq.in
Area of triangle		$b(R(\text{Intrados})-a)$	=	832.67 sq.in
Area of segment		Area of sector - Area of triangle	Aseg =	316.42 sq.in
Area of jack arch		$(2\theta/360) \times \pi(R(\text{Extrados})^2 - R(\text{Intrados})^2)$	Aarch =	554.84 sq.in
Jack arch UDL		$554.84/144 \times 140 =$	539.43	lb/ft
		=	0.241	ton/ft

Miscellaneous Fill

Area above asphalt layer		$38.75 \times 71.5 =$	2770.6	sq.in
Area between jack arches and asphalt layer				
Total area		$71.50 \times (2.06 + 17.44) =$	1394.3	sq.in
Area of fill				
Total - area JA - area segment - area web - area top flange		=	480.09	sq.in
Miscellaneous Fill UDL		$((480.09 + 2,770.63) / 144) \times 135 =$	3047.5	lb/ft
		=	1.361	ton/ft
Total UDL		=	1.815	ton/ft


Office	York Office	Page No.	24	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Girder 19

Girder 19 partially supports the carriageway and the pedestrian area to the north. It will be assumed the east half of the girder supports road and the west half supports footway.

The deck makeup of the road has been assumed based on the available historical information

The cross section below shows the girder at midspan.



Jack Arch

Arch Barrel Thickness

Arch Barrel Rise

Jack Arch Span

Jack Arch Radius

R(Intrados)

R(Extrados)

$(a^2+b^2)/2a$

$R(\text{Intrados})+darch$

$\text{Sin}\theta=(b/R(\text{Intrados}))$

Area of sector

Area of triangle

Area of segment

Area of jack arch



$(2\theta/360) \times \pi \times R(\text{Intrados})^2$

$b(R(\text{Intrados})-a)$

Area of sector - Area of triangle

$(2\theta/360) \times \pi (R(\text{Extrados})^2 - R(\text{Intrados})^2)$

darch= 9.00 in

a= 9.00 in

2b= 51.50 in

b= 25.75 in

= 41.34 in

= 50.34 in

θ = 38.53 °

= 1149.10 sq.in

= 832.67 sq.in

Aseg = 316.42 sq.in

Aarch = 554.84 sq.in

Jack arch UDL

$554.84/144 \times 140 \times 1/2 =$

269.71 lb/ft

= 0.120 ton/ft

Office	York Office	Page No.	25	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Jack Arch Backing

The backing has been assumed as miscellaneous fill as indicated on the available historical information as no intrusive investigations into the deck make up were undertaken as part of the inspection.

Girder spacing	=	71.50	in
Depth of fill	=	19.50	in
Area of fill	$(71.5 \times 19.5) - 554.84 - 316.42$	=	522.99 sq.in
Jack Arch Backing UDL	$(522.99/144) \times 135 \times 1/2$	=	245.15 lb/ft
		=	0.109 ton/ft

Concrete Infill

Area	$(7.5 \times 2.0625) + (9.625 \times 17.4375) + (0.5 \times 1.5)$	=	184.05 sq.in
Concrete Infill UDL	$(184.05/144) \times 150$	=	191.72 lb/ft
		=	0.086 ton/ft

1" Asphalt Layer

Width supported by girder	=	46.25	in
Area of asphalt layer	=	46.25	sq.in
Asphalt layer UDL	$(46.25/144) \times 144$	=	46.25 lb/ft
		=	0.021 ton/ft

Pedestrian Area

Width supported by girder	=	46.25	in
Depth of miscellaneous fill	=	17	in
Area of miscellaneous fill	46.25×17	=	786.25 sq.in
Miscellaneous fill UDL	$(786.25/144) \times 135$	=	737.11 lb/ft
		=	0.329 ton/ft
Depth of paving stones (assumed)	=	2.5	in
Area of paving stones	46.25×2.5	=	115.63 sq.in
Paving stones UDL	$(115.63/144) \times 144$	=	115.63 lb/ft
		=	0.052 ton/ft
Pedestrian section UDL	=	0.381	ton/ft

Office	York Office	Page No.	26	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25


Road

Width supported by girder	=	46.25	in
Depth of miscellaneous fill	=	6.5	in
Area of miscellaneous fill	46.25 x 6.5 =	300.63	sq.in
Miscellaneous fill UDL	(300.63/144) x 135 =	281.84	lb/ft
	=	0.126	ton/ft
Depth of concrete (assumed)	=	4	in
Area of concrete	46.25 x 4.0 =	185	sq.in
Concrete UDL	(185.00/144) x 150 =	192.71	lb/ft
	=	0.086	ton/ft
Depth of surfacing (assumed)	=	4	in
Area of surfacing	46.25 x 4.0 =	185	sq.in
Surfacing UDL	(185/144) x 144 =	185	lb/ft
	=	0.083	ton/ft
Road section UDL	=	0.294	ton/ft
UDL at east end	=	0.631	ton/ft
UDL at west end	=	0.717	ton/ft

Girder 20

Girder 20 also partially supports the pedestrian area at the west end.

The unit weight of the concrete slabs between the steel girders will be assumed as **157.5 lb/cu.ft** to represent reinforced concrete.



Office	York Office	Page No.	27	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Concrete Encasement

Width of encasement	=	15.5	in
Depth of encasement	=	21	in
Area of encasement	$(15.5 \times 21.0) - 56.44 =$	269.06	sq.in
Encasement UDL	$(269.06/144) \times 150 =$	280.27	lb/ft
	=	0.125	ton/ft

Concrete 'slab'

Width of slab supported by girder	=	16	in
Depth of slab	=	9	in
Area of slab	=	144	sq.in
Slab UDL	$(144/144) \times 157.5 =$	157.5	lb/ft
	=	0.070	ton/ft

Asphalt layer

Area of asphalt layer	$(15.5 \times 1) + ((13 + 15.25) \times 0.75) =$	36.69	sq.in
Asphalt layer UDL	$(36.69/144) \times 144 =$	36.69	lb/ft
	=	0.016	ton/ft

Pedestrian area

Width supported by girder	=	31.5	in
Area of miscellaneous fill	$(17 \times 31.5) + (15.25 \times 12.25) =$	722.31	sq.in
Miscellaneous fill UDL	$(722.31/144) \times 135 =$	677.17	lb/ft
	=	0.302	ton/ft
Area of slabs	$31.50 \times 2.50 =$	78.75	sq.in
Slab UDL	$(78.75/144) \times 144 =$	78.75	lb/ft
	=	0.035	ton/ft
Pedestrian area UDL	=	0.337	ton/ft


Office	York Office	Page No.	28	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Road

Depth of surfacing	=	4	in
Area of surfacing	4 x 31.50 =	126	sq.in
Surfacing UDL	(126/144) x 144 =	126.0	lb/ft
	=	0.056	ton/ft
Depth of concrete	=	4	in
Area of concrete	4 x 31.50 =	126	sq.in
Concrete UDL	(126/144) x 150 =	131.3	lb/ft
	=	0.059	ton/ft
Miscellaneous fill area	(6.5 x 31.50) + (12.25 x 15.25) =	391.56	sq.in
Miscellaneous fill UDL	(391.56/144) x 135 =	367.1	lb/ft
	=	0.164	ton/ft
Total road UDL	=	0.279	ton/ft
UDL at east end	=	0.461	ton/ft
UDL at west end	=	0.645	ton/ft

Girder 21

This girder carries a small portion of the pedestrian area at the west end.



Office	York Office	Page No.	29	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Concrete Encasement

Width of encasement	=	16	in
Depth of encasement	=	20.75	in
Area of encasement	(16.0 x 20.8) - 56.44 =	275.56	sq.in
Encasement UDL	(275.56/144) x 150 =	287.04	lb/ft
	=	0.128	ton/ft

Concrete 'slab'

Width of slab supported by girder	=	32.5	in
Depth of slab	=	9	in
Area of slab	=	292.5	sq.in
Slab UDL	(293/144) x 157.5 =	319.92	lb/ft
	=	0.143	ton/ft

Asphalt layer

Area of asphalt layer	0.75 x (15.25+12.75+16+12.75+15.5) =	54.19	sq.in
Asphalt layer UDL	(54.19/144) x 144 =	54.19	lb/ft
	=	0.024	ton/ft

Pedestrian Area

Width supported by girder	=	48.5	in
Area of miscellaneous fill	29.25(15.25+15.5)+(17.5 x 17.5) =	1205.7	sq.in
Miscellaneous fill UDL	(1,205.69/144) x 135 =	1130.3	lb/ft
	=	0.505	ton/ft
Area of slabs	48.50 x 2.5 =	121.25	sq.in
Slab UDL	(121.25/144) x 144 =	121.25	lb/ft
	=	0.054	ton/ft
Pedestrian area UDL	=	0.559	ton/ft

Office	York Office	Page No.	31	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Concrete encasement

Width of encasement = 14 in
 Depth of encasement = 16.75 in

Area of encasement $(14.0 \times 16.8) - 42.50 = 192$ sq.in

Encasement UDL $(192.00/144) \times 150 = 200$ lb/ft
 = 0.089 ton/ft

Concrete 'slab'

Width of slab supported by girder = 34.25 in
 Depth of slab = 9 in

Area of slab = 308.25 sq.in

Slab UDL $(308/144) \times 157.5 = 337.15$ lb/ft
 = 0.151 ton/ft

Asphalt layer

Area of asphalt layer $0.75 \times (15.5 + 8.5 + 14 + 8.5 + 17) = 47.63$ sq.in

Asphalt layer UDL $(47.63/144) \times 144 = 47.63$ lb/ft
 = 0.021 ton/ft

Surfacing

Width of surfacing supported by girder = 48.25 in
 Depth of surfacing = 4 in

Area of surfacing = 193 sq.in

Surfacing UDL $(193/144) \times 144.0 = 193$ lb/ft
 = 0.086 ton/ft

Concrete

Width of concrete supported by girder = 48.25 in
 Depth of concrete = 4 in

Area of concrete = 193 sq.in

Concrete UDL $(193/144) \times 150.0 = 201.04$ lb/ft
 = 0.090 ton/ft

Office	York Office	Page No.	32	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25


Miscellaneous Fill

Miscellaneous fill area $18.75(15.75 + 17) + (11 \times 15.5) = 784.56$ sq.in

Miscellaneous fill UDL $(784.56/144) \times 135 = 735.5$ lb/ft
 $= 0.328$ ton/ft

Total UDL on Girder 22 $= 0.838$ ton/ft

Girder 23



Concrete encasement

Width of encasement $= 11$ in

Depth of encasement $= 16.25$ in

Area of encasement $(11.0 \times 16.3) - 26.00 = 152.75$ sq.in

Encasement UDL $(152.75/144) \times 150 = 159.11$ lb/ft
 $= 0.071$ ton/ft

Concrete 'slab'

Width of slab supported by girder $= 36.25$ in

Depth of slab $= 9$ in

Area of slab $= 326.25$ sq.in

Slab UDL $(326/144) \times 157.5 = 356.84$ lb/ft
 $= 0.159$ ton/ft

Office	York Office	Page No.	33	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Asphalt layer

Area of asphalt layer $0.75(17+7.25+12.5+7.25+17.75) =$ 46.31 sq.in

Asphalt layer UDL $(46.31/144) \times 144 =$ 46.31 lb/ft
 $=$ 0.021 ton/ft

Surfacing

Width of surfacing supported by girder $=$ 47.25 in

Depth of surfacing $=$ 4 in

Area of surfacing $=$ 189 sq.in

Surfacing UDL $(189/144) \times 144.0 =$ 189 lb/ft
 $=$ 0.084 ton/ft

Concrete

Width of concrete supported by girder $=$ 47.25 in

Depth of concrete $=$ 4 in

Area of concrete $=$ 189 sq.in

Concrete UDL $(189/144) \times 150.0 =$ 196.88 lb/ft
 $=$ 0.088 ton/ft

Miscellaneous Fill

Miscellaneous fill area $18.47(17+17.75) + (11.22 \times 12.5) =$ 782.08 sq.in


Miscellaneous fill UDL $(782.08/144) \times 135 =$ 733.2 lb/ft
 $=$ 0.327 ton/ft

Total UDL on Girder 23 $=$ 0.795 ton/ft

Office	York Office	Page No.	34	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Girder 24

The distance between girder 24 and 25 will be taken as the average



Concrete encasement

Width of encasement	=	11	in
Depth of encasement	=	13.25	in
Area of encasement	$(11.0 \times 13.3) - 22.50 =$	123.25	sq.in
Encasement UDL	$(123.25/144) \times 150 =$	128.39	lb/ft
	=	0.057	ton/ft

Concrete 'slab'

Width of slab supported by girder	=	25	in
Depth of slab	=	9	in
Area of slab	=	225	sq.in
Slab UDL	$(225/144) \times 157.5 =$	246.09	lb/ft
	=	0.110	ton/ft

Asphalt layer

Area of asphalt layer	$0.75(17.5+4.25+12.5+4.25+5.5) =$	33.00	sq.in
Asphalt layer UDL	$(33.00/144) \times 144 =$	33.00	lb/ft
	=	0.015	ton/ft

Office	York Office	Page No.	35	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Surfacing

Width of surfacing supported by girder = $\boxed{36}$ in
 Depth of surfacing = $\boxed{4}$ in
 Area of surfacing = $\boxed{144}$ sq.in
Surfacing UDL (144/144) x 144.0 = $\boxed{144}$ lb/ft
 = $\boxed{0.064}$ ton/ft

Concrete


Width of concrete supported by girder = $\boxed{36}$ in
 Depth of concrete = $\boxed{4}$ in
 Area of concrete = $\boxed{144}$ sq.in
Concrete UDL (144/144) x 150.0 = $\boxed{150}$ lb/ft
 = $\boxed{0.067}$ ton/ft

Miscellaneous Fill

Miscellaneous fill area $18.47(17.75+5.75) + (14.22 \times 12.5) = \boxed{611.8}$ sq.in
Miscellaneous fill UDL (611.80/144) x 135 = $\boxed{573.6}$ lb/ft
 = $\boxed{0.256}$ ton/ft
Total UDL on Girder 24 = $\boxed{0.607}$ ton/ft

Office	York Office	Page No.	36	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Girder 25



Fill depth at midspan taken

Concrete encasement

Width of encasement	=	16.5	in
Depth of encasement	=	28	in
Area of encasement	$(16.5 \times 28.0) - 81.44$	=	380.56 sq.in
Encasement UDL	$(380.56/144) \times 150$	=	396.42 lb/ft
		=	0.177 ton/ft

Concrete 'slab'

Width of slab supported by girder	=	0.75	in
Depth of slab	=	9	in
Area of slab	=	6.75	sq.in
Slab UDL	$(6.75/144) \times 157.5$	=	7.3828 lb/ft
		=	0.003 ton/ft

Asphalt layer

Area of asphalt layer	$0.75(19.75+16.5)$	=	27.19 sq.in
Asphalt layer UDL	$(27.19/144) \times 144$	=	27.19 lb/ft
		=	0.012 ton/ft

Office	York Office	Page No.	37	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Surfacing

Width of surfacing supported by girder = 17.25 in
 Depth of surfacing = 4 in

Area of surfacing = 69 sq.in

Surfacing UDL (69/144) x 144.0 = 69 lb/ft
 = 0.031 ton/ft

Concrete

Width of concrete supported by girder = 17.25 in
 Depth of concrete = 10.64 in

Area of concrete = 183.54 sq.in

Concrete UDL (184/144) x 150.0 = 191.19 lb/ft
 = 0.085 ton/ft

Miscellaneous Fill

Miscellaneous fill area 19 x 6.5 = 123.5 sq.in


Miscellaneous fill UDL (123.50/144) x 135 = 115.8 lb/ft
 = 0.052 ton/ft

Total UDL on Girder 25 = 0.499 ton/ft

Office	York Office	Page No.	38	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Girder 26

Section at midspan taken. Area of concrete between Girders 26 and 27 has been estimated from historical information.



Concrete 'slab'

Width of slab supported by girder	=	6.25	in
Depth of slab	=	9	in
Area of slab	=	56.25	sq.in
Slab UDL	(56/144) x 157.5 =	61.523	lb/ft
	=	0.027	ton/ft

Concrete Encasement

Area at top flange	(18.5 x 5.5) - 18.0 =	83.75	sq.in
Area at bottom flange	(14.5 x 2) - 14.0 =	15.00	sq.in
Area to left of web	(27.875 x 7.1875) - 0.625(8 + 6.75) =	191.13	sq.in
Area between web and 'slab'	(6.6875 x 7) - 0.625(4+3.375) =	42.20	sq.in
Area to right of web	(6.375 + 11.5)/2 x 12.9375 =	115.63	sq.in
Area of encasement	=	447.71	sq.in
Encasement UDL	(447.71/144) x 150 =	466.37	lb/ft
	=	0.208	ton/ft

Office	York Office	Page No.	39	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Miscellaneous Fill

Miscellaneous fill area = 162.21 sq.in

Miscellaneous fill UDL (162.21/144) x 135 = 152.1 lb/ft
= 0.068 ton/ft

Surfacing

Width of surfacing supported by girder = 20.75 in

Depth of surfacing = 4 in

Area of surfacing = 83 sq.in

Surfacing UDL (83/144) x 144.0 = 83 lb/ft
= 0.037 ton/ft

Concrete

Width of concrete supported by girder = 20.75 in

Depth of concrete = 4 in


Area of concrete = 83 sq.in

Concrete UDL (83/144) x 150.0 = 86.458 lb/ft
= 0.039 ton/ft

Total UDL on Girder 26 = 0.495 ton/ft

Office	York Office	Page No.	40	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Girders 27 and 29



Concrete Encasement

Area at bottom flange	$14 \times 1 =$	14.00	sq.in
Area to right of web	$(6.6875 \times 27.875) - 0.625(8+6.75) =$	177.2	sq.in
Area between web and 'slab'	$(6.6875 \times 7) - 0.625(4+3.375) =$	42.20	sq.in
Area to left of web	$(6.375 + 11.5)/2 \times 12.9375 =$	115.63	sq.in

Area of encasement = **349.03** sq.in

Encasement UDL $(349.03/144) \times 150 =$ **363.57** lb/ft
 = **0.162** ton/ft

Concrete 'slab'

Width of slab supported by girder = **18.125** in
 Depth of slab = **9** in

Area of slab = **163.13** sq.in

Slab UDL $(163/144) \times 157.5 =$ **178.42** lb/ft
 = **0.080** ton/ft

Office	York Office	Page No.	41	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Surfacing

Width of surfacing supported by girder = 32.125 in
 Depth of surfacing = 4 in

Area of surfacing = 128.5 sq.in

Surfacing UDL (129/144) x 144.0 = 128.5 lb/ft
 = 0.057 ton/ft

Concrete

Width of concrete supported by girder = 32.125 in
 Depth of concrete = 4 in

Area of concrete above top flange = 123.52 sq.in

Total area of concrete = 252.02 sq.in

Concrete UDL (252/144) x 150.0 = 262.52 lb/ft
 = 0.117 ton/ft

Asphalt layer

Area of asphalt layer $0.75(2.6875 + 21.875 + 11.875) = 27.33$ sq.in

Asphalt layer UDL (27.33/144) x 144 = 27.33 lb/ft
 = 0.012 ton/ft

Miscellaneous Fill


Miscellaneous fill area = 405.57 sq.in

Miscellaneous fill UDL (405.57/144) x 135 = 380.2 lb/ft
 = 0.170 ton/ft

Total UDL on Girder 27 = 0.714 ton/ft

Office	York Office	Page No.	42	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Girder 28



Concrete encasement

Width of encasement = 16 in
 Depth of encasement = 29.5 in

Area of encasement $(16.0 \times 29.5) - 62.06 = 409.94$ sq.in

Encasement UDL $(409.94/144) \times 150 = 427.02$ lb/ft
 = 0.191 ton/ft

Concrete 'slab'

Width of slab supported by girder = 21.75 in
 Depth of slab = 9 in

Area of slab = 195.75 sq.in

Slab UDL $(196/144) \times 157.5 = 214.1$ lb/ft
 = 0.096 ton/ft

Asphalt layer

Area of asphalt layer $0.75(10.125+20.5+17.5+20.5+10.125) = 59.06$ sq.in

Asphalt layer UDL $(59.06/144) \times 144 = 59.06$ lb/ft
 = 0.026 ton/ft

Office	York Office	Page No.	43	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Miscellaneous Fill

Miscellaneous fill area $2 \times 10.125 \times 21.875 = 442.97$ sq.in

Miscellaneous fill UDL $(442.97/144) \times 135 = 415.3$ lb/ft
 $= 0.185$ ton/ft

Surfacing

Width of surfacing supported by girder $= 37.75$ in
 Depth of surfacing $= 4$ in

Area of surfacing $= 151$ sq.in

Surfacing UDL $(151/144) \times 144.0 = 151$ lb/ft
 $= 0.067$ ton/ft

Concrete

Width of concrete supported by girder $= 37.75$ in
 Depth of concrete $= 4$ in

Area of concrete above top flange $= 166.29$ sq.in


Total area of concrete $= 317.29$ sq.in

Concrete UDL $(317/144) \times 150.0 = 330.51$ lb/ft
 $= 0.148$ ton/ft

Total UDL on Girder 28 $= 0.819$ ton/ft

Office	York Office	Page No.	44	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Girder 30



Concrete Encasement

Area at bottom flange	$14 \times 1 =$	14.00	sq.in
Area to right of web	$(6.6875 \times 27.875) - 0.625(8+6.75) =$	177.2	sq.in
Area between web and 'slab'	$(6.6875 \times 7) - 0.625(4+3.375) =$	42.20	sq.in
Area to left of web	$(6.375 + 11.5)/2 \times 12.9375 =$	115.63	sq.in

Area of encasement = **349.03** sq.in

Encasement UDL $(349.03/144) \times 150 =$ **363.57** lb/ft
 = **0.162** ton/ft

Concrete 'slab'

Width of slab supported by girder = **14.625** in
 Depth of slab = **9** in

Area of slab = **131.63** sq.in

Slab UDL $(132/144) \times 157.5 =$ **143.96** lb/ft
 = **0.064** ton/ft

Asphalt layer

Area of asphalt layer $0.75(2.6875 + 21.875 + 8.375) =$ **24.70** sq.in

Asphalt layer UDL $(24.70/144) \times 144 =$ **24.70** lb/ft
 = **0.011** ton/ft

Office	York Office	Page No.	45	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Miscellaneous Fill

Miscellaneous fill area = 329 sq.in

Miscellaneous fill UDL (329.00/144) x 135 = 308.4 lb/ft
= 0.138 ton/ft

Surfacing

Width of surfacing supported by girder = 28.625 in
Depth of surfacing = 4 in

Area of surfacing = 114.5 sq.in

Surfacing UDL (115/144) x 144.0 = 114.5 lb/ft
= 0.051 ton/ft

Concrete

Width of concrete supported by girder = 28.625 in
Depth of concrete = 4 in

Area of concrete above top flange = 110.39 sq.in

Total area of concrete = 224.89 sq.in

Concrete UDL (225/144) x 150.0 = 234.26 lb/ft
= 0.105 ton/ft


Total UDL on Girder 30 = 0.646 ton/ft

Office	York Office	Page No.	46	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Girder 31

Girders 32, 33 and 34 bear onto Girder 31 at an angle.

The UDL on Girder 31 will be estimated using the following:



Concrete encasement

Width of encasement	=	17	in
Depth of encasement	=	28	in
Area of encasement	$(17.0 \times 28.0) - 81.44$	=	394.56 sq.in
Encasement UDL	$(394.56/144) \times 150$	=	411 lb/ft
		=	0.183 ton/ft

Concrete 'slab'

Width of slab supported by girder	=	18.63	in
Depth of slab	=	9	in
Area of slab	=	167.63	sq.in
Slab UDL	$(168/144) \times 157.5$	=	183.34 lb/ft
		=	0.082 ton/ft

Office	York Office	Page No.	47	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Asphalt layer

Area of asphalt layer = 55.22 sq.in

Asphalt layer UDL (55.22/144) x 144 = 55.22 lb/ft
= 0.025 ton/ft

Miscellaneous Fill

Miscellaneous fill area = 433.48 sq.in

Miscellaneous fill UDL remainder (433.48/144) x 135 = 406.4 lb/ft
= 0.181 ton/ft

Surfacing

Width of surfacing supported by girder = 34.875 in

Depth of surfacing = 4 in

Area of surfacing = 139.5 sq.in

Surfacing UDL (139.50/144) x 144.0 = 139.5 lb/ft
= 0.062 ton/ft

Concrete

Width of concrete supported by girder = 34.88 in

Depth of concrete = 4 in

Area of concrete above top flange = 126.15 sq.in


Area of concrete = 265.65 sq.in

Concrete UDL (265.65/144) x 150.0 = 276.71 lb/ft
= 0.124 ton/ft

Total UDL = 0.796 ton/ft

Office	York Office	Page No.	48	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Girder 32



Concrete encasement

Width of encasement	=	11	in
Depth of encasement	=	16.5	in
Area of encasement	$(11.0 \times 16.5) - 26.00 =$	155.5	sq.in
Encasement UDL	$(155.50/144) \times 150 =$	161.98	lb/ft
	=	0.072	ton/ft

Concrete 'slab'

Width of slab supported by girder	=	29.625	in
Depth of slab	=	9	in
Area of slab	=	266.63	sq.in
Slab UDL	$(266.63/144) \times 157.5 =$	291.62	lb/ft
	=	0.130	ton/ft

Asphalt layer

Area of asphalt layer	=	41.72	sq.in
Asphalt layer UDL	$(41.72/144) \times 144 =$	41.72	lb/ft
	=	0.019	ton/ft

Miscellaneous Fill

Miscellaneous fill area	=	947.88	sq.in
-------------------------	---	--------	-------

Office	York Office	Page No.	49	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Miscellaneous fill UDL $(947.88/144) \times 135 =$ 888.6 lb/ft
 $=$ 0.397 ton/ft

Surfacing

Width of surfacing supported by girder $=$ 40.625 in
 Depth of surfacing $=$ 4 in

Area of surfacing $=$ 162.5 sq.in

Surfacing UDL $(163/144) \times 144.0 =$ 162.5 lb/ft
 $=$ 0.073 ton/ft

Concrete

Width of concrete supported by girder $=$ 40.625 in
 Depth of concrete $=$ 4 in

Area of concrete $=$ 162.5 sq.in


Concrete UDL $(162.50/144) \times 150.0 =$ 169.27 lb/ft
 $=$ 0.076 ton/ft

Total UDL on Girder 32 $=$ 0.810 ton/ft

Office	York Office	Page No.	50	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Girder 33

The east end of the girder supports footway but the additional dead load will be negligible and therefore the deck makeup of the carriageway will be used.



Concrete encasement

Width of encasement	=	14	in
Depth of encasement	=	17	in
Area of encasement	$(14.0 \times 17.0) - 42.50$	=	195.5 sq.in
Encasement UDL	$(195.50/144) \times 150$	=	203.65 lb/ft
		=	0.091 ton/ft

Concrete 'slab'

Width of slab supported by girder	=	37.5	in
Depth of slab	=	9	in
Area of slab	=	337.5	sq.in
Slab UDL	$(337.50/144) \times 157.5$	=	369.14 lb/ft
		=	0.165 ton/ft

Asphalt layer

Area of asphalt layer	=	50.63	sq.in
Asphalt layer UDL	$(50.63/144) \times 144$	=	50.63 lb/ft
		=	0.023 ton/ft

Office	York Office	Page No.	51	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Miscellaneous Fill

Miscellaneous fill area = 1196.5 sq.in

Miscellaneous fill UDL (1,196.46/144) x 135 = 1121.7 lb/ft
= 0.501 ton/ft

Surfacing

Width of surfacing supported by girder = 51.5 in

Depth of surfacing = 4 in

Area of surfacing = 206 sq.in

Surfacing UDL (206/144) x 144.0 = 206 lb/ft
= 0.092 ton/ft

Concrete

Width of concrete supported by girder = 51.5 in

Depth of concrete = 4 in

Area of concrete = 206 sq.in

Concrete UDL (206.00/144) x 150.0 = 214.58 lb/ft
= 0.096 ton/ft


Total UDL on Girder 33 = 1.039 ton/ft

Office	York Office	Page No.	52	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Girder 34

Girder 34 partially supports the carriageway and the footway to the south. It will be assumed the west half of the girder supports road and the east half supports footway.

The cross section below shows the girder at midspan.



Concrete encasement

Width of encasement	=	16	in
Depth of encasement	=	21	in
Area of encasement	$(16.0 \times 21.0) - 56.44$	=	279.56 sq.in
Encasement UDL	$(279.56/144) \times 150$	=	291.21 lb/ft
		=	0.130 ton/ft

Concrete 'slab'

Width of slab supported by girder	=	33.875	in
Depth of slab	=	9	in
Area of slab	=	304.88	sq.in
Slab UDL	$(304.88/144) \times 157.5$	=	333.46 lb/ft
		=	0.149 ton/ft

Office	York Office	Page No.	53	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Asphalt layer

Area of asphalt layer = 55.41 sq.in

Asphalt layer UDL (55.41/144) x 144 = 55.41 lb/ft
= 0.025 ton/ft

Carriageway Area

Miscellaneous Fill

Miscellaneous fill area = 1068.8 sq.in

Miscellaneous fill UDL (1,068.80/144) x 135 = 1002.0 lb/ft
= 0.447 ton/ft

Concrete

Width of concrete supported by girder = 49.875 in

Depth of concrete = 4 in

Area of concrete = 199.5 sq.in

Concrete UDL (199.50/144) x 150.0 = 207.81 lb/ft
= 0.093 ton/ft

Surfacing

Width of surfacing supported by girder = 49.875 in

Depth of surfacing = 4 in

Area of surfacing = 199.5 sq.in

Surfacing UDL (200/144) x 144.0 = 199.5 lb/ft
= 0.089 ton/ft

Footway Area

Miscellaneous Fill

Miscellaneous fill area = 1559.6 sq.in

Miscellaneous fill UDL (1,559.57/144) x 135 = 1462.1 lb/ft
= 0.653 ton/ft


Office	York Office	Page No.	54	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Concrete slabs

Width of concrete supported by girder	=	49.875	in
Depth of concrete	=	2.5	in
Area of concrete	=	124.69	sq.in
Concrete UDL	(124.69/144) x 150.0 =	129.88	lb/ft
	=	0.058	ton/ft
UDL on Girder 34 under carriageway	=	1.029	ton/ft
UDL on Girder 34 under footway	=	1.110	ton/ft

Girder 35

Girder 35 partially supports the carriageway and the footway to the south. It will be assumed the west half of the girder supports road and the east half supports footway. The cross section below shows the girder at midspan.



Concrete encasement

Width of encasement	=	15.5	in
Depth of encasement	=	21	in
Area of encasement	(15.5 x 21.0) - 56.44 =	269.06	sq.in
Encasement UDL	(269.06/144) x 150 =	280.27	lb/ft
	=	0.125	ton/ft

Office	York Office	Page No.	55	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Concrete 'slab'

Width of slab supported by girder	=	15.75	in
Depth of slab	=	9	in
Area of slab	=	141.75	sq.in
Slab UDL	(141.75/144) x 157.5 =	155.04	lb/ft
	=	0.069	ton/ft

Asphalt layer

Area of asphalt layer	=	31.88	sq.in
Asphalt layer UDL	(31.88/144) x 144 =	31.88	lb/ft
	=	0.014	ton/ft

Carriageway Area

Miscellaneous Fill

Miscellaneous fill area	=	606.25	sq.in
Miscellaneous fill UDL	(606.25/144) x 135 =	568.4	lb/ft
	=	0.254	ton/ft

Concrete

Width of concrete supported by girder	=	31.25	in
Depth of concrete	=	4	in
Area of concrete	=	125	sq.in
Concrete UDL	(125.00/144) x 150.0 =	130.21	lb/ft
	=	0.058	ton/ft

Surfacing

Width of surfacing supported by girder	=	31.25	in
Depth of surfacing	=	4	in
Area of surfacing	=	125	sq.in
Surfacing UDL	(125/144) x 144.0 =	125	lb/ft
	=	0.056	ton/ft

Office	York Office	Page No.	56	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Loads	Checker		Date	Mar-25

Footway Area

Miscellaneous Fill

Miscellaneous fill area = 913.75 sq.in

Miscellaneous fill UDL $(913.75/144) \times 135 = 856.6$ lb/ft
 = 0.382 ton/ft

Concrete slabs

Width of concrete supported by girder = 31.25 in
 Depth of concrete = 2.5 in

Area of concrete = 78.125 sq.in

Concrete UDL $(78.13/144) \times 150.0 = 81.38$ lb/ft
 = 0.036 ton/ft

UDL on Girder 35 under carriageway = 0.672 ton/ft

UDL on Girder 35 under footway = 0.723 ton/ft

Office	York Office	Page No.	57	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Load Effects	Checker		Date	Mar-25

Dead Load Effects

The maximum bending moment and shear force in a beam with a UDL are given by:


$$\text{Maximum Bending Moment} \quad M_{max} = \frac{wl^2}{8}$$

$$\text{Maximum Shear Force} \quad V_{max} = \frac{wl}{2}$$

Girder 8

$$\text{DL UDL} = 1.815 \text{ ton/ft}$$


$$\text{MDL} = 154.33 \text{ ton.ft}$$



$$\text{VDL} = 23.67 \text{ ton}$$

Girder 19

The girder partially supports the pedestrian area to the north therefore assume the following:



$$\begin{aligned} RE &= \frac{((0.717 \times 13.042 \times 6.521) + (0.631 \times 13.042 \times 19.563))}{26.083} \\ &= 8.50 \text{ ton} \end{aligned}$$

$$\begin{aligned} RW &= (0.717 \times 13.042) + (0.631 \times 13.042) - 8.504 \\ &= 9.07 \text{ ton} \end{aligned}$$


Maximum moment occurs 12.649 ft from the west end

$$\begin{aligned} M_{max} &= 0.5 \times 9.07 \times 12.649 \\ &= 57.34 \text{ ton.ft} \end{aligned}$$

Office	York Office	Page No.	58	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Load Effects	Checker		Date	Mar-25

Girder 20

The girder partially supports the pedestrian are to the north therefore assume the following:



$$RE = \frac{((0.645 \times 10.583 \times 5.292) + (0.461 \times 15.833 \times 18.500))}{26.417}$$

$$= 6.48 \text{ ton}$$

$$RW = (0.645 \times 10.583) + (0.461 \times 15.833) - 6.48$$

$$= 7.65 \text{ ton}$$

Maximum moment occurs 14.053 ft from the east end


$$M_{max} = 0.5 \times 6.48 \times 14.053$$

$$= 45.56 \text{ ton.ft}$$

$$M_{midspan} = 45.40 \text{ ton.ft}$$

Girder 21

The girder partially supports the pedestrian are to the north therefore assume the following:



$$RE = \frac{((0.950 \times 4.581 \times 2.291) + (0.861 \times 18.947 \times 14.054))}{23.528}$$

$$= 10.16 \text{ ton}$$

$$RW = (0.950 \times 4.581) + (0.861 \times 18.947) - 10.16$$

$$= 10.49 \text{ ton}$$

Maximum moment occurs 11.81 ft from the east end

$$M_{max} = 0.5 \times 10.16 \times 11.810$$

$$= 60.017 \text{ ton.ft}$$


$$M_{midspan} = 60.016 \text{ ton.ft}$$

Office	York Office	Page No.	59	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Load Effects	Checker		Date	Mar-25

Girder 22

$$DL\ UDL = 0.838\ \text{ton/ft}$$

$$MDL = 32.17\ \text{ton.ft}$$




$$VDL = 7.34\ \text{ton}$$

Girder 23

$$DL\ UDL = 0.795\ \text{ton/ft}$$

$$MDL = 13.39\ \text{ton.ft}$$




$$VDL = 4.61\ \text{ton}$$

Girder 24

$$DL\ UDL = 0.607\ \text{ton/ft}$$

$$MDL = 2.61\ \text{ton.ft}$$




$$VDL = 1.78\ \text{ton}$$

Girder 25

Imposed loads due to UDL


$$DL\ UDL = 0.499\ \text{ton/ft}$$

$$MUDL = 59.60\ \text{ton.ft}$$



$$VUDL = 7.71\ \text{ton}$$

Consider the following arrangement for the imposed dead loads from girders 21, 22, 23 and 24



Office	York Office	Page No.	60	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Load Effects	Checker		Date	Mar-25

Imposed loads due to girders

$$RW = ((10.16 \times 2.750) + (7.34 \times 10.007) + (4.61 \times 17.265) + (1.78 \times 24.459)) / 30.917$$

$$= 7.27 \text{ ton}$$

$$RE = 10.16 + 7.34 + 4.61 + 1.78 - 7.27$$

$$= 16.63 \text{ ton}$$

Maximum moment occurs 10.007 ft from the east end

$$M_{max} = (16.63 \times 2.750) + (6.47 \times 7.257)$$

$$= 92.70 \text{ ton.ft}$$

Combined imposed loads

$$RW = 14.98 \text{ ton}$$

$$RE = 24.34 \text{ ton}$$

Maximum moment occurs 13.713 ft from the east end

$$M_{max} = 148.31 \text{ ton.ft}$$

$$\text{Moment at midspan} = 147.44 \text{ ton.ft}$$

The girder will also be checked at the curtailment points of the additional plates
The additional plates are 18' - 8" and 12' - 0" long, the plates therefore curtail
6.125 ft and 9.458 ft from each support

$$\text{Shear at } 6.125 \text{ ft} = 24.34 - 10.16 - (0.499 \times 6.125) \quad (\text{from E end})$$

$$= 11.13 \text{ ton}$$

$$\text{Moment} = ((24.34 + 22.97) / 2) \times 2.750 + ((12.81 + 11.126) / 2) \times 3.375$$

$$= 105.45 \text{ ton.ft}$$

$$\text{Shear at } 9.458 \text{ ft} = 24.34 - 10.16 - (0.499 \times 9.46) \quad (\text{from E end})$$

$$= 9.46 \text{ ton}$$

$$\text{Moment} = 105.45 + (((11.13 + 9.46) / 2) \times 3.333)$$


$$= 139.76 \text{ ton.ft}$$

Office	York Office	Page No.	61	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Load Effects	Checker		Date	Mar-25

Girder 26


$$\text{DL UDL} = 0.495 \text{ ton/ft}$$

$$\text{MDL} = 59.75 \text{ ton.ft}$$



$$\text{VDL} = 7.69 \text{ ton}$$

Girder 26 will also be checked at the locations of the cut outs and curtailment points of the additional plates, see sketch below.



$$\begin{aligned} \text{Shear at } 5.00 \text{ ft} &= 7.69 - (0.495 \times 5.00) && (60") \\ &= 5.21 \text{ ton} \end{aligned}$$

$$\begin{aligned} \text{Moment} &= ((7.69 + 5.21) / 2) \times 5.00 \\ &= 32.26 \text{ ton.ft} \end{aligned}$$

$$\begin{aligned} \text{Shear at } 5.90 \text{ ft} &= 7.69 - (0.495 \times 5.90) && (70.75") \\ &= 4.77 \text{ ton} \end{aligned}$$

$$\begin{aligned} \text{Moment} &= ((7.69 + 4.77) / 2) \times 5.90 \\ &= 36.73 \text{ ton.ft} \end{aligned}$$

$$\begin{aligned} \text{Shear at } 7.02 \text{ ft} &= 7.69 - (0.495 \times 7.02) && (84.25") \\ &= 4.22 \text{ ton} \end{aligned}$$

$$\begin{aligned} \text{Moment} &= ((7.69 + 4.22) / 2) \times 7.02 \\ &= 41.79 \text{ ton.ft} \end{aligned}$$

$$\begin{aligned} \text{Shear at } 11.08 \text{ ft} &= 7.69 - (0.495 \times 11.08) && (133") \\ &= 2.21 \text{ ton} \end{aligned}$$


$$\begin{aligned} \text{Moment} &= ((7.69 + 2.21) / 2) \times 11.08 \\ &= 54.83 \text{ ton.ft} \end{aligned}$$

Office	York Office	Page No.	62	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Load Effects	Checker		Date	Mar-25

Girders 27 and 29

$$DL\ UDL = 0.714\ \text{ton/ft}$$

$$MDL = 86.22\ \text{ton.ft}$$



$$VDL = 11.10\ \text{ton}$$

$$\begin{aligned} \text{Shear at } 5.00\ \text{ft} &= 11.10 - (0.714 \times 5.00) && (60") \\ &= 7.53\ \text{ton} \end{aligned}$$

$$\begin{aligned} \text{Moment} &= ((11.10 + 7.53) / 2) \times 5.00 \\ &= 46.56\ \text{ton.ft} \end{aligned}$$

$$\begin{aligned} \text{Shear at } 5.90\ \text{ft} &= 11.10 - (0.714 \times 5.90) && (70.75") \\ &= 6.89\ \text{ton} \end{aligned}$$

$$\begin{aligned} \text{Moment} &= ((11.10 + 6.89) / 2) \times 5.90 \\ &= 53.01\ \text{ton.ft} \end{aligned}$$

$$\begin{aligned} \text{Shear at } 7.02\ \text{ft} &= 11.10 - (0.714 \times 7.02) && (84.25") \\ &= 6.08\ \text{ton} \end{aligned}$$

$$\begin{aligned} \text{Moment} &= ((11.10 + 6.08) / 2) \times 7.02 \\ &= 60.31\ \text{ton.ft} \end{aligned}$$


$$\begin{aligned} \text{Shear at } 11.08\ \text{ft} &= 11.10 - (0.714 \times 11.08) && (133") \\ &= 3.18\ \text{ton} \end{aligned}$$

$$\begin{aligned} \text{Moment} &= ((11.10 + 3.18) / 2) \times 11.08 \\ &= 79.13\ \text{ton.ft} \end{aligned}$$

Girder 30

$$DL\ UDL = 0.646\ \text{ton/ft}$$

$$MDL = 78.08\ \text{ton.ft}$$



$$VDL = 10.05\ \text{ton}$$

$$\begin{aligned} \text{Shear at } 5.00\ \text{ft} &= 10.05 - (0.646 \times 5.00) && (60") \\ &= 6.82\ \text{ton} \end{aligned}$$

Office	York Office	Page No.	63	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Load Effects	Checker		Date	Mar-25

$$\begin{aligned} \text{Moment} &= ((10.05 + 6.82) / 2) \times 5.00 \\ &= \boxed{42.16} \text{ ton.ft} \end{aligned}$$

$$\begin{aligned} \text{Shear at } \boxed{5.90} \text{ ft} &= 10.05 - (0.646 \times 5.90) && (70.75") \\ &= \boxed{6.24} \text{ ton} \end{aligned}$$

$$\begin{aligned} \text{Moment} &= ((10.05 + 6.24) / 2) \times 5.90 \\ &= \boxed{48.00} \text{ ton.ft} \end{aligned}$$

$$\begin{aligned} \text{Shear at } \boxed{7.02} \text{ ft} &= 10.05 - (0.646 \times 7.02) && (84.25") \\ &= \boxed{5.51} \text{ ton} \end{aligned}$$

$$\begin{aligned} \text{Moment} &= ((10.05 + 5.51) / 2) \times 7.02 \\ &= \boxed{54.61} \text{ ton.ft} \end{aligned}$$


$$\begin{aligned} \text{Shear at } \boxed{11.08} \text{ ft} &= 10.05 - (0.646 \times 11.08) && (133") \\ &= \boxed{2.88} \text{ ton} \end{aligned}$$

$$\begin{aligned} \text{Moment} &= ((10.05 + 2.88) / 2) \times 11.08 \\ &= \boxed{71.65} \text{ ton.ft} \end{aligned}$$

Girder 28

$$\text{DL UDL} = \boxed{0.819} \text{ ton/ft}$$

$$\text{MDL} = \boxed{97.80} \text{ ton.ft}$$



$$\text{VDL} = \boxed{12.65} \text{ ton}$$

The girder will also be checked at the curtailment point which is $\boxed{6.333}$ ft from each end


$$\begin{aligned} M_x &= ((12.65 + 7.47) / 2) \times 6.333 \\ &= \boxed{63.72} \text{ ton.ft} \end{aligned}$$

Office	York Office	Page No.	64	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Load Effects	Checker		Date	Mar-25

Girder 32

$$DL\ UDL = 0.810\ \text{ton/ft}$$

$$MDL = 9.86\ \text{ton.ft}$$




$$VDL = 4.00\ \text{ton}$$

Girder 33

$$DL\ UDL = 1.039\ \text{ton/ft}$$


$$MDL = 36.23\ \text{ton.ft}$$



$$VDL = 8.68\ \text{ton}$$

Girder 34

The girder partially supports the pedestrian area to the south therefore assume the following:



$$\begin{aligned} \text{For east end UDL} &= 7.111\ \text{ft} \\ \text{For west end UDL} &= 16.417\ \text{ft} \end{aligned}$$

$$\begin{aligned} RW &= ((1.110 \times 7.111 \times 3.556) + (1.029 \times 16.417 \times 15.319)) / 23.528 \\ &= 12.19\ \text{ton} \end{aligned}$$

$$\begin{aligned} RE &= (1.110 \times 7.111) + (1.029 \times 16.417) - 12.19 \\ &= 12.59\ \text{ton} \end{aligned}$$

Maximum moment occurs 11.849 ft from the west end


$$\begin{aligned} M_{\max} &= 0.5 \times 12.19 \times 11.849 \\ &= 72.22\ \text{ton.ft} \end{aligned}$$

Office	York Office	Page No.	65	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Load Effects	Checker		Date	Mar-25

Girder 31

$$DL \text{ UDL} = 0.796 \text{ ton/ft}$$

$$MDL = 95.08 \text{ ton.ft}$$



$$VDL = 12.30 \text{ ton}$$

Consider the following arrangement for the imposed dead loads from girders 32, 33 and 34



Imposed loads due to girders

$$RW = \frac{(4.00 \times 14.591) + (8.68 \times 21.848) + (12.19 \times 29.105)}{30.917} = 19.49 \text{ ton}$$

$$RE = 4.00 + 8.68 + 12.19 - 19.49 = 5.37 \text{ ton}$$

Maximum moment occurs 21.848 ft from the east end

$$M_{max} = (5.37 \times 14.591) + (1.37 \times 7.257) = 88.33 \text{ ton.ft}$$

Combined imposed loads

$$RW = 31.80 \text{ ton}$$

$$RE = 17.67 \text{ ton}$$

Maximum moment occurs 17.184 ft from the east end

$$M_{max} = 175.82 \text{ ton.ft}$$

$$\text{Moment at midspan} = 174.64 \text{ ton.ft}$$

The girder will also be checked at the curtailment points of the additional plates
The additional plates are 18' - 8" and 12' - 0" long, the plates therefore curtail
6.125 ft and 9.458 ft from each support

$$\text{Shear at } 6.125 \text{ ft} = 31.80 - 12.19 - 4.87 = 14.73 \text{ ton (west end)}$$

Office	York Office	Page No.	66	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Dead Load Effects	Checker		Date	Mar-25


$$\begin{aligned} \text{Moment} &= (((31.80 + 30.35) / 2) \times 1.812) + (((18.16 + 14.73) / 2) \times 4.313) \\ &= \boxed{127.25} \text{ ton.ft} \end{aligned}$$

$$\begin{aligned} \text{Shear at } 9.458 \text{ ft} &= 17.67 - 7.53 \\ &= \boxed{10.15} \text{ ton} \quad (\text{east end}) \end{aligned}$$

$$\begin{aligned} \text{Moment} &= ((17.67 + 10.15) / 2) \times 9.458 \\ &= \boxed{131.55} \text{ ton.ft} \end{aligned}$$

Girder 35

The girder partially supports the pedestrian area to the south therefore assume the following:



$$\begin{aligned} \text{RW} &= ((0.723 \times 13.208 \times 6.604) + (0.672 \times 13.208 \times 19.813)) / 26.417 \\ &= \boxed{9.05} \text{ ton} \end{aligned}$$

$$\begin{aligned} \text{RE} &= (0.723 \times 13.208) + (0.672 \times 13.208) - 9.05 \\ &= \boxed{9.39} \text{ ton} \end{aligned}$$

Maximum moment occurs $\boxed{12.975} \text{ ft}$ from the east end

$$\begin{aligned} \text{Mmax} &= 0.5 \times 9.39 \times 12.975 \\ &= \boxed{60.89} \text{ ton.ft} \end{aligned}$$

Office	York Office	Page No.	67	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

Live Loads

4 axle vehicle $W = 24$ ton


Axle	0.33W	0.167W
Axle Load (ton)	8	4
Wheel Load (ton)	4	2
Factored Load (ton)	5	2.5

2 axle vehicle $W = 13$ ton

Axle	0.7W	0.3W
Axle Load (ton)	9	4
Wheel Load (ton)	4.5	2
Factored Load (ton)	5.625	2.5

Girder 19

Consider the following arrangement for imposing the worst case bending at midspan
The wheel load between girders 18 and 19 will be distributed by simple statics.



Impact will be applied on the wheel acting directly on girder 19

Girder 19 will carry 57% of the second wheel load

$$L = 26.083 \text{ ft}$$

$$\text{Moment due to dead loads at } 16.125 \text{ ft} = 55.16 \text{ ton.ft}$$

Maximum moment due to dead loads occurs 12.649 ft from the west end


$$RE = \frac{(5 \times 16.125) + (2.27 \times 19.875)}{26.083} = 4.82 \text{ ton}$$

$$RW = 2.45 \text{ ton}$$

$$M_{max} = 2.45 \times 16.125 = 39.49 \text{ ton.ft} \quad M@12.649 = 2.45 \times 12.649 = 30.98 \text{ ton.ft}$$

Office	York Office	Page No.	68	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

The following has been included as a check as the worst possible arrangement of a vehicle on the girder. With the bus stop at the east edge of the deck, there is a possibility of vehicles pulling around a stopped bus.



$$RE = \frac{((5 \times 16.125) + (4 \times 20.625))}{26.083}$$

$$= 6.25 \text{ ton}$$

$$RW = 5 + 4 - 6.25$$

$$= 2.75 \text{ ton}$$

$$M_{max} = 2.75 \times 16.125$$

$$= 44.28 \text{ ton.ft}$$


$$M@12.649 = 2.75 \times 12.649$$

$$= 34.74 \text{ ton.ft}$$

Office	York Office	Page No.	69	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

BE4 Cl. 201

A check will also be done using twin 9 ton axles at 4ft spacing



$$RE = \frac{((4.5 \times 1.25 \times 16.125) + (2.77 \times 18.888))}{26.083}$$

$$= 5.48 \text{ ton}$$

$$RW = 5.63 + 2.77 - 5.48$$

$$= 2.91 \text{ ton}$$

$$M_{max} = 2.91 \times 16.125$$

$$= 46.93 \text{ ton.ft}$$

$$M@12.649 = 2.91 \times 12.649$$

$$= 36.82 \text{ ton.ft}$$

Checking for a vehicle running parallel to the girder:

$$RE = \frac{(5.63 \times 16.125) + (4.5 \times 20.125)}{26.083}$$

$$= 6.95 \text{ ton}$$

$$RW = 5.63 + 4.5 - 6.95$$

$$= 3.18 \text{ ton}$$

$$M_{max} = 3.18 \times 16.125$$

$$= 51.21 \text{ ton.ft}$$

$$M@12.649 = 3.18 \times 12.649$$


$$= 40.17 \text{ ton.ft}$$

Office	York Office	Page No.	70	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

BE4 CI 201

Girder 20

It will be assumed that a wheel load can act directly on the midspan of the girder
Twin 9 ton axles at 4' spacing impose greater moment than vehicle train in Fig 1(b)



$$L = 26.417 \text{ ft}$$




$$RE = \frac{(2.02 \times 9.875) + (5.6 \times 13.208)}{26.417} = 3.57 \text{ ton}$$

$$RW = 2.02 + 5.6 - 3.57 = 4.07 \text{ ton}$$

Maximum moment occurs at midspan

$$M_{max} = (4.07 \times 9.875) + (2.06 \times 3.333) = 47.10 \text{ ton.ft}$$


Consider the following arrangement for imposing the worst case shear




$$RE = \frac{(2.02 \times 23.083) + (5.6 \times 26.417)}{26.417} = 7.39 \text{ ton}$$

Office	York Office	Page No.	71	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

As for girder 19 the following has been included as a check for the worst possible loading case for bending



$$L = 26.417 \text{ ft}$$



$$RE = \frac{((5.63 \times 13.208) + (4.5 \times 17.208))}{26.417}$$

$$= 5.74 \text{ ton}$$

$$RW = 5.63 + 4.5 - 5.74$$

$$= 4.38 \text{ ton}$$

Maximum moment occurs at midspan

$$M_{max} = (4.38 \times 13.208)$$


$$= 57.87 \text{ ton.ft}$$

Office	York Office	Page No.	72	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

Girder 21

BE4 CI 201

Consider the following arrangement for imposing the worst case bending moment.
A twin 9 ton axle at 4' spacing imposes greater moment than vehicle train in Fig 1(b)



$$L = 23.528 \text{ ft}$$



$$RE = \frac{(2.02 \times 8.431) + (5.0 \times 11.764)}{23.528}$$

$$= 3.22 \text{ ton}$$

$$RW = 2.02 + 5.0 - 3.22$$



$$= 3.79 \text{ ton}$$

Maximum moment occurs at midspan

$$M_{max} = 3.22 \times 11.764$$

$$= 37.91 \text{ ton.ft}$$

For the maximum imposed shear, consider the following arrangement




$$RE = \frac{(1.42 \times 15.819) + (5.63 \times 22.319)}{23.528}$$

$$= 6.29 \text{ ton}$$


Office	York Office	Page No.	73	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

Girder 22

Consider the following arrangement for maximum imposed bending moment



$$L = 17.528 \text{ ft}$$



$$RE = \frac{(2.02 \times 5.431) + (5.63 \times 8.764)}{17.528}$$

$$= 3.44 \text{ ton}$$

$$RW = 2.02 + 5.63 - 3.44$$


$$= 4.20 \text{ ton}$$

Maximum moment occurs at midspan

$$M_{max} = 3.44 \times 8.764$$

$$= 30.12 \text{ ton.ft}$$

Consider the following arrangement for maximum imposed shear




$$RE = \frac{(1.58 \times 9.819) + (5.63 \times 16.319)}{17.528}$$

$$= 6.12 \text{ ton}$$

Office	York Office	Page No.	74	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

Girder 23

Consider the following arrangement for maximum imposed bending moment



$$L = 11.611 \text{ ft}$$





$$RE = \frac{(2.02 \times 2.472) + (5.63 \times 5.806)}{11.611} = 3.24 \text{ ton}$$

$$RW = 2.02 + 5.63 - 3.24 = 4.40 \text{ ton}$$

Maximum moment occurs at midspan

$$M_{max} = 3.24 \times 5.806 = 18.82 \text{ ton.ft}$$

Consider the following arrangement for the maximum imposed shear




$$RE = \frac{(1.58 \times 3.903) + (5.63 \times 10.403)}{11.611} = 5.57 \text{ ton}$$

Office	York Office	Page No.	75	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

Girder 24

Consider the following arrangement for maximum imposed bending moment



$$L = 5.861 \text{ ft}$$




$$RE = RW = 5.63 / 2 = 2.81 \text{ ton}$$

Maximum moment occurs at midspan

$$M_{max} = 2.81 \times 2.931 = 8.24 \text{ ton.ft}$$

For maximum imposed shear




$$RE = (5.63 \times 4.653) / 5.861 = 4.47 \text{ ton}$$

Office	York Office	Page No.	76	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

Girder 25

Consider the following arrangement for maximum imposed bending



Girder 22 imposed load

$$RE = \frac{((4.00 \times 6.054) + (2.76 \times 9.506))}{17.528}$$


$$= 2.88 \text{ ton}$$

Girder 21 imposed load

$$RE = \frac{((2.24 \times 9.754) + (1.04 \times 16.014))}{23.528}$$

$$= 1.64 \text{ ton}$$

$$L = 30.917 \text{ ft}$$



$$RE = \frac{((2 \times 0.96) + (4 \times 10.96) + (5 \times 15.46) + (2.88 \times 17.26) + (2 \times 22.96) + (2 \times 27.46) + (1.64 \times 28.17))}{30.92}$$

$$= 10.338 \text{ ton}$$

$$RW = 9.17 \text{ ton}$$

Maximum moment occurs 15.458 ft from the west end (midspan)

$$M_{max} = (9.17 \times 0.958) + (7.17 \times 10.0) + (3.17 \times 4.5)$$


$$= 94.82 \text{ ton.ft}$$

Office	York Office	Page No.	77	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

The girder is also to be checked at the curtailment points of the additional plates

6.125 ft from east end

To impose the worst case loading, assume opposite direction of travel.



Girder 21 imposed load

$$RE = \frac{((1.33 \times 17.803) + (4.0 \times 14.049))}{23.528}$$

$$= \boxed{3.39} \text{ ton}$$

Girder 22 imposed load

$$RE = \frac{((2.00 \times 7.587) + (0.92 \times 3.830))}{17.528}$$

$$= \boxed{1.07} \text{ ton}$$


Girder 23 imposed loads

$$RE = \frac{(1.08 \times 3.970)}{11.611}$$

$$= \boxed{0.37} \text{ ton}$$

Office	York Office	Page No.	78	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

$$L = 30.917 \text{ ft}$$



$$RE = ((2 \times 8.29) + (2 \times 12.79) + (0.37 \times 13.65) + (4 \times 20.29) + (1.07 \times 20.91) + (5 \times 24.79) + (3.39 \times 28.17)) / 30.92$$

$$= 11.98 \text{ ton}$$

$$RW = 5.85 \text{ ton}$$


$$\text{Moment at } 6.125 \text{ ft} = (11.98 \times 2.750) + (8.58 \times 3.375)$$

$$= 61.89 \text{ ton.ft}$$

$$\text{Shear at } 6.125 \text{ ft} = 11.98 - 3.39$$

$$= 8.58 \text{ ton}$$

9.458 ft from the east end



As a conservative assessment it will be assumed that girder 21 will carry 100% of the wheel from axle 3 and girder 22 will carry 100% of the wheel from axle 2

Girder 21 imposed load


$$RE = (5.0 \times 14.761) / 23.528$$

$$= 3.14 \text{ ton}$$

Office	York Office	Page No.	79	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

Girder 22 imposed load
 $RE = ((2.0 \times 8.558) + (1.24 \times 4.804)) / 17.528$
 $= 1.32$ ton

Girder 23 imposed load
 $RE = (0.76 \times 4.944) / 11.611$
 $= 0.32$ ton




$RE = ((2.00 \times 9.522) + (0.32 \times 13.715) + (2.00 \times 14.022) + (1.32 \times 20.973) + (5.00 \times 21.458) + (4.00 \times 25.958) + (3.14 \times 28.167)) / 30.917$
 $= 12.25$ ton

$RW = 5.53$ ton

Moment at 9.458 ft = $(12.25 \times 2.750) + (9.11 \times 2.208) + (5.11 \times 4.500)$
 $= 76.79$ ton.ft

Shear at 9.458 ft = $12.25 - 3.14 - 4.00$
 $= 5.11$ ton


Consider the following arrangement for imposing the worst case shear



Office	York Office	Page No.	80	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

Girder 21 imposed load
 $RE = \frac{(2.0 \times 12.644) + (0.62 \times 8.886)}{23.528}$
 = 1.31 ton

Girder 22 imposed load
 $RE = \frac{(1.38 \times 8.944)}{17.528}$
 = 0.70 ton




Office	York Office	Page No.	81	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

Girders 26, 27, 29 and 30

These girders will be assumed to carry a single row of wheel as a conservative assessment with no distribution of the loads.

Girders 26, 27, 29 and 30 all have the same effective span.

Consider the following arrangement for imposing the worst case bending



$$RE = \frac{(2 \times 3.542) + (2 \times 8.042) + (5 \times 15.542) + (4 \times 20.042) + (2 \times 30.042)}{31.083}$$

$$= 7.76 \text{ ton}$$

$$RW = 2 + 2 + 5 + 4 + 2 - 7.76$$


$$= 7.24 \text{ ton}$$

$$M_{max} = (7.24 \times 3.542) + (5.24 \times 4.5) + (3.24 \times 7.5)$$

$$= 73.56 \text{ ton.ft}$$

The girders will also be checked at 5.00 ft, 5.896 ft, 7.021 ft and 11.083 ft from the supports

Consider the following arrangement for bending at 5.00 ft



$$RE = \frac{(2(9.583 + 14.083)) + (4 \times 21.583) + (5 \times 26.083)}{31.083}$$


$$= 8.50 \text{ ton}$$

$$\text{Moment at 5ft} = 8.50 \times 5$$

$$= 42.48 \text{ ton.ft}$$

Office	York Office	Page No.	82	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

Consider the following arrangement for bending at 5.896 ft




$$RE = \frac{(2(8.688 + 13.188) + (4 \times 20.688) + (5 \times 25.188))}{31.083}$$

$$= 8.12 \text{ ton}$$

$$\text{Moment} = 8.12 \times 6$$

$$= 47.88 \text{ ton.ft}$$

Consider the following arrangement for bending at 7.021 ft




$$RE = \frac{(2(7.563 + 12.063) + (4 \times 19.563) + (5 \times 24.063))}{31.083}$$

$$= 7.65 \text{ ton}$$

$$\text{Moment} = 7.65 \times 7$$

$$= 53.72 \text{ ton.ft}$$

Consider the following arrangement for bending at 11.083 ft



$$RE = \frac{(2(8.000 + 12.500) + (5 \times 20.000) + (4 \times 24.500))}{31.083}$$


$$= 7.69 \text{ ton}$$

$$\text{Moment} = (7.69 \times 6.583) + (3.69 \times 4.5)$$

$$= 67.22 \text{ ton.ft}$$

Office	York Office	Page No.	83	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

Consider the following arrangement for imposing the worst case shear
The east end will be checked as it is assumed this is the shallower end.




$$RE = \frac{(4(4.583 + 26.583) + 2(14.583 + 19.083) + (5 \times 31.083))}{31.083}$$

$$= 11.18 \text{ ton}$$

Girder 28

Girder 28 will also be assumed to carry a single line of wheel loads.
Consider the following arrangement for the worst case bending.



$$RE = \frac{((2 \times 3.458) + (2 \times 7.958) + (5 \times 12.458) + (4 \times 16.958) + (2 \times 21.458))}{30.917}$$

$$= 7.76 \text{ ton}$$

$$RW = 2 + 2 + 5 + 4 + 2 - 7.76$$

$$= 7.24 \text{ ton}$$


$$M_{max} = (7.24 \times 3.458) + (5.24 \times 4.5) + (3.24 \times 7.5)$$

$$= 72.94 \text{ ton.ft}$$

Girder 28 is to be checked at the curtailment point 6.333 ft from the supports

Office	York Office	Page No.	84	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

Consider the following arrangement for imposing the worst case bending.




$$RE = \frac{(2(8.083 + 12.583) + (4 \times 20.083) + (5 \times 24.583))}{30.917}$$

$$= 7.91 \text{ ton}$$

$$\text{Moment} = 7.91 \times 6$$

$$= 50.10 \text{ ton.ft}$$

Consider the following arrangement for imposing the worst case shear




$$RE = \frac{(4(4.417 + 26.417) + 2(14.417 + 18.917) + (5 \times 30.917))}{30.917}$$

$$= 11.15 \text{ ton}$$

Office	York Office	Page No.	85	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

Girder 31

Girder 31 will be checked at the same locations as girder 25. The vehicle train will be assumed to run parallel to girder 31 for the worst case loading. Consider the following arrangement for imposing the worst case bending at midspan



Girder 32 imposed load

$$RW = (2.80 \times 3.667) / 9.868$$

$$= 1.04 \text{ ton}$$

Girder 33 imposed load

$$RW = ((2.80 \times 18.658) + (3.40 \times 22.417)) / 30.917$$


$$= 4.16 \text{ ton}$$

Girder 34 imposed load

$$RW = ((1.30 \times 15.230) + (1.60 \times 8.970)) / 23.528$$

$$= 1.45 \text{ ton}$$

$$L = 30.917 \text{ ft}$$



$$RE = 9.61 \text{ ton}$$

$$RW = 12.03 \text{ ton}$$

Office	York Office	Page No.	86	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25


Maximum moment occurs 15.458 ft from the west end (midspan)

Mmax = 100.67 ton.ft

The girder is also to be checked at the curtailment points of the additional plates

6.125 ft from west end

To impose worst case loading assume opposite direction of travel.



Girder 32 imposed load

$$RW = (1.34 \times 1.443) / 9.868$$

$$= \text{0.20 ton}$$

Girder 33 imposed load

$$RW = ((0.66 \times 2.218) + (2.00 \times 5.976)) / 16.701$$


$$= \text{0.80 ton}$$

Girder 34 imposed load

$$RW = ((4.00 \times 13.003) + (1.98 \times 16.759)) / 23.528$$

$$= \text{3.62 ton}$$

Office	York Office	Page No.	87	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25




RE = 5.55 ton

RW = 12.07 ton

Moment at 6.125 ft = 58.30 ton.ft

Shear at 6.125 ft = 8.45 ton

9.458 ft from the east end



Girder 32 imposed load

RW = $(1.02 \times 2.417) / 9.868$
 = 0.25 ton


Girder 33 imposed load

RW = $((2.00 \times 6.947) + (0.98 \times 3.194)) / 16.701$
 = 1.02 ton

Girder 34 imposed load

RW = $(5.00 \times 13.977) / 23.528$
 = 2.97 ton

Office	York Office	Page No.	88	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25




RE = 5.21 ton

RW = 12.03 ton

Moment at 9.458 ft = 71.03 ton.ft

Shear at 9.458 ft = 4.04 ton

Consider the following arrangement for imposing worst case shear at the west support




Girder 33 imposed load

RW = $(2 \times 7.335) / 16.701$
= 0.88 ton

Girder 34 imposed load

RW = $(2 \times 11.861) / 23.528$
= 1.01 ton




RW = 12.14 ton

Office	York Office	Page No.	89	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

Girders 32 to 35 will be checked the same way as 20 to 24 with the twin 9 ton axle which will impose greater loading on the girders than the 24ton vehicle train.

Girder 32

Consider the following arrangement for imposing the maximum bending




$$L = 9.868 \text{ ft}$$

$$RE = \frac{((5.63 \times 4.934) + (2.28 \times 1.453))}{9.868}$$

$$= 3.15 \text{ ton}$$

$$M_{max} = 15.537 \text{ ton.ft}$$

Consider the following arrangement for imposing the maximum shear




$$RE = \frac{((5.63 \times 9.8681) + (2.28 \times 6.387))}{9.868}$$

$$= 7.10$$

Office	York Office	Page No.	90	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

Girder 33

Consider the following arrangement for imposing the maximum bending.




$$L = 16.701 \text{ ft}$$

$$RE = \frac{((5.63 \times 8.351) + (2.28 \times 4.870))}{16.701}$$

$$= 3.48 \text{ ton}$$

$$M_{max} = 29.05 \text{ ton.ft}$$

Consider the following arrangement for imposing the maximum shear




$$RE = \frac{((1.08 \times 7.598) + (2.28 \times 10.427) + (5.63 \times 13.911))}{16.701}$$

$$= 6.60 \text{ ton}$$

Office	York Office	Page No.	91	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Live Loads	Checker		Date	Mar-25

Girder 34




$$L = 23.528 \text{ ft}$$

$$RE = \frac{((5.63 \times 11.764) + (2.28 \times 8.283))}{23.528}$$

$$= 3.62 \text{ ton}$$

$$M_{max} = 42.55 \text{ ton.ft}$$

Consider the following arrangement for imposing the maximum shear



$$RW = \frac{((5.63 \times 22.317) + (1.643 \times 18.836))}{23.528}$$

$$= 6.65 \text{ ton}$$

Girder 35 is the same arrangement as Girder 20 which will have greater imposed loads

Office	York Office	Page No.	92	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Girder Capacities	Checker		Date	Mar-25

Girder Capacities

The permissible stress in cast iron must not exceed 3 ton/sq.in in tension

The actual permissible tensile stress shall be based upon the ratio of dead to live load, and calculated from the equation: $5f_L + 2.2f_D = 8$ but shall in no case exceed 3 ton/sq.in

Where: f_L is the tensile bending stress due to live loads
 f_D is the tensile bending stress due to dead loads

Girder 8

Girder 8 is being checked for dead loads only as the worst case imposed dead loads on the cast iron girders.

Imposed dead loads = 154.33 ton.ft

Zxt = 503.98 cu.in

Stress due to dead loads = 3.67 ton/sq.in

Girder does not have sufficient capacity for imposed dead loads.

Girder 19

Girder 19 will be checked at the locations of maximum moment due to dead loads and maximum moment due to live loads.

The following is a summary of the imposed live loads checked:

4 axle vehicle parallel to girder

Mmax due to live loads = 44.28 ton.ft

Mmax @ 12.649ft = 34.74 ton.ft

4 axle vehicle parallel to kerb

Mmax due to live loads = 39.49 ton.ft

Mmax @ 12.649ft = 30.98 ton.ft

Twin 9 ton axles parallel to girder

Mmax due to live loads = 51.21 ton.ft

Mmax @ 12.649ft = 40.17 ton.ft

Twin 9 ton axle parallel to kerb

Mmax due to live loads = 46.93 ton.ft

Mmax @ 12.649ft = 36.82 ton.ft

Office	York Office	Page No.	93	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Girder Capacities	Checker		Date	Mar-25

The twin 9 ton axle arrangement is the more critical for all cases and will be used to check the capacity of the girder.

$$\begin{aligned} \text{Maximum moment due to dead loads} &= 57.34 \text{ ton.ft} \\ \text{Moment due to live loads} &= 40.17 \text{ ton.ft} \end{aligned}$$

$$Z_{xt} = 503.98 \text{ cu.in}$$

$$\begin{aligned} f_L &= 0.96 \text{ ton/sq.in} && \text{(for a vehicle parallel to the girder)} \\ f_D &= 1.37 \text{ ton/sq.in} \end{aligned}$$

$$\begin{aligned} 5f_L &= 4.78 \\ 2.2f_D &= 3.00 \end{aligned}$$

$$5f_L + 2.2f_D = 7.79 \text{ ton/sq.in} < 8 \text{ therefore OK}$$

$$\text{Total imposed stress} = 2.32 \text{ ton/sq.in} < 3 \text{ therefore OK}$$

Girder 19 is suitable for the imposed loads at the point of maximum bending due to dead loads considering worst case live loads.

$$\begin{aligned} \text{Moment due to dead loads} &= 55.16 \text{ ton.ft} \\ \text{Maximum moment due to live loads} &= 51.21 \text{ ton.ft} \end{aligned}$$

$$Z_{xt} = 503.98 \text{ cu.in}$$

$$\begin{aligned} f_L &= 1.22 \text{ ton/sq.in} && \text{(for a vehicle parallel to the girder)} \\ f_D &= 1.31 \text{ ton/sq.in} \end{aligned}$$

$$\begin{aligned} 5f_L &= 6.10 \\ 2.2f_D &= 2.89 \end{aligned}$$

$$5f_L + 2.2f_D = 8.99 \text{ ton/sq.in} > 8 \text{ not OK}$$

$$\text{Total imposed stress} = 2.53 \text{ ton/sq.in} < 3 \text{ therefore OK}$$

Girder 19 is not suitable for the imposed loads at the point of maximum bending due to live loads. This has been based upon assuming a vehicle could traverse the deck and line up the wheels parallel to the girder axis and directly above.

Office	York Office	Page No.	94	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Girder Capacities	Checker		Date	Mar-25

Checking the girder for a vehicle traversing the deck remaining parallel to the kerb

$$\text{Moment due to dead loads} = 55.16 \text{ ton.ft}$$

$$\text{Maximum moment due to live loads} = 46.93 \text{ ton.ft}$$

$$Z_{xt} = 503.98 \text{ cu.in}$$

$$f_L = 1.12 \text{ ton/sq.in}$$

$$f_D = 1.31 \text{ ton/sq.in}$$

$$5f_L = 5.59$$

$$2.2f_D = 2.89$$

$$5f_L + 2.2f_D = 8.48 \text{ ton/sq.in} > 8 \text{ not OK}$$

$$\text{Total imposed stress} = 2.43 \text{ ton/sq.in} < 3 \text{ therefore OK}$$

The girder is not suitable for the imposed live loads

Office	York Office	Page No.	95	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Girder Capacities	Checker		Date	Mar-25

Steel Girders

Bending Moment Capacity

The deck construction offers restraint to the top flanges of the girders against lateral torsional buckling, therefore capacity (μ) can be derived from the section modulus of the bottom flange.

$$\mu = P_{bt} \cdot Z_{xt}$$

Where:

Z_{xt} = Elastic section modulus (tension flange)

P_{bt} = Permissible stress in bending

The steel section of the structure was constructed in the early 1900s and therefore it will be assumed as Steel to B.S. 15 or B.S. 2762 for the purpose of determining the basic permissible stress.

The yield stress shall be taken as 15 ton/sq.in for all cases

The stresses for mild steel shall be as in BS 153, Part 3B, Table 1 Case II
Therefore the stresses shall be increased by 25%

d_1 = the clear distance between the flange angles

t = the thickness of the web

d_1/t will be less than 85 for all girders

Therefore basic permissible stress = 9.5 ton/sq.in

Permissible stress in bending = 11.875 ton/sq.in

Girders 20, 21, 34 and 35 at Midspan

$$Z_{xt} = \text{305.72 in}^3$$

$$\mu = \text{3630.4 ton.in}$$

$$= \text{302.54 ton.ft}$$

Girders 22 and 33 at Midspan

$$Z_{xt} = \text{171.87 in}^3$$

$$\mu = \text{2041 ton.in}$$

$$= \text{170.08 ton.ft}$$

BS153: Part 3B
Table 3

BE4 Part I
Cl. 304 (a)

Office	York Office	Page No.	96	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Girder Capacities	Checker		Date	Mar-25

Girders 23 and 32 at Midspan

$$Z_{xt} = 92.20 \text{ in}^3$$

$$\begin{aligned} \mu &= 1094.8 \text{ ton.in} \\ &= 91.24 \text{ ton.ft} \end{aligned}$$

Girder 24

$$Z_{xt} = 59.12 \text{ in}^3$$

$$\begin{aligned} \mu &= 702.08 \text{ ton.in} \\ &= 58.51 \text{ ton.ft} \end{aligned}$$

Girder 25 and 31

At Midspan

$$Z_{xt} = 710.66 \text{ in}^3$$

$$\begin{aligned} \mu &= 8439.1 \text{ ton.in} \\ &= 703.26 \text{ ton.ft} \end{aligned}$$

At first curtailment point

$$Z_{xt} = 545.30 \text{ in}^3$$

$$\begin{aligned} \mu &= 6475.5 \text{ ton.in} \\ &= 539.62 \text{ ton.ft} \end{aligned}$$

At second curtailment point

$$Z_{xt} = 381.62 \text{ in}^3$$

$$\begin{aligned} \mu &= 4531.7 \text{ ton.in} \\ &= 377.64 \text{ ton.ft} \end{aligned}$$

Girder 28

At Midspan

$$Z_{xt} = 522.86 \text{ in}^3$$

$$\begin{aligned} \mu &= 6208.9 \text{ ton.in} \\ &= 517.41 \text{ ton.ft} \end{aligned}$$

Office	York Office	Page No.	97	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Girder Capacities	Checker		Date	Mar-25

At Curtailment Point

$$Z_{xt} = 377.12 \text{ in}^3$$

$$\begin{aligned} \mu &= 4478.3 \text{ ton.in} \\ &= 373.19 \text{ ton.ft} \end{aligned}$$

Girders 26, 27, 29 and 30

At west cutout and curtailment point

$$Z_{xt} = 458.00 \text{ in}^3$$

$$\begin{aligned} \mu &= 5438.8 \text{ ton.in} \\ &= 453.23 \text{ ton.ft} \end{aligned}$$

At midspan

$$Z_{xt} = 609.25 \text{ in}^3$$

$$\begin{aligned} \mu &= 7234.8 \text{ ton.in} \\ &= 602.90 \text{ ton.ft} \end{aligned}$$

At east cutout

$$Z_{xt} = 407.32 \text{ in}^3$$

$$\begin{aligned} \mu &= 4836.9 \text{ ton.in} \\ &= 403.08 \text{ ton.ft} \end{aligned}$$

At east curtailment point

$$Z_{xt} = 230.80 \text{ in}^3$$

$$\begin{aligned} \mu &= 2740.7 \text{ ton.in} \\ &= 228.39 \text{ ton.ft} \end{aligned}$$

Office	York Office	Page No.	98	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Girder Capacities	Checker		Date	Mar-25

Shear Capacity

BS153 Part 4
Cl. 20 d (ii)

The effective sectional area for parts in shear is the product of the thickness of the web and the full depth of the web plate.

BS153 Part 3B
Cl. 29 a

The calculated average shear stress, f_q , on the effective sectional area of the web shall not exceed the value given in Table 3 or the value of P_q given by the following equation:

$$p_q = 6 \left[1.3 - \frac{b/t}{250 \left\{ 1 + \frac{1}{2} \left(\frac{b}{a} \right)^2 \right\}} \right]$$

Where:

- a = the greater clear dimension of the web in a panel, not greater than 270t
- b = the lesser clear dimension of the web in a panel, not greater than 180t

BS.153 Part 3B
Table 3

Using a yield stress of 15 ton/sq.in for mild steel, the average shear stress shall not exceed 5.50 ton/sq.in (steel to BS 15 / BS 2762)

BE4 Part I
Cl. 304(a)

The stresses for mild steel shall be as in BS153, Part 3B Case II
Therefore the allowable stresses shall be increased by 25% = 6.875 ton/sq.in

Girders 20 and 35

Taking dimensions from the historical drawings

$$t = \text{span style="border: 1px solid black; padding: 2px;">0.63 in$$

$$\begin{aligned} \text{end panel width} &= \text{span style="border: 1px solid black; padding: 2px;">22.5 in && (25.5 - 3) \\ \text{height} &= \text{span style="border: 1px solid black; padding: 2px;">4.0 in && (12 - 8) \end{aligned}$$

$$\begin{aligned} 270t &= \text{span style="border: 1px solid black; padding: 2px;">168.75 in \\ \text{Therefore a} &= \text{span style="border: 1px solid black; padding: 2px;">22.5 in \end{aligned}$$

$$\begin{aligned} 180t &= \text{span style="border: 1px solid black; padding: 2px;">112.5 in \\ \text{Therefore b} &= \text{span style="border: 1px solid black; padding: 2px;">4.0 in \end{aligned}$$

$$p_q = \text{span style="border: 1px solid black; padding: 2px;">7.65 tons/sq.in$$

$$\text{Therefore the stresses in the web shall not exceed } p_{bc} = \text{span style="border: 1px solid black; padding: 2px;">6.88 ton/sq.in$$

$$\begin{aligned} \text{Shear capacity} &= 6.88 \times 0.63 \times 12.00 \\ &= \text{span style="border: 1px solid black; padding: 2px;">51.563 ton \end{aligned}$$

Office	York Office	Page No.	99	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Girder Capacities	Checker		Date	Mar-25

Girders 21 and 34

$$t = 0.63 \text{ in}$$

$$\begin{aligned} \text{end panel width} &= 24.0 \text{ in} && (31 - 7) \\ \text{height} &= 3.5 \text{ in} && (11.5 - 8) \end{aligned}$$

$$\begin{aligned} 270t &= 168.75 \text{ in} \\ \text{Therefore a} &= 24.0 \text{ in} \end{aligned}$$

$$\begin{aligned} 180t &= 112.5 \text{ in} \\ \text{Therefore b} &= 3.5 \text{ in} \end{aligned}$$

$$p_q = 7.67 \text{ tons/sq.in}$$

$$\text{Therefore the stresses in the web shall not exceed } p_{bc} = 6.88 \text{ ton/sq.in}$$

$$\begin{aligned} \text{Shear capacity} &= 6.88 \times 0.63 \times 11.50 \\ &= 49.41 \text{ ton} \end{aligned}$$

Girder 22 and 33

$$t = 0.63 \text{ in}$$

$$\begin{aligned} \text{end panel width} &= 25.0 \text{ in} && (31 - 6) \\ \text{height} &= 4.0 \text{ in} && (12 - 8) \end{aligned}$$

$$\begin{aligned} 270t &= 168.75 \text{ in} \\ \text{Therefore a} &= 25.0 \text{ in} \end{aligned}$$

$$\begin{aligned} 180t &= 112.5 \text{ in} \\ \text{Therefore b} &= 4.0 \text{ in} \end{aligned}$$

$$p_q = 7.65 \text{ tons/sq.in}$$

$$\text{Therefore the stresses in the web shall not exceed } p_{bc} = 6.88 \text{ ton/sq.in}$$

$$\begin{aligned} \text{Shear capacity} &= 6.88 \times 0.63 \times 12.00 \\ &= 51.56 \text{ ton} \end{aligned}$$

Office	York Office	Page No.	100	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Girder Capacities	Checker		Date	Mar-25

Girder 23 and 32

$$t = 0.50 \text{ in}$$

$$\begin{aligned} \text{end panel width} &= 16.0 \text{ in} && (22 - 6) \\ \text{height} &= 6.0 \text{ in} && (12 - 6) \end{aligned}$$

$$\begin{aligned} 270t &= 135 \text{ in} \\ \text{Therefore a} &= 16.0 \text{ in} \end{aligned}$$

$$\begin{aligned} 180t &= 90 \text{ in} \\ \text{Therefore b} &= 6.0 \text{ in} \end{aligned}$$

$$pq = 7.53 \text{ tons/sq.in}$$

$$\text{Therefore the stresses in the web shall not exceed } pbc = 6.88 \text{ ton/sq.in}$$

$$\begin{aligned} \text{Shear capacity} &= 6.88 \times 0.50 \times 12.00 \\ &= 41.3 \text{ ton} \end{aligned}$$

Girder 24

$$t = 0.50 \text{ in}$$

$$\begin{aligned} \text{end panel width} &= 17.0 \text{ in} && (22 - 5) \\ \text{height} &= 4.0 \text{ in} && (9 - 5) \end{aligned}$$

$$\begin{aligned} 270t &= 135 \text{ in} \\ \text{Therefore a} &= 17.0 \text{ in} \end{aligned}$$

$$\begin{aligned} 180t &= 90 \text{ in} \\ \text{Therefore b} &= 4.0 \text{ in} \end{aligned}$$

$$pq = 7.61 \text{ tons/sq.in}$$

$$\text{Therefore the stresses in the web shall not exceed } pbc = 6.88 \text{ ton/sq.in}$$

$$\begin{aligned} \text{Shear capacity} &= 6.88 \times 0.50 \times 9.00 \\ &= 30.9 \text{ ton} \end{aligned}$$

Girders 25 and 31

The maximum clear dimension is not known so it will be assumed that the stresses in the web will not exceed $pbc = 6.88 \text{ ton/sq.in}$

$$\begin{aligned} \text{Shear capacity} &= 6.88 \times 0.63 \times 24.00 \\ &= 103.1 \text{ ton} \end{aligned}$$

Office	York Office	Page No.	101	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Girder Capacities	Checker		Date	Mar-25

Girders 26, 27, 29 and 30

The girders are deeper at one end and the stiffener spacings also differ.

Deeper end

$$t = 0.63 \text{ in} \quad dw = 30.875 \text{ in}$$

$$\begin{aligned} \text{end panel width} &= 15.0 \text{ in} \\ \text{height} &= 22.9 \text{ in} \end{aligned}$$

$$\begin{aligned} 270t &= 168.75 \text{ in} \\ \text{Therefore a} &= 22.9 \text{ in} \end{aligned}$$

$$\begin{aligned} 180t &= 112.5 \text{ in} \\ \text{Therefore b} &= 15.0 \text{ in} \end{aligned}$$

$$pq = 7.33 \text{ tons/sq.in}$$

$$\text{Therefore the stresses in the web shall not exceed } pbc = 6.88 \text{ ton/sq.in}$$

$$\begin{aligned} \text{Shear capacity} &= 6.88 \times 0.63 \times 30.88 \\ &= 132.7 \text{ ton} \end{aligned}$$

Shallower end

$$t = 0.63 \text{ in} \quad dw = 24.875 \text{ in}$$

$$\begin{aligned} \text{end panel width} &= 22.0 \text{ in} \\ \text{height} &= 16.9 \text{ in} \end{aligned}$$

$$\begin{aligned} 270t &= 168.75 \text{ in} \\ \text{Therefore a} &= 22.0 \text{ in} \end{aligned}$$

$$\begin{aligned} 180t &= 112.5 \text{ in} \\ \text{Therefore b} &= 16.9 \text{ in} \end{aligned}$$

$$pq = 7.30 \text{ tons/sq.in}$$

$$\text{Therefore the stresses in the web shall not exceed } pbc = 6.88 \text{ ton/sq.in}$$

$$\begin{aligned} \text{Shear capacity} &= 6.88 \times 0.63 \times 24.88 \\ &= 106.9 \text{ ton} \end{aligned}$$

Office	York Office	Page No.	102	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Girder Capacities	Checker		Date	Mar-25

Girder 28

$$t = 0.63 \text{ in} \quad dw = 25 \text{ in}$$

$$\begin{array}{l} \text{end panel width} = 4.0 \text{ in} \\ \text{height} = 17.0 \text{ in} \end{array}$$

$$\begin{array}{l} 270t = 168.75 \text{ in} \\ \text{Therefore a} = 17.0 \text{ in} \end{array}$$

$$\begin{array}{l} 180t = 112.5 \text{ in} \\ \text{Therefore b} = 4.0 \text{ in} \end{array}$$

$$pq = 7.65 \text{ tons/sq.in}$$

$$\text{Therefore the stresses in the web shall not exceed pbc} = 6.88 \text{ ton/sq.in}$$

$$\begin{array}{l} \text{Shear capacity} = 6.88 \times 0.63 \times 25.00 \\ = 107.4 \text{ ton} \end{array}$$

Office	York Office	Page No.	103	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Girder Capacities	Checker		Date	Mar-25

Capacity Summary

Girder 20

Bending capacity = 302.54 ton.ft

Maximum imposed bending due to dead loads = 45.56 ton.ft
 Imposed bending due to dead loads at midspan = 45.40 ton.ft

Maximum imposed bending due to live loads = 47.10 ton.ft
 Imposed bending due to LL, vehicle parallel to girder = 57.87 ton.ft

Bending capacity is sufficient for 24 ton loading

Shear capacity = 51.56 ton

Shear due to dead loads at east support = 6.48 ton
 Shear due to live loads at east support = 7.39 ton

Shear capacity is sufficient for 24 ton loading

Girder 21

Bending capacity = 302.54 ton.ft

Maximum imposed bending due to dead loads = 60.02 ton.ft
 Maximum imposed bending due to live loads = 37.91 ton.ft

Bending capacity is sufficient for 24 ton loading

Shear capacity = 49.41 ton

Shear due to dead loads at east support = 10.16 ton
 Shear due to live loads at east support = 6.29 ton

Shear capacity is sufficient for 24 ton loading

Office	York Office	Page No.	104	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Girder Capacities	Checker		Date	Mar-25

Girder 22

Bending capacity = 170.08 ton.ft

Maximum imposed bending due to dead loads = 32.17 ton.ft

Maximum imposed bending due to live loads = 30.12 ton.ft

Bending capacity is sufficient for 24 ton loading

Shear capacity = 51.56 ton

Shear due to dead loads at east support = 7.34 ton

Shear due to live loads at east support = 6.12 ton

Shear capacity is sufficient for 24 ton loading

Girder 23

Bending capacity = 91.24 ton.ft

Maximum imposed bending due to dead loads = 13.39 ton.ft

Maximum imposed bending due to live loads = 18.82 ton.ft

Bending capacity is sufficient for 24 ton loading

Shear capacity = 41.25 ton

Shear due to dead loads at east support = 4.61 ton

Shear due to live loads at east support = 5.57 ton

Shear capacity is sufficient for 24 ton loading

Girder 24

Bending capacity = 58.51 ton.ft

Maximum imposed bending due to dead loads = 2.61 ton.ft

Maximum imposed bending due to live loads = 8.24 ton.ft

Bending capacity is sufficient for 24 ton loading

Shear capacity = 30.94 ton

Shear due to dead loads at east support = 1.78 ton

Shear due to live loads at east support = 4.47 ton

Shear capacity is sufficient for 24 ton loading

Office	York Office	Page No.	105	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Girder Capacities	Checker		Date	Mar-25

Girder 25

Bending capacity at midspan = 703.26 ton.ft

Maximum moment due to dead loads = 148.31 ton.ft (at 13.713ft from E)

Moment at midspan due to dead loads = 147.44 ton.ft

Moment at midspan due to live loads = 94.82 ton.ft

Girder has sufficient capacity at midspan for 24 ton loading

Bending capacity with 1 curtailment plate = 539.62 ton.ft

Moment due to dead loads at first curtailment point = 139.76 ton.ft

Moment due to live loads at first curtailment point = 76.79 ton.ft

Girder has sufficient capacity at curtailment point for 24 ton loading

Bending capacity with no curtailment plate = 377.64 ton.ft

Moment due to dead loads at second curtailment point = 105.45 ton.ft

Moment due to live loads at second curtailment point = 61.89 ton.ft

Girder has sufficient capacity at curtailment point for 24 ton loading

Shear Capacity = 103.1 ton

Shear due to dead loads at east support = 24.34 ton

Shear due to live loads at east support = 12.24 ton

Shear capacity is sufficient for 24 ton loading

Office	York Office	Page No.	106	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Girder Capacities	Checker		Date	Mar-25

Girders 26, 27, 29 and 30

The dead loads for girders 27 and 29 will be used as they are the most onerous

Bending capacity at west cutout and curtailment point = 453.23 ton.ft

Bending due to dead loads = 53.01 ton.ft

Bending due to live loads = 47.88 ton.ft

Girder has sufficient bending capacity at the west cutout/curtailment point

Bending capacity at midspan = 602.90 ton.ft

Bending due to dead loads = 86.22 ton.ft

Bending due to live loads = 73.56 ton.ft

Girder has sufficient bending capacity at midspan

Bending capacity at east cutout = 403.08 ton.ft

Bending due to dead loads = 79.13 ton.ft

Bending due to live loads = 67.22 ton.ft

Girder has sufficient bending capacity at east cutout

Bending capacity at east curtailment point = 228.39 ton.ft

Bending due to dead loads = 60.31 ton.ft

Bending due to live loads = 53.72 ton.ft

Girder has sufficient bending capacity at east curtailment point

Shear capacity at east support = 106.9 ton

Shear due to dead loads at east support = 11.10 ton

Shear due to live loads at east support = 11.18 ton

Shear capacity is sufficient for 24 ton loading

Office	York Office	Page No.	107	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Girder Capacities	Checker		Date	Mar-25

Girder 28

Bending capacity at midspan = 517.41 ton.ft

Bending due to dead loads = 97.80 ton.ft

Bending due to live loads = 72.94 ton.ft

Girder has sufficient bending capacity at midspan

Bending capacity at curtailment point = 373.19 ton.ft

Bending due to dead loads = 63.72 ton.ft

Bending due to live loads = 50.10 ton.ft

Girder has sufficient bending capacity at curtailment point

Shear capacity at support = 107.4 ton

Shear due to dead loads = 12.65 ton

Shear due to live loads at east support = 11.15 ton

Shear capacity is sufficient for 24 ton loading

Girder 31

Bending capacity at midspan = 703.26 ton.ft

Maximum moment due to dead loads = 175.82 ton.ft (at 17.184ft from E)

Moment at midspan due to dead loads = 174.64 ton.ft

Moment at midspan due to live loads = 100.67 ton.ft

Girder has sufficient capacity at midspan for 24 ton loading

Bending capacity with 1 curtailment plate = 539.62 ton.ft

Moment due to dead loads at first curtailment point = 131.55 ton.ft

Moment due to live loads at first curtailment point = 71.03 ton.ft

Girder has sufficient capacity at curtailment point for 24 ton loading

Bending capacity with no curtailment plate = 377.64 ton.ft

Moment due to dead loads at second curtailment point = 127.25 ton.ft

Moment due to live loads at second curtailment point = 58.30 ton.ft

Girder has sufficient capacity at curtailment point for 24 ton loading

Office	York Office	Page No.	109	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Girder Capacities	Checker		Date	Mar-25

Shear Capacity = 103.1 ton

Shear due to dead loads at west support = 31.80 ton

Shear due to live loads at west support = 12.14 ton

Shear capacity is sufficient for 24 ton loading

Girder 32

Bending capacity = 91.24 ton.ft

Maximum imposed bending due to dead loads = 9.86 ton.ft

Maximum imposed bending due to live loads = 15.54 ton.ft

Bending capacity is sufficient for 24 ton loading

Shear capacity = 41.25 ton

Shear due to dead loads = 4.00 ton

Shear due to live loads at east support = 7.10 ton

Shear capacity is sufficient for 24 ton loading

Girder 33

Bending capacity = 170.08 ton.ft

Maximum imposed bending due to dead loads = 36.23 ton.ft

Maximum imposed bending due to live loads = 29.05 ton.ft

Bending capacity is sufficient for 24 ton loading

Shear capacity = 51.56 ton

Shear due to dead loads = 8.68 ton

Shear due to live loads at east support = 6.60 ton

Shear capacity is sufficient for 24 ton loading

Office	York Office	Page No.	109	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Girder Capacities	Checker		Date	Mar-25

Girder 34

Bending capacity = 302.54 ton.ft

Maximum imposed bending due to dead loads = 72.22 ton.ft

Maximum imposed bending due to live loads = 42.55 ton.ft

Bending capacity is sufficient for 24 ton loading

Shear capacity = 49.41 ton

Shear due to dead loads at west support = 12.19 ton

Shear due to live loads at west support = 6.65 ton

Shear capacity is sufficient for 24 ton loading

Office	York Office	Page No.	110	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Girder Capacities	Checker		Date	Mar-25

Results Summary Table

Support & midspan
 Support & Mmax
 Curtailment point
 Curtailment point
 Support & midspan
 Cut out
 Cut out
 Curtailment point
 Curtailment point
 Support & midspan
 Cut out
 Curtailment point
 Curtailment point
 Cut out
 Support & midspan
 Cut out
 Curtailment point
 Curtailment point
 Cut out
 Support & midspan
 Curtailment point
 Support & midspan
 Curtailment point
 Curtailment point
 Support & midspan
 Support & midspan
 Support & midspan
 Support & midspan

Girder	Dead Loads		Live Loads		Total		Capacity	
	Bending	Shear	Bending	Shear	Bending	Shear	Bending	Shear
20	45.56	6.48	57.87	7.39	103.43	13.87	302.54	51.563
21	60.02	10.16	37.91	6.29	97.92	16.45	302.54	49.41
22	32.17	7.34	30.12	6.12	62.29	13.47	170.08	51.56
23	13.39	4.61	18.82	5.57	32.21	10.19	91.24	41.3
24	2.61	1.78	8.24	4.47	10.85	6.25	58.51	30.9
25	148.31	16.63	94.82	12.24	243.13	28.88	703.26	103.1
25	139.76	9.46	76.79	5.11	216.55	14.57	539.62	103.1
25	105.45	11.13	61.89	8.58	167.35	19.71	377.64	103.1
26	59.75	7.69	73.56	11.18	133.31	18.87	602.90	106.9
26	54.83	2.21	67.22	3.69	122.05	5.89	403.08	*
26	32.26	5.21	42.48	8.50	74.74	13.71	453.23	*
26	41.79	4.22	53.72	7.65	95.50	11.87	228.39	*
26	36.73	4.77	47.88	8.12	84.61	12.89	453.23	*
27 & 29	86.22	11.10	73.56	11.18	159.79	22.27	602.90	106.9
27 & 29	79.13	3.18	67.22	3.69	146.35	6.87	403.08	*
27 & 29	60.31	6.08	53.72	7.65	114.02	13.73	228.39	*
27 & 29	53.01	6.89	47.88	8.12	100.89	15.01	453.23	*
27 & 29	46.56	7.53	42.48	8.50	89.04	16.02	453.23	*
30	78.08	10.05	73.56	11.18	151.64	21.22	602.90	106.9
30	71.65	2.88	67.22	3.69	138.87	6.57	403.08	*
30	54.61	5.51	53.72	7.65	108.32	13.16	228.39	*
30	48.00	6.24	47.88	8.12	95.88	14.36	453.23	*
30	42.16	6.82	42.48	8.50	84.64	15.31	453.23	*
28	97.80	12.65	72.94	11.15	170.74	23.80	517.41	107.4
28	63.72	7.47	50.10	7.91	113.82	15.38	373.19	107.4
31	174.64	31.80	100.67	12.14	275.30	43.94	703.26	103.1
31	131.55	10.15	71.03	4.04	202.58	14.19	539.62	103.1
31	127.25	14.73	58.30	8.45	185.54	23.18	377.64	103.1
32	9.86	4.00	15.54	7.10	25.40	11.10	91.24	41.25
33	36.23	8.68	29.05	6.60	65.28	15.28	170.08	49.41
34	72.22	12.19	42.55	6.65	114.77	18.84	302.54	49.41
35	Same as 20 which has greater imposed loading							

*Girder has sufficient shear capacity under the worst case (shallowest end and greatest shear). Therefore the shear capacity at the cut outs and curtailment points has not been checked due to the uncertainty of the stiffener locations.

Office	York Office	Page No.	111	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Concrete Slab (Angle) Check	Checker		Date	Mar-25

Concrete Deck

The deck between the steel girders will be checked using a single wheel load.

Checking the 3" x 3" x 1/2" angles

Section	b in	d in	A in ²	y in	A·y in ³	A(y-yt) ² in ³	I _{xx} in ⁴
Web	0.50	2.50	1.3	1.25	1.56	0.84	0.65
Flange	3.00	0.50	1.5	2.75	4.13	0.70	0.03
Net Area			2.8		5.69	1.53	0.68

Depth of full section	D =	3.00	in
Depth of web	d _{we} =	2.50	in
Distance to NA from top of section	y _t =	2.07	in
Distance to NA from bottom of section	y _b =	0.93	in
Second moment of area of section	I _{xx} =	2.22	in ⁴
Elastic section modulus (top flange)	Z _{xc} =	1.07	in ³
Elastic section modulus (bott. flange)	Z _{xt} =	2.38	in ³

The section of the deck between girder 31 and 32 has the greatest span and will therefore impose the greatest loading on a single angle.

Taking the distance between the girders at the support as a conservative assessment

Span = 5.96 ft

Distance between girders = 4.92 ft

Material	lb/cu.ft
Steel	490
Concrete	150
Miscellaneous Fill	135
Macadam (tar)	144


Self Weight (2.8/144) x (490/2240) = 0.0042 ton/ft

Concrete slab

Area = 105.25 in²
UDL = 0.049 ton/ft

Bitumen Layer

Area = 9 in²
UDL = 0.004 ton/ft



Office	York Office	Page No.	112	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Concrete Slab (Angle) Check	Checker		Date	Mar-25

Miscellaneous Fill

Area = 307.68 in²
 UDL = 0.129 ton/ft


Concrete

Area = 48 in²
 UDL = 0.022 ton/ft

Surfacing

Area = 48 in²
 UDL = 0.021 ton/ft

Total UDL = 0.230 ton/ft
 op09



Vmax = 0.56 ton

Mmax = (0.56 x 0.52) + (0.56 x 0.5 x 2.46)
 = 0.99 ton.ft

The angle will be checked for a single wheel load. Consider the following for dispersal of the wheel load.

BE4 CI 201

The maximum weight of 1 wheel is 5 ton

The approximate contact area for each wheel may be taken as 33 sq.in/ton and may be assumed as rectangular and equal to 1.4b²

Area of wheel load = 5 x 1.25 x 33
 = 206.25 sq.in

b = 12.14 in
 a = 16.99 in

Depth of fill to top of angle = 39.4 in

Length of dispersed sides
 A = 90.94 in = 7.578 ft
 B = 95.79 in = 7.983 ft


Office	York Office	Page No.	113	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Concrete Slab (Angle) Check	Checker		Date	Mar-25

Using the shorter side for a conservative assessment

The angle will carry 13% of the wheel load

Assuming the wheel load is dispersed evenly along the length of the angle

$$\begin{aligned} \text{UDL} &= (6.25 \times 0.13) / 5.958 \\ &= 0.138 \text{ ton/ft} \end{aligned}$$



$$M_{\text{max}} = 0.61 \text{ ton.ft}$$

$$V_{\text{max}} = 0.41 \text{ ton}$$

Capacity

$$\text{Permissible stress in bending} = 11.875 \text{ ton/sq.in}$$

$$\begin{aligned} \mu &= 28.2 \text{ ton.in} \\ &= 2.35 \text{ ton.ft} \end{aligned}$$

$$\text{Total imposed moment} = 1.60 \text{ ton.ft}$$

It will be assumed that stresses in the web will not exceed
 $p_{bc} = 5.50 \text{ ton/sq.in}$


$$\begin{aligned} \text{Shear capacity} &= 1.25 \times 5.5 \\ &= 6.88 \text{ ton} \end{aligned}$$

$$\text{Total imposed loads} = 0.98 \text{ ton}$$

Angle has sufficient capacity for imposed loads and therefore further checks considering the contribution of the concrete as well will not be undertaken.

Jacobs		CALCULATION SHEET			
Office	York	Page No.	114	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Jack Arches	Checker		Date	Mar-25

Jack Arch Assessment



Typical jack arch section from the cast iron section north of the road.

The jack arches are in fair condition. There is some minor spalling on isolated bricks and minor mortar loss throughout. Some softening of the mortar is expected due to the damp present across the structure soffit.

**Review of the adequacy of the jack arches and tie-rods will be based upon the empirical method described in Bridgeguard 3 Current Information Sheet No 22 (Pro-forma for the empirical assessment of brick, masonry and concrete jack arches and associated ties.)*

SECTION 1 Check for Compliance with 40T Configuration Requirements

					Compliant Yes/No
What is the maximum span of the arch?			1,308	m	Yes
<i>*Non-compliant if greater than 2.0m</i>					
Do jack arches spring from bottom flanges of beams?			Yes		Yes
<i>*If not, non-compliant</i>					
What is the beam spacing?	(web - web) b =		1,816	m	Yes
What is the rise of the arch?	r _c =		0,229	m	
Gross aspect ratio?	b/r _c =		7,93		
<i>*Non-compliant if b/r_c greater than 10</i>					
What is the arch barrel thickness?	d =		225	mm	Yes
(include concrete fill above)					
How is thickness derived?	From previous assessment calculations				Yes
<i>*Non-compliant if thickness is less than 220mm</i>					

Office	York	Page No.	115	Calc No.	0451956
Job No. & Title	VAR9/7410 HRE Assessment Programme BOK1/283 BE4 Assessment	Calcs by		Date	Mar-25
Section	Jack Arches	Checker		Date	Mar-25

SECTION 2 Check for Deficiency

Type No.	Deficiency	Pass/ Fail
1	<p>What is the backing material? Is it structural? » Possibly concrete, if not well compacted fill therefore considered structural</p> <p>Does the structural backing extend to at least the crown level of the arch extrados? <input type="text" value="Yes"/></p> <p><i>*If not, fail</i></p> <p>What is effective shear depth of deck? $D_s =$ <input type="text" value="489"/> mm » arch rise <input type="text" value="229"/> mm + barrel thickness <input type="text" value="225"/> mm + height of structural fill above crown of extrados <input type="text" value="35"/> mm</p> <p>Is $D_s \geq$ minimum requirement Fig1. Fig1. Min = <input type="text" value="393.92"/> mm <i>*Fail if $D_s <$ Fig 1</i> » 489 > 393.92</p>	Pass
2	<p>Do jack arches span longitudinally or transversely between longitudinal girders? <input type="text" value="Transversely"/></p> <p><i>For Longitudinal spanning jack arches, ignore following questions on ties/lateral restraint and state N/A.</i></p> <p>Are ties provided in edge bays of transverse spanning jack arches? <input type="text" value="No"/></p> <p><i>*If yes, go to 3a/3b</i> <i>*If not, fail, unless edge bay is 'hard' (see 5)</i> End bays considered hard</p>	Pass
3a CI	<p>What is the cross sectional area of one tie? $A =$ <input type="text" value="-"/> mm² <i>(Allowing for corrosion losses)</i></p> <p>What is the number of ties per beam length? $n =$ <input type="text" value="-"/></p> <p>What is the clear skew span? $L =$ <input type="text" value="-"/> m</p> <p>Specific area of tie (A_s) = $((n+1) \times A) / L$ $A_s =$ <input type="text" value="N/A"/> mm²/m <i>*Non-compliant if less than 260mm²/m</i></p> <p>What is the maximum tie spacing? $S =$ <input type="text" value="-"/> m <i>*Non compliant if greater than 3.0m for wrought iron/steel</i></p>	N/A
3b W/ ST	<p>What is the cross sectional area of one tie? $A =$ <input type="text" value="-"/> mm² <i>(Allowing for coorsion losses)</i></p> <p>What is the number of ties per beam length? $n =$ <input type="text" value="-"/></p> <p>What is the clear skew span? $L =$ <input type="text" value="-"/> m</p> <p>Specific area of tie (A_s) = $((n+1) \times A) / L$ $A_s =$ <input type="text" value="N/A"/> mm²/m <i>*Non-compliant if less than 260mm²/m</i></p> <p>What is the maximum tie spacing? $S =$ <input type="text" value="-"/> m <i>*Non compliant if greater than 3.0m for wrought iron/steel</i></p>	N/A
4	<p>Are ties located within crown of external arch? <input type="text" value="No"/></p> <p><i>*If so, then fail CI or possible fail for wrought iron/steel</i></p>	N/A
5	<p>Does external bay construction provide alternative lateral restraint? (ie not soft edge) <input type="text" value="Yes"/></p> <p><i>*If so, pass</i> <i>*If not, are ties provided in first Jack Arch bay?</i> <i>*If yes, treat as 3a (or 3b) Otherwise fail.</i></p>	Pass

Appendix G. Services Search Results



National One Call

Protecting People and Services in the UK

Online: www.national-one-call.co.uk

Call us: 0800 0853 865 (Mon-Fri, 9am-5pm)

Retriever Planning Pack

Jacobs UK Ltd

Enquiry Date	13/10/21	Enquiry	NOC/CTWSV456
Contact		Service	Retriever
Asset Owners	22	Enquiry Status	Complete
Price Status	Actual	Payment Status	Unpaid

Enquiry Specification

Option	What is it?	Selected
Enquiry Type	Enquiry by National One Call	✓
Express	Emailing of Plans as they arrive	✗
Fusion Plan	Compile Plans into 1 Drawing	✗
Delivery	Delivery of Completed Pack by Email	✓

Enquiry Documentation

Document	What is it?	Included
PlanToDig Enquiry	Details of Enquiry	✓
Asset Owner Contacts	List of Selected Asset Owners	✓
Text Responses	Instructions from Asset Owners	✓
CoRE	Certificate of Registered Enquiry	✓

Appendix A: Asset Owner Plans

See Plans section Cover Page for Details

Appendix B: Enquiry Accounting

Invoice	Invoice for Enquiry	✓
----------------	---------------------	---

For Guidance on PlanToDig

[View / download our PlanToDig Guide](#)



National One Call

Protecting People and Services in the UK


Online: www.national-one-call.co.uk

Call us: 0800 0853 865 (Mon-Fri, 9am-5pm)

PlanToDig Enquiry

Jacobs UK Ltd

Date	13/10/21	Enquiry	NOC/CTWSV456
Contact	[REDACTED]	Status	Complete



Enquiry Site

Dalston Ln, London E8 3DF

Disused railway tunnel (**Public Street / Road**)

OS Centre(Approx):533624,184860 (@5603 sq.mtrs)

Work Intentions

Intention	Start	Duration
Works Intended	2021-10-23	1 Day

Please send client waiver letter to all known service providers

Enquiry is Complete

Status: This Enquiry has Completed; you should now have all Responses from Asset Owners.

Asset Owners: Charges from 22 Asset Owners have been Confirmed

Timing: As Asset Owner Areas of Interest and Plans change frequently, please do not rely on Enquiries or Responses that are more than 30 days old.

Content: Asset Owner responses should be considered 'indicative only' until physically verified. Follow guidance in HSG(47)/NRSWA/CDM etc relating to services verification and excavation methods.



National One Call

Protecting People and Services in the UK

Online: www.national-one-call.co.uk

Call us: 0800 0853 865 (Mon-Fri, 9am-5pm)

Summary of Asset Owner Contacts for NOC/CTWSV456

Enquiry Date	13/10/21	Enquiry	NOC/CTWSV456
Selected Contacts	22	Closed	22
Est. Charges	£202.67	Act. Charges	£134.47

Contact List

Asset Owner	Status	Txt	Est.	Act.
Affected by Enquiry				
Asset Owner				
E S Pipelines Ltd	Closed		-	-
Electricity				
UK Power Networks (Operations) Ltd	Closed		£41.67	£41.67
Gas				
Cadent (National Grid Gas)	Closed		-	-
Multi-utility				
Brookfield Utilities UK (was GTC	Closed		-	-
Pipeline				
Linesearch (Pipeline search service)	Closed	T	-	-
Telecommunications				
BT Openreach	Closed		-	-
Virgin Media	Closed		£43.00	£43.00
Water / Sewerage				
Thames Water	Closed	T	£49.80	£49.80
See Response Text				
Electricity				
Utility Assets Ltd	Closed	T	-	-
Not Affected				
Asset Owner				
Zayo Group UK Ltd	Closed	T	-	-
Electricity				
National Grid Transmission Electricity	Closed		-	-
SSE Networks (Electricity)	Closed		£15.00	-
Gas				
National Grid Transmission (Gas)	Closed		-	-
Multi-utility				
Cofely District Energy	Closed	T	-	-
Telecommunications				
BSkyB Telecommunications Services Ltd	Closed	T	-	-
CityFibre	Closed	T	-	-
Colt Telecoms	Closed	T	-	-
Instalcom	Closed	T	-	-
Telia Sonera	Closed	T	-	-
Trafficmaster Ltd	Closed	T	-	-
Verizon Business	Closed	T	-	-
Vodafone Limited	Closed	T	£53.20	-



National One Call

Protecting People and Services in the UK

Online: www.national-one-call.co.uk

Call us: 0800 0853 865 (Mon-Fri, 9am-5pm)

Contact Comments

Some Asset Owners provide guidance / notes when making their Response - in the interests of safety, these should be provided to any Site Operatives along with any Plans.

Asset Owner	Comments
Affected by Enquiry	
Pipeline	
Linesearch (Pipeline search service)	Cadent Gas, ES Pipelines, UK Power Networks and Zayo UK in Zone of Interest
Water / Sewerage	
Thames Water	OSS/12/1395325.Your Reference: NOC/CTWSV456.Site Address Supplied: Dalston Lane, London, E8 3DF. Thank you for placing your order with Thames Water Property Searches.? Please see the attached file for further details regarding your case. Yours faithfully Customer Service TeamThames Water Property Searches
See Response Text	
Electricity	
Utility Assets Ltd	Thank you for recently contacting Utility Assets plant record department. We will check whether we have any plant present at your site and contact you within 5 - 7 working days ONLY if we own any plant in the vicinity. If we do not reply, we do not have any apparatus in the area of your works. However, PLEASE TAKE CARE when excavating around electricity cables in the event that not all cables present may be accurately shown. We recommend you use detecting equipment to map the site before excavating and fully comply with HSG47. DO NOT assume that a cable is dead if you don't have a record of its presence. The cable must be treated as live unless PROVEN DEAD by the cable owner. In case of emergency please contact your local electricity distribution company.
Not Affected	
Asset Owner	
Zayo Group UK Ltd	Having examined our records, we can confirm that ZAYO GROUP UK LTD has no owned apparatus within the searcharea of your enquiry detailed in the reference/location provided.
Multi-utility	
Cofely District Energy	We can confirm that, based on the details provided to us, we have no buried plant or equipment in the identified area.
Telecommunications	



National One Call

Protecting People and Services in the UK

Online: www.national-one-call.co.uk

Call us: 0800 0853 865 (Mon-Fri, 9am-5pm)

BSkyB Telecommunications Services Ltd	Please be advised that Sky Telecommunications Services Ltd will not be affected by your proposal.
CityFibre	Title: NOC/CTWSV456Comment:Please find attached a plan of the area of your interest that may contain plant which may be affected by your proposed works.The validity of this response is 6 weeks, after such time a new enquiry would need to be made.
Colt Telecoms	We can confirm that Colt Technology Services do not have apparatus near the above location as presented on your submitted plan
Instalcom	We can confirm that Lumen Technologies (formerly CenturyLink Communications UK Limited, Level 3, Global Crossing (Uk) Ltd, Global Crossing PEC, Fibernet UK Ltd and Fibrespan Ltd) do not have any apparatus within the indicated works area.
Telia Sonera	Our client?s apparatus, Telia Carrier, is not located within the vicinity of the above reference and we therefore haveno further interest in this current location
Trafficmaster Ltd	I can confirm that Trafficmaster does not have equipment installed within the boundary of the works.
Verizon Business	We have reviewed your plans and have determined that Verizon (Formally known as MCI WorldCom, MFS) has no apparatus in the areas concerned.
Vodafone Limited	Please accept this email as confirmation that Vodafone: Fixed does not have apparatus within the vicinity of your proposed works



National One Call

Protecting People and Services in the UK

Online: www.national-one-call.co.uk

Call us: 0800 0853 865 (Mon-Fri, 9am-5pm)

Asset Owner Plans Cover

Plans received from Asset Owners will be sent to you by email; these may require specialist printers, sometimes up to A0.

Plans may be accompanied by Disclaimers / Instructions etc. which will be contained in the Asset Owner Comments document. These Comments are often as important as the plans themselves as they give direction and context to the plan.

Treat All Plans as 'Indicative' until physically verified.

Sometimes an Asset Owner may have provided a Plan even if they considered that they are 'Not Affected'.

It is also possible that an Asset Owner has responded as 'Affected' but is unable to provide a Plan of their services; this will be stated in the Asset Owner Comments.

Ensure that Asset Owner Comments accompany Plans



National One Call

Protecting People and Services in the UK

Online: www.national-one-call.co.uk

Call us: 0800 0853 865 (Mon-Fri, 9am-5pm)

Certificate of Registered Enquiry (CoRE)

Enquiry Date	13/10/21	Enquiry	NOC/CTWSV456
Work Intention	Works Intended	Site Type	Public Street / Road

Asset Owners Contacted

A CoRE is issued on completion of a PlanToDig Enquiry, when all Responses have been received from the selected Asset Owners. Due to risk of changes to Asset Owner presences / their Area of Interest (AoI), and the probability of changes to plans and service presences, an Enquiry should only be considered 'good' for 30 days following Enquiry Date.

Asset Owner	Comments
Affected by Enquiry	
Asset Owner	
E S Pipelines Ltd	
Electricity	
UK Power Networks (Operations) Ltd	
Gas	
Cadent (National Grid Gas)	
Multi-utility	
Brookfield Utilities UK (was GTC	
Pipeline	
Linesearch (Pipeline search service)	✓
Telecommunications	
BT Openreach	
Virgin Media	
Water / Sewerage	
Thames Water	✓
See Response Text	
Electricity	
Utility Assets Ltd	✓
Not Affected	
Asset Owner	
Zayo Group UK Ltd	✓
Electricity	
National Grid Transmission Electricity	
SSE Networks (Electricity)	
Gas	
National Grid Transmission (Gas)	
Multi-utility	



National One Call

Protecting People and Services in the UK

Online: www.national-one-call.co.uk

Call us: 0800 0853 865 (Mon-Fri, 9am-5pm)



Cofely District Energy	✓
Telecommunications	
BSkyB Telecommunications Services Ltd	✓
CityFibre	✓
Colt Telecoms	✓
Instalcom	✓
Telia Sonera	✓
Trafficmaster Ltd	✓
Verizon Business	✓
Vodafone Limited	✓

NO	DESCRIPTION	DATE	BY
1	ISSUED FOR CONSTRUCTION	13/10/2021	MM
2	ISSUED FOR CONSTRUCTION	13/10/2021	MM
3	ISSUED FOR CONSTRUCTION	13/10/2021	MM
4	ISSUED FOR CONSTRUCTION	13/10/2021	MM



APPROVED FOR CONSTRUCTION

FIRS SITE

SOUTH CORE RISER ELEVATIONS



NORTH CORE RISER ELEVATIONS




Thin Metallic Edge Layer

300mm	Blue
400mm	Orange
450mm	Green
500mm	Red
550mm	Purple
600mm	Yellow
650mm	Cyan
700mm	Magenta
750mm	Black

CONSTRUCTION INFORMATION

NOTES

1. ALL WORK TO BE IN ACCORDANCE WITH THE CONTRACT DOCUMENTS.
2. ALL WORK TO BE IN ACCORDANCE WITH THE CONTRACT DOCUMENTS.
3. ALL WORK TO BE IN ACCORDANCE WITH THE CONTRACT DOCUMENTS.
4. ALL WORK TO BE IN ACCORDANCE WITH THE CONTRACT DOCUMENTS.



mgm


Network Number: 533511/80898
 Drawing Number: P00015985-PL-4-2-06-6
 Developer: Tokyo Kinokuniya Company Limited
 Location: Kingsford High Street, Dalmeida, London, E9 2DS

THIS DRAWING SHOWS
GTC LAYOUT

NO	REVISION	DATE	BY	CHK	APP
1	ISSUED FOR PERMIT	20.10.19
2	FOR CONSTRUCTION	20.10.19
3	FOR CONSTRUCTION	20.10.19
4	FOR CONSTRUCTION	20.10.19

APPROVED FOR CONSTRUCTION

FIRS SITE



Color	Material	Design Layer
Blue	300 Pipe	...
Orange	150 Pipe	...
Yellow	48 Pipe	...
Green	24 Pipe	...
Purple	12 Pipe	...
Red	6 Pipe	...

Symbol	Material	Design Layer
...
...
...

Drawing Scale: 1:200
 Network Number: 533511/80895
 Drawing Number: P00015985-1_R1-4_3_06
 Developer: Tokyo Vineyard
 Location: Kingsland High Street, Dalston, London, E9 2DS


THIS DRAWING SHOWS DEVELOPER LAYOUT

NO	REVISION	DATE	BY	CHKD	APP'D
1	ISSUED FOR PERMIT	20.10.19
2	FOR CONSTRUCTION	20.10.19
3	FOR CONSTRUCTION	20.10.19
4	FOR CONSTRUCTION	20.10.19

**FN0017524-1 - 51-57 Kingsland Road,
LONDON, E8 2J5**
Dev/Engr: Bennett Construction

**APPROVED FOR
CONSTRUCTION**

FIRS SITE



**EXISTING OFFSITE
OPENREACH DUCT**
370m of 14/10 sub duct
370m of 48F

**SKY
EXCHANGE
POSITION**
E:533465
N:184829

**OSCP
Position**
E:533565
N:184853

**Shiloh
Peelcoastal**
RN0015586-1 - Dalston Western Curve,
Kingsland High Street, London, E8 2J5
Dev/Engr: Taylor Wimpey

Color	Material / Layer
Blue	100mm Polystyrene
Green	150mm Polystyrene
Yellow	200mm Polystyrene
Orange	250mm Polystyrene
Red	300mm Polystyrene
Purple	400mm Polystyrene
Brown	500mm Polystyrene
Pink	600mm Polystyrene
Light Blue	700mm Polystyrene
Light Green	800mm Polystyrene
Light Yellow	900mm Polystyrene
Light Orange	1000mm Polystyrene
Light Red	1100mm Polystyrene
Light Purple	1200mm Polystyrene
Light Brown	1300mm Polystyrene
Light Pink	1400mm Polystyrene
Light Light Blue	1500mm Polystyrene
Light Light Green	1600mm Polystyrene
Light Light Yellow	1700mm Polystyrene
Light Light Orange	1800mm Polystyrene
Light Light Red	1900mm Polystyrene
Light Light Purple	2000mm Polystyrene
Light Light Brown	2100mm Polystyrene
Light Light Pink	2200mm Polystyrene
Light Light Light Blue	2300mm Polystyrene
Light Light Light Green	2400mm Polystyrene
Light Light Light Yellow	2500mm Polystyrene
Light Light Light Orange	2600mm Polystyrene
Light Light Light Red	2700mm Polystyrene
Light Light Light Purple	2800mm Polystyrene
Light Light Light Brown	2900mm Polystyrene
Light Light Light Pink	3000mm Polystyrene

Legend

- 100mm Polystyrene
- 150mm Polystyrene
- 200mm Polystyrene
- 250mm Polystyrene
- 300mm Polystyrene
- 400mm Polystyrene
- 500mm Polystyrene
- 600mm Polystyrene
- 700mm Polystyrene
- 800mm Polystyrene
- 900mm Polystyrene
- 1000mm Polystyrene
- 1100mm Polystyrene
- 1200mm Polystyrene
- 1300mm Polystyrene
- 1400mm Polystyrene
- 1500mm Polystyrene
- 1600mm Polystyrene
- 1700mm Polystyrene
- 1800mm Polystyrene
- 1900mm Polystyrene
- 2000mm Polystyrene
- 2100mm Polystyrene
- 2200mm Polystyrene
- 2300mm Polystyrene
- 2400mm Polystyrene
- 2500mm Polystyrene
- 2600mm Polystyrene
- 2700mm Polystyrene
- 2800mm Polystyrene
- 2900mm Polystyrene
- 3000mm Polystyrene

Notes

1. ALL DIMENSIONS ARE IN METERS UNLESS OTHERWISE STATED.
2. ALL DIMENSIONS ARE TO FACE UNLESS OTHERWISE STATED.
3. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
4. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
5. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
6. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
7. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
8. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
9. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
10. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
11. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
12. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
13. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
14. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
15. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
16. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
17. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
18. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
19. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
20. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
21. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
22. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
23. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
24. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
25. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
26. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
27. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
28. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
29. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.
30. ALL DIMENSIONS ARE TO CENTERLINE UNLESS OTHERWISE STATED.

Drawn Scale: 1:2000

Network Number: 533511/88085

OS Grid Reference: E:533565 N:184853

Developer: Taylor Wimpey

Location: Kingsland High Street, Dalston, London, E8 2J5

Project Name: Shiloh Peelcoastal

Project Number: FN0015586-1, J1, 4, 5, 6

Scale: 1:2000

Author: J. Smith

Check: M. Jones



Approved: K. Brown

Date: 20.10.19

Sheet: 1 of 1

THIS DRAWING SHOWS
GTC LAYOUT

Rev	Description	Date	By	Appr
1.7	RC Data Added from V.21.142	21/10/16	PK	PK
1.8	Approved LRC 3000 Approved from LV 16592	06/12/16	J	N/A
1.9	Schematic Updated: C03174/DWG/001/Rev 6	06/09/17	J	N/A
2.0	Schematic Updated: C03174/DWG/001/Rev 6	06/09/17	GS	N/A
2.1	RC Data Added from V.251.0 (RFD) 66225	07/05/17	J	N/A
2.2	RC Data Added from V.287.22 (RFD) 0101283	24/10/17	ENVT	N/A
2.3	RC Data Added from V.485.17 (RFD) 2795294	14/10/19	SM	N/A
2.4	Approved Design: C03174/DWG/001/Rev 8	25/10/19	CH	N/A
2.5	Approved Design: C03174/DWG/001/Rev 8	14/09/19	CH	N/A
2.6	Approved Schematic: C03174/DWG/001/Rev 9	21/03/20	CH	N/A
2.7	Approved Drawing: C03174/DWG/001/Rev 9	18/04/21	PH	N/A
2.8	LRC Data Added from V.568.02 (RFD) 443352	06/04/21	PH	N/A



This electrical network design has been prepared in accordance with the following standards:


- BS 7671:2018 (IET Wiring Regulations)
- BS EN 60947-1:2012 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-2:2014 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-3:2010 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-4:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-5:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-6:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-7:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-8:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-9:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-10:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-11:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-12:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-13:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-14:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-15:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-16:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-17:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-18:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-19:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-20:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-21:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-22:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-23:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-24:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-25:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-26:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-27:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-28:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-29:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-30:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-31:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-32:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-33:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-34:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-35:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-36:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-37:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-38:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-39:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-40:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-41:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-42:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-43:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-44:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-45:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-46:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-47:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-48:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-49:2011 (Low Voltage Switchgear and Controlgear)
- BS EN 60947-50:2011 (Low Voltage Switchgear and Controlgear)

Drawing Scale : VTS
 O.S. REF : 533536, 189E19
 Network Number : W0015683-1
 Project Number :
 Drawing Number : EN0015683-1_R2-8_3_of_5_Schematic 1
 Developer : Power On Connections
 Location : Delsion Curve, Kingland Hill Street, Delsion, London, E8





THIS DRAWING SHOWS:
 SCHEMATIC

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16




1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16

A B C D E F G H





1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16

A B C D E F G H







1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16

A B C D E F G H



1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16





A B C D E F G H



1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16

A B C D E F G H

Rev	Description	Date	By	CHK	Appr
1.1	RC Data Added from V.21742	21/11/16	PH	PH	N/A
1.2	Approved LRC Data Added from V.16592	06/12/16	JL	N/A	N/A
1.3	Approved LRC Data Added from V.16592	06/12/16	JL	N/A	N/A
1.4	Schematic Updated: C03174/DWG/001/Rev 5	06/09/17	JL	N/A	N/A
2.0	Schematic Updated: C03174/DWG/001/Rev 6	05/05/17	GR	N/A	N/A
2.1	RC Data Added from V.25110 (RFD) 66225	07/05/17	JL	N/A	N/A
2.2	RC Data Added from V.25110 (RFD) 66225	07/05/17	JL	N/A	N/A
2.3	RC Data Added from V.28722 (RFD) 01203	22/10/17	ENVT	N/A	N/A
2.4	RC Data Added from V.48517 (RFD) 27924	11/10/19	SM	N/A	N/A
2.5	Approved Design: C03174/DWG/001/Rev 8	25/10/19	CH	N/A	N/A
2.6	Approved Design: C03174/DWG/001/Rev 9	11/01/20	CH	N/A	N/A
2.7	Approved Drawing: C03174/DWG/001/Rev 5	21/03/20	CH	N/A	N/A
2.8	LRC Data Added from V.58852 (RFD) 44352	06/04/21	PH	N/A	N/A



This drawing has been prepared by The Electricity Business Company Ltd. It is a technical drawing and should not be used for any other purpose. It is the responsibility of the user to ensure that the drawing is used in accordance with the relevant standards and specifications. The drawing is the property of The Electricity Business Company Ltd. and should not be reproduced without their written consent. All cables and equipment used on this drawing are to be in accordance with the relevant standards and specifications. The drawing is the property of The Electricity Business Company Ltd. and should not be reproduced without their written consent.

This electrical network design has been prepared by:
 The Electricity Business Company Ltd.
 11, Langdon Green, Langdon, Essex, SS16 5LH
 Tel: 01206 440000
 Email: sales@theelectricitybusiness.com
 www.theelectricitybusiness.com

Drawing Scale: 1:500
 O.S. REF: 533536, 189E19
 Network Number: W0015683-1
 Project Number: EN0015683-1
 Drawing Number: EN0015683-1_R2-8_5_of_5 LRC

Developer: Power On Connections
 Location: Deighton Curve, Kingland Hill Street, Deighton, London, E8

THIS DRAWING SHOWS:
 LRC

Our Ref: Ref shown on map

Date of issue: shown on map

email: nnhc@openreach.co.uk

Dear Customer,

NR & SW ACT 1991 – PROPOSED WORKS AT: Dalston Ln, London.

Prior to commencement of work: For free onsite guidance and accurate up to date location of BT Apparatus please contact our Plant Protection Service by the following methods:-

Email the Click Before You Dig Team CBYD@openreach.co.uk

Visit the Click Before You Dig Website www.openreach.co.uk/cbyd

Thank you for your request of **NOC/CTWSV456** describing the above proposals.

Enclosed are copies of our drawings marked up to show the approximate locations of BT apparatus in the immediate vicinity of your works. It is intended for general guidance only. No guarantee is given of its accuracy.

The drawings are valid for 90 days from the date of issue and should not be relied upon after this time period has expired.

When planning excavation work or other works near to BT apparatus, please be mindful our apparatus may exist at various depths and may deviate from the marked route.


To avoid damage it is recommended that mechanical excavators or borers are not used within 600mm of BT apparatus. If scaffolding is erected, please ensure that our equipment is not enclosed, blocked, covered or otherwise obstructed by the scaffolding.

In the event of BT apparatus being in the area of your works we recommend that your plant/vehicle crossing is either resited, or apply for a budget estimate by submitting detailed plans to our Network Relocation Team at <https://www.ournetwork.openreach.co.uk/altering-our-network.aspx>

Yours faithfully,

Julie Cullum
NNHC & MBE Manager

Maps by email Plant Information Reply



IMPORTANT WARNING

Information regarding the location of BT apparatus is given for your assistance and is intended for general guidance only. No guarantee is given of its accuracy. It should not be relied upon in the event of excavations or other works being made near to BT apparatus which may exist at various depths and may deviate from the marked route.



openreach

CLICK BEFORE YOU DIG

FOR PROFESSIONAL FREE ON SITE ASSISTANCE PRIOR TO COMMENCEMENT OF EXCAVATION WORKS INCLUDING LOCATE AND MARKING SERVICE

email cbyd@openreach.co.uk

ADVANCE NOTICE REQUIRED
(Office hours: Monday - Friday 08.00 to 17.00)
www.openreach.co.uk/cbyd

Accidents happen

If you do damage any Openreach equipment please let us know by calling 0800 023 2023 (opt 1 + opt 1) and we can get it fixed ASAP

KEY TO BT SYMBOLS		Change Of State	+	Hatchings	
	<i>Planned</i>	<i>Live</i>	×	Built	
PCP			▲	Planned	
Pole			■	Inferred	
Box			Ⓚ	Duct	
Manhole			Other proposed plant is shown using dashed lines. BT Symbols not listed above may be disregarded. Existing BT Plant may not be recorded. Information valid at time of preparation. Maps are only valid for 90 days after the date of publication.		
Cabinet					
	<i>Pending Add</i>	<i>In Place</i>	<i>Pending Remove</i>	<i>Not In Use</i>	
Power Cable					
Power Duct				N/A	

Reproduced from the Ordnance Survey map by BT by permission of Ordnance Survey on behalf of the Controller of Her Majesty's Stationary Office

(C) Crown Copyright British Telecommunications plc 100028040

BT Ref : EJD09575R

Map Reference : (centre) TQ3363584806

Easting/Northing : (centre) 533635,184806

Issued : 13/10/2021 09:58:07

WARNING: IF PLANNED WORKS FALL INSIDE HATCHED AREA IT IS ESSENTIAL BEFORE PROCEEDING THAT YOU CONTACT THE NATIONAL NOTICE HANDLING CENTRE. PLEASE SEND E-MAIL TO: nnhc@openreach.co.uk

Date: 13/10/2021

LinesearchbeforeUdig ref: 23548644

Your ref: NOC/CTWSV456

Dear Sir/Madam,

Your planned works may proceed with caution.

We have received a notification from the LinesearchbeforeUdig (LSBUD) platform regarding your plans to carry out works. Based on the information you provided:

Although there are Cadent gas pipes in the area you're planning to work, you can proceed with your planned work with caution and in line with the guidance. This outcome is based on the information you gave us. If your plans change, or you are unable to work to the guidance please let us know as soon as possible so we can work with you to find a solution.

If your works are being carried out in an easement, please ensure that you contact us to obtain formal, signed written consent which will only be provided following consultation with our plant protection team.

Please find enclosed a copy of our plans for the area and ensure you follow our key guidance document [Specification for Safe Working in the Vicinity of Cadent Assets](#).

What you need to do

BEFORE carrying out any work you must:

- Carefully read the guidance documents and maps showing the location of our gas apparatus.
- Contact the landowner and ensure any proposed works in private land do not infringe on Cadent's legal rights (i.e. easements or other rights). If the works are in the road or footpath, the relevant local authority should be contacted.
- Ensure that all persons, including direct labour and contractors, working for you on or near Cadent apparatus follow the requirements of the HSE Guidance Notes HSG47 'Avoiding danger from underground services'. This guidance can be downloaded free of charge at www.hse.gov.uk
- In line with the guidance, verify and establish the actual position of gas mains, pipes, services and other apparatus on site before any activities are undertaken.

DURING any work you must:

- Comply with all guidance and any further guidance from our specialist team.
- Ensure that access to Cadent apparatus is maintained at all times.
- Prevent the placing of heavy construction plant, equipment, materials or the passage of heavy vehicles over Cadent apparatus unless specifically agreed with us in advance.
- Exercise extreme caution if slab (mass) concrete is encountered during excavation works as this may be protecting or supporting Cadent apparatus.
- Maintain appropriate clearances between gas apparatus and the position of other buried plant.

This outcome is valid for 28 days from the date of this letter. If your work, or the location, date or nature of the work you're doing changes, you must submit another enquiry.

If you need any further information or have any questions about this letter, please contact us at plantprotection@cadentgas.com or on **0800 688 588** quoting your reference at the top of this letter.

Your responsibilities and obligations

It is your responsibility to ensure that the information you have given us is accurate. You must also share all relevant documents, including the guidance notes, with anyone who carries out work on your behalf.

This assessment solely relates to Cadent gas pipes. It doesn't include:

- Cadent's legal interest (easements or other rights) in the land which restricts activity near Cadent's pipes in private land. You must get details of any such restrictions from the landowner in the first instance and if in doubt contact us on **0800 688 588** or at
- Gas service pipes and related apparatus.
- Recently installed apparatus.
- Apparatus owned by other organisations such as other gas distribution networks, local electricity companies and other utilities.

It is your responsibility to consider whether the points above are relevant to you and whether they could be affected by your proposed work.

This letter does not constitute any formal agreement or consent for any proposed development work either generally or related to Cadent's easements or other rights, or any planning or building regulations applications.

Cadent Gas Ltd or their agents, servants or contractors do not accept any liability for any losses arising under or in connection with this information. This limit on liability applies to all and any claims in contract, tort (including negligence), misrepresentation (excluding fraudulent misrepresentation), breach of statutory duty or otherwise. This limit on liability does not exclude or restrict liability where prohibited by the law nor does it supersede the express terms of any related agreements.


Kind Regards,

Plant Protection Team

T: 0800 688 588

plantprotection@cadentgas.com

Overview Map of Worksite 2



Warning: PDF designed for A3 colour print only with no page scaling

In case of an emergency call 0800 111 999



Dig Sites

- LP Mains
- MP Mains
- IP Mains
- LPP Mains

Area: ---
Line: ---

Valve

Depth of cover

Syphon

Diameter Change

Material Change


Out of Standard Service

IMPORTANT NOTICES

This plan shows the gas pipes owned by Cadent Gas Limited in its role as a Licensed Gas Transporter (G1). Gas pipes owned by other G1's or otherwise privately owned may be present in this area. Information with regards to such pipes should be obtained from the relevant owners. The information shown on this plan is given without warranty, the accuracy thereof cannot be guaranteed. Service pipes, valves, syphons, stub connections etc. are not shown but their presence should be anticipated. No liability of any kind whatsoever is accepted by Cadent Gas Limited or its agents, servants or contractors for any errors or omissions. Safe digging practices, in accordance with HSE/G47, must be used to verify and establish the actual position of mains, pipes, services and other apparatus on site before any mechanical plant is used. It is your responsibility to ensure that this information is provided to all persons (either direct labour or contractors) working for you on or near gas apparatus. The information included on this plan should not be referred to beyond a period of 28 days from the date of issue.

Date Requested: 13/10/2021
 Job Reference: 23548644
 Site Location: 533635 164805
 Requested by:
 Mr Brian McMaster
 Your Scheme Reference:
 NOCCTWS456

Scale: 1:1538 (When plotted at A3)



Warning: PDF designed for A3 colour print only with no page scaling

In case of an emergency call 0800 111 999

Dig Sites

- LP Mains
- MP Mains
- IP Mains
- LHP Mains

Area: - - - - -

Line: - - - - -


- Valve
- Depth of cover
- Syphon
- Diameter Change
- Material Change
- Out of Standard Service

IMPORTANT NOTICES

This plan shows these pipes owned by Cadent Gas Limited in its role as a Licensed Gas Transporter (G1). Gas pipes owned by other G1's or otherwise privately owned may be present in this area. Information shown on this plan is given without warranty, the accuracy thereof cannot be guaranteed. Service pipes, valves, syphons, stub connections etc. are not shown but their presence should be anticipated. No liability of any kind whatsoever is accepted by Cadent Gas Limited or their agents, servants or contractors for any errors or omission. Safe digging practices, in accordance with HSE/G47, must be used to verify and establish the actual position of mains, pipes, services and other apparatus on site before any mechanical plant is used. It is your responsibility to ensure that this information is provided to all persons (either direct labour or contractors) working for you or near gas apparatus. The information included on this plan should not be referred to beyond a period of 28 days from the date of issue.

Date Requested: 13/10/2021
 Job Reference: 23548644
 Site Location: 533635 164805
 Requested by:
 Yr Brian McMaister
 Your Scheme Reference:
 NOCCTWSV456

Scale: 1:500 (When plotted at A3)



Warning: PDF designed for A3 colour print only with no page scaling

In case of an emergency call 0800 111 999

Dig Sites

- LP Mains
- MP Mains
- IP Mains
- LHP Mains

Area: [Dashed Purple Line]

Line: [Dashed Purple Line]

Scale: 50m

- Valve
- Depth of cover
- Syphon
- Diameter Change
- Material Change
- Out of Standard Service


View extent: 200m, 115m

IMPORTANT NOTICES

This plan shows these pipes owned by Cadent Gas Limited in its role as a Licensed Gas Transporter (GT). Gas pipes owned by other GT's or otherwise privately owned may be present in this area. Information with regards to such pipes should be obtained from the relevant owners. The information shown on this plan is given without warranty, the accuracy thereof cannot be guaranteed. Service pipes, valves, syphons, stub connections etc. are not shown but their presence should be anticipated. No liability of any kind whatsoever is accepted by Cadent Gas Limited or their agents, servants or contractors for any errors or omission. Safe digging practices, in accordance with H5(G)47, must be used to verify and establish the actual position of mains, pipes, services and other apparatus on site before any mechanical plant is used. It is your responsibility to ensure that this information is provided to all persons (either direct labour or contractors) working for you on or near gas apparatus. The information included on this plan should not be referred to beyond a period of 28 days from the date of issue.

Date Requested: 13/10/2021
 Job Reference: 23548644
 Site Location: 539635 164805
 Requested by:
 Mr Brian McMaister
 Your Scheme Reference:
 NOCCTWSV456

Scale: 1:500 (When plotted at A3)



Warning: PDF designed for A3 colour print only with no page scaling

In case of an emergency call 0800 111 999

View extent: 200m, 115m

IMPORTANT NOTICES

This plan shows the pipes owned by Cadent Gas Limited in its role as a Licensed Gas Transporter (GT). Gas pipes owned by other GT's or otherwise privately owned may be present in this area. Information with regards to such pipes should be obtained from the relevant owners. The information shown on this plan is given without warranty, the accuracy thereof cannot be guaranteed. Service pipes, valves, syphons, stub connections etc. are not shown but their presence should be anticipated. No liability of any kind whatsoever is accepted by Cadent Gas Limited or their agents, servants or contractors for any errors or omissions. Safe digging practices, in accordance with HSE/G47, must be used to verify and establish the actual position of mains, pipes, services and other apparatus on site before any mechanical plant is used. It is your responsibility to ensure that this information is provided to all persons (either direct labour or contractors) working for you on or near gas apparatus. The information included on this plan should not be referred to beyond a period of 28 days from the date of issue.

Dig Sites

- LP Mains
- MP Mains
- IP Mains
- LHP Mains

Line:

- Area
- Line

Valve

Depth of cover

Syphon

Diameter Change


Material Change

Out of Standard Service

Date Requested: 13/10/2021
 Job Reference: 23548644
 Site Location: 539635 164805
 Requested by:
 Yr Brian McMaster
 Your Scheme Reference:
 NOCCTWSV456

Scale: 1:500 (When plotted at A3)

Crown Copyright © - This plan is reproduced from or based on the OS map by Cadent Gas Limited, with the sanction of the controller of the HM Stationary Office. Crown Copyright Reserved. Ordnance Survey Licence number 100024886



Warning: PDF designed for A3 colour print only with no page scaling

In case of an emergency call 0800 111 999

Cadent
Your Gas Network

Dig Sites

- LP Mains
- MP Mains
- IP Mains
- LHP Mains

Area: [Dashed Purple Box] **Line:** [Dashed Purple Line]

- Valve
- Depth of cover
- Syphon
- Diameter Change
- Material Change
- Out of Standard Service

Scale: 1:500 (When plotted at A3)


View extent: 200m, 115m

IMPORTANT NOTICES

This plan shows these pipes owned by Cadent Gas Limited in its role as a Licensed Gas Transporter (GT). Gas pipes owned by other GT's or otherwise probably owned may be present in this area. Information with regards to such pipes should be obtained from the relevant owners. The information shown on this plan is given without warranty, the accuracy thereof cannot be guaranteed. Service pipes, valves, syphons, stub connections etc. are not shown but their presence should be anticipated. No liability of any kind whatsoever is accepted by Cadent Gas Limited or their agents, servants or contractors for any errors or omissions. Safe digging practices, in accordance with HSE/G47, must be used to verify and establish the actual position of mains, pipes, services and other apparatus on site before any mechanical plant is used. It is your responsibility to ensure that this information is provided to all persons (either direct labour or contractors) working for you on or near gas apparatus. The information included on this plan should not be referred to beyond a period of 28 days from the date of issue.

Date Requested: 13/10/2021
 Job Reference: 23548644
 Site Location: 539635 164805
 Requested by:
 Mr Brian McMaster
 Your Scheme Reference:
 NOCCTWSV456

Scale: 1:500 (When plotted at A3)



Warning: PDF designed for A3 colour print only with no page scaling

In case of an emergency call 0800 111 999

Scale: 1:500 (When plotted at A3)

IMPORTANT NOTICES

This plan shows the gas pipes owned by Cadent Gas Limited in role as Licensed Gas Transporter (GT). Gas pipes owned by other GT's or otherwise privately owned are not shown on this plan. Information with regards to such pipes should be obtained from the relevant owners. The information shown on this plan is given without warranty but its accuracy cannot be guaranteed. Service pipes, valves, syphons, stub connections etc. are not shown but their presence should be anticipated. No liability of any kind whatsoever is accepted by Cadent Gas Limited or its agents, servants or contractors for errors or omissions. Safe digging practices, in accordance with HSE/G47, must be used to verify and establish the actual position of mains, pipes, services and other apparatus on site before any mechanical plant is used. It is your responsibility to ensure that this information is provided to all persons (either direct labour or contractors) working for you on or near gas apparatus. The information included on this plan should not be referred to beyond a period of 28 days from the date of issue.

View extent: 200m, 115m

Dig Sites

- LP Mains
- MP Mains
- IP Mains
- LHP Mains

Line:

- Area
- Line

Valve

Depth of cover

Syphon

Diameter Change

Material Change

Out of Standard Service

Date Requested: 13/10/2021

Job Reference: 23548644


Site Location: 539635 164805

Requested by: Mr Brian McMaister

Your Scheme Reference: NOCCTWSV456

Scale: 1:500 (When plotted at A3)

Copyright: Crown Copyright © - This plan is reproduced from or based on the OS map by Cadent Gas Limited, with the sanction of the controller of the HM Stationary Office. Crown Copyright Reserved. Ordnance Survey Licence number 100024886



Warning: PDF designed for A3 colour print only with no page scaling

In case of an emergency call 0800 111 999

Dig Sites

- LP Mains (Red line)
- MP Mains (Blue line)
- IP Mains (Green line)
- LHP Mains (Yellow line)

Area: - - - - -

Line: - - - - -

- Valve (Symbol: X)
- Depth of cover (Symbol: V)
- Syphon (Symbol: O)
- Diameter Change (Symbol: T)
- Material Change (Symbol: I)
- Out of Standard Service (Symbol: !)

Scale bar: 50m

IMPORTANT NOTICES

This plan shows the pipes owned by Cadent Gas Limited in its role as a Licensed Gas Transporter (G1). Gas pipes owned by other G1's or otherwise privately owned may be present in this area. Information with regards to such pipes should be obtained from the relevant owners. The information shown on this plan is given without warranty, the accuracy thereof cannot be guaranteed. Service pipes, valves, syphons, stub connections etc. are not shown but their presence should be anticipated. No liability of any kind whatsoever is accepted by Cadent Gas Limited or their agents, servants or contractors for any errors or omissions. Safe digging practices, in accordance with H5(G)47, must be used to verify and establish the actual position of mains, pipes, services and other apparatus on site before any mechanical plant is used. It is your responsibility to ensure that this information is provided to all persons (either direct labour or contractors) working for you on or near gas apparatus. The information included on this plan should not be referred to beyond a period of 28 days from the date of issue.

View extent: 200m, 115m

Date Requested: 13/10/2021
 Job Reference: 23548644
 Site Location: 539635 164805
 Requested by:
 Mr Brian McMaister
 Your Scheme Reference:
 NOCCTWSV456

Scale: 1:500 (When plotted at A3)

Crown Copyright © - This plan is reproduced from or based on the OS map by Cadent Gas Limited, with the sanction of the controller of the HM Stationary Office. Crown Copyright Reserved. Ordnance Survey Licence number 100024886

LEGEND

- EXISTING PLANT
- EXISTING PLANT

bitmap_layout_select_raster

Head Office
CityFibre Holdings Ltd
15 Bedford Street,
London
WC2E 9HE
Tel: 0845 293 0774
Web: www.cityfibre.com

Asset Office
CityFibre Holdings Ltd
Rutherford House,
Birchwood,
Warrington,
WA3 6ZJ
Email: asset.team@cityfibre.com

Disclaimer:

Information shown on this plan is for general guidance only. No warranty is made as to its accuracy. This plan must not be solely relied upon in the event of excavation or other works being carried out in the vicinity of Cityfibre plant.

No liability of any kind is accepted by Cityfibre, its agents or servants for any error, omission, discrepancy or deviation. This information is valid for the date printed.

Project
Plant Enquiry

Drawing
Existing Plant

Drawn by:
smallworld


Date: 13/10/2021

Drawing No.
CFH_EP_000001

Revision
001

Scale: 1:2500

A4



13/10/2021

LinesearchbeforeUdig Ref: 23548644

Your Ref: NOC/CTWSV456

Dear Sir/Madam,

Further to your enquiry received on 13/10/2021 08:57:57 AM please find attached the ESP Utilities Group (ESP) response to your enquiry.

If your proposed work site was found to be in the vicinity of ESP plant, project drawing as laid extracts for these sites are enclosed (not to scale) for your information which show the approximate location of the ESP gas/electric network close to the area of interest.

As your plans for the proposed work develop you are required to keep ESP regularly updated about the extent and nature of your proposed works in order for us to fully establish whether any additional precautionary or diversionary works are necessary to protect our gas network.


Arrangements can be set in place so that one of our representatives can meet on site (date to be agreed) and we will be happy to discuss the impact of your proposals on the gas network once we have received the details.

ESP are continually constructing new gas and electricity networks and this notification is valid for 90 days from the date of this letter. If your proposed works start after this period of time, please re-submit your linesearchbeforeUdig enquiry.

Yours sincerely,

ESP Utilities Group Ltd

Overview



Date Requested: 13/10/2021

Requested by: Brian McMaster

Job Reference: 23548644

Company: PlanToDig

Your Scheme/Reference: NOC/CTWSV456

Key for Mains & Service Pipework

-  Existing LP mains or services operating up to 75 millibar gauge
-  Existing MP mains or services operating between 75 millibar and 2 bar gauge
-  Existing IP mains or services operating between 2 bar and 7 bar gauge

Whilst ESP Utilities Group Ltd (ESP) try to ensure the asset information we provide is accurate, the information is provided Without Prejudice and ESP accept no liability for claims arising from any inaccuracy, omissions or errors contained in this response. The actual position of underground services must be verified and established on site before any mechanical plant is used. Authorities and contractors will be held liable for the full cost of repairs to ESP apparatus and all claims made against them by Third parties as a result of any interference or damage.

REPRODUCED FROM THE ORDNANCE SURVEY MAP WITH THE SANCTION OF THE CONTROLLER OF HER MAJESTY'S STATIONARY OFFICE © CROWN COPYRIGHT RESERVED.

THIS DRAWING IS THE COPYRIGHT OF ES PIPELINES LIMITED AND MAY NOT BE REPRODUCED WITHOUT WRITTEN CONSENT ©




ESP Utilities Group Ltd
 Bluebird House
 Mole Business Park
 Leatherhead
 Surrey
 KT22 7BA
 Phone: 01372 587500
 Email: PlantResponses@espug.com

Dig Sites:

Area  Line 

Approx scale on A4 paper: 1:1000
 (excluding Overview map)



Date Requested: 13/10/2021

Requested by: Brian McMaster

Job Reference: 23548644

Company: PlanToDig

Your Scheme/Reference: NOC/CTWSV456

Key for Mains & Service Pipework

-  Existing LP mains or services operating up to 75 millibar gauge
-  Existing MP mains or services operating between 75 millibar and 2 bar gauge
-  Existing IP mains or services operating between 2 bar and 7 bar gauge

Whilst ESP Utilities Group Ltd (ESP) try to ensure the asset information we provide is accurate, the information is provided Without Prejudice and ESP accept no liability for claims arising from any inaccuracy, omissions or errors contained in this response. The actual position of underground services must be verified and established on site before any mechanical plant is used. Authorities and contractors will be held liable for the full cost of repairs to ESP apparatus and all claims made against them by Third parties as a result of any interference or damage.

REPRODUCED FROM THE ORDNANCE SURVEY MAP WITH THE SANCTION OF THE CONTROLLER OF HER MAJESTY'S STATIONARY OFFICE © CROWN COPYRIGHT RESERVED.

THIS DRAWING IS THE COPYRIGHT OF ES PIPELINES LIMITED AND MAY NOT BE REPRODUCED WITHOUT WRITTEN CONSENT ©




ESP Utilities Group Ltd
 Bluebird House
 Mole Business Park
 Leatherhead
 Surrey
 KT22 7BA
 Phone: 01372 587500
 Email: PlantResponses@espug.com

Dig Sites:

Area  Line 

Approx scale on A4 paper: 1:1000
 (excluding Overview map)



Date Requested: 13/10/2021

Requested by: Brian McMaster

Job Reference: 23548644

Company: PlanToDig

Your Scheme/Reference: NOC/CTWSV456

Key for Mains & Service Pipework



Existing LP mains or services operating up to 75 millibar gauge



Existing MP mains or services operating between 75 millibar and 2 bar gauge



Existing IP mains or services operating between 2 bar and 7 bar gauge

Whilst ESP Utilities Group Ltd (ESP) try to ensure the asset information we provide is accurate, the information is provided Without Prejudice and ESP accept no liability for claims arising from any inaccuracy, omissions or errors contained in this response. The actual position of underground services must be verified and established on site before any mechanical plant is used. Authorities and contractors will be held liable for the full cost of repairs to ESP apparatus and all claims made against them by Third parties as a result of any interference or damage.

REPRODUCED FROM THE ORDNANCE SURVEY MAP WITH THE SANCTION OF THE CONTROLLER OF HER MAJESTY'S STATIONARY OFFICE © CROWN COPYRIGHT RESERVED.

THIS DRAWING IS THE COPYRIGHT OF ES PIPELINES LIMITED AND MAY NOT BE REPRODUCED WITHOUT WRITTEN CONSENT ©




ESP Utilities Group Ltd
 Bluebird House
 Mole Business Park
 Leatherhead
 Surrey
 KT22 7BA
 Phone: 01372 587500
 Email: PlantResponses@espug.com

Dig Sites:

Area Line

Approx scale on A4 paper: 1:1000
 (excluding Overview map)



Date Requested: 13/10/2021

Requested by: Brian McMaster

Job Reference: 23548644

Company: PlanToDig

Your Scheme/Reference: NOC/CTWSV456

Key for Mains & Service Pipework

-  Existing LP mains or services operating up to 75 millibar gauge
-  Existing MP mains or services operating between 75 millibar and 2 bar gauge
-  Existing IP mains or services operating between 2 bar and 7 bar gauge

Whilst ESP Utilities Group Ltd (ESP) try to ensure the asset information we provide is accurate, the information is provided Without Prejudice and ESP accept no liability for claims arising from any inaccuracy, omissions or errors contained in this response. The actual position of underground services must be verified and established on site before any mechanical plant is used. Authorities and contractors will be held liable for the full cost of repairs to ESP apparatus and all claims made against them by Third parties as a result of any interference or damage.

REPRODUCED FROM THE ORDNANCE SURVEY MAP WITH THE SANCTION OF THE CONTROLLER OF HER MAJESTY'S STATIONARY OFFICE © CROWN COPYRIGHT RESERVED.



THIS DRAWING IS THE COPYRIGHT OF ES PIPELINES LIMITED AND MAY NOT BE REPRODUCED WITHOUT WRITTEN CONSENT ©



ESP Utilities Group Ltd
 Bluebird House
 Mole Business Park
 Leatherhead
 Surrey
 KT22 7BA
 Phone: 01372 587500
 Email: PlantResponses@espug.com

Dig Sites:

Area  Line 
 Approx scale on A4 paper: 1:1000
 (excluding Overview map)




Manifold Schematic

2" steel riser with 1 1/4" steel laterals and 50mm long 3/4" steel offtakes for each meter.
 ALLOW FURTHER 1/2 METRE ABOVE HEIGHT SHOWN FOR METER INSTALLATION
 Design as per NP14 tables A.6 & B.4.

IIV to be fitted inside building close to point of entry to building.
Alternatively a building entry tee with an integral valve operable only by a special key.
Please refer to table Supporting Above Ground Network Pipelines on this drawing for pipe support spacing.

Mains Design Pressure and Velocity		Network Design	
LP	MP	LP	MP
Source Pressure	23 mBar	63mm LP	16 MP
Peak Flow	12.7 m3/hr	90mm LP	63mm Pe
Maximum Velocity	4.35 m/s	125mm LP	90mm Pe
Minimum Pressure	22.71 mBar	180mm LP	125mm Pe
Pressure Drop	0.29 mBar	250mm LP	180mm Pe
Parent Main Operator	Cadent	315mm LP	250mm Pe
Parent Main Dia	90mm	355mm LP	355mm Pe
Parent Main Material	Pe	Steel LP	Steel MP
Connection	63mm top outlet service tee	1.25" LP	5.1 MP
POC Coordinates	533488, 184810	2" LP	1.3 MP
Downstream Main	63mm Pe		

Meterbox Types: Manifold



Asset location search



Property Searches

National One Call Plan To Dig
Mill Place
1 Mill Road Industrial Estate
WEST LOTHIAN
EH49 7TL

Search address supplied Dalston Lane
London
E8 3DF

Your reference NOC/CTWSV456

Our reference ALS/ALS Standard/2021_4521701

Search date 13 October 2021

Knowledge of features below the surface is essential for every development

The benefits of this knowledge not only include ensuring due diligence and avoiding risk, but also being able to ascertain the feasibility of any development.

Did you know that Thames Water Property Searches can also provide a variety of utility searches including a more comprehensive view of utility providers' assets (across up to 35-45 different providers), as well as more focused searches relating to specific major utility companies such as National Grid (gas and electric).

Contact us to find out more.



Thames Water Utilities Ltd
Property Searches, PO Box 3189, Slough SL1 4WW
DX 151280 Slough 13



searches@thameswater.co.uk
www.thameswater-propertysearches.co.uk



0800 009 4540

Asset location search



Property Searches

Search address supplied: Dalston Lane, London, E8 3DF

Dear Sir / Madam

An Asset Location Search is recommended when undertaking a site development. It is essential to obtain information on the size and location of clean water and sewerage assets to safeguard against expensive damage and allow cost-effective service design.

The following records were searched in compiling this report: - the map of public sewers & the map of waterworks. Thames Water Utilities Ltd (TWUL) holds all of these.

This search provides maps showing the position, size of Thames Water assets close to the proposed development and also manhole cover and invert levels, where available.

Please note that none of the charges made for this report relate to the provision of Ordnance Survey mapping information. The replies contained in this letter are given following inspection of the public service records available to this company. No responsibility can be accepted for any error or omission in the replies.

You should be aware that the information contained on these plans is current only on the day that the plans are issued. The plans should only be used for the duration of the work that is being carried out at the present time. Under no circumstances should this data be copied or transmitted to parties other than those for whom the current work is being carried out.

Thames Water do update these service plans on a regular basis and failure to observe the above conditions could lead to damage arising to new or diverted services at a later date.

Contact Us

If you have any further queries regarding this enquiry please feel free to contact a member of the team on 0800 009 4540, or use the address below:

Thames Water Utilities Ltd
Property Searches
PO Box 3189
Slough
SL1 4WW

Email: searches@thameswater.co.uk

Web: www.thameswater-propertysearches.co.uk

Waste Water Services

Please provide a copy extract from the public sewer map.

Enclosed is a map showing the approximate lines of our sewers. Our plans do not show sewer connections from individual properties or any sewers not owned by Thames Water unless specifically annotated otherwise. Records such as "private" pipework are in some cases available from the Building Control Department of the relevant Local Authority.

Where the Local Authority does not hold such plans it might be advisable to consult the property deeds for the site or contact neighbouring landowners.

This report relates only to sewerage apparatus of Thames Water Utilities Ltd, it does not disclose details of cables and or communications equipment that may be running through or around such apparatus.

The sewer level information contained in this response represents all of the level data available in our existing records. Should you require any further Information, please refer to the relevant section within the 'Further Contacts' page found later in this document.

For your guidance:

- The Company is not generally responsible for rivers, watercourses, ponds, culverts or highway drains. If any of these are shown on the copy extract they are shown for information only.
- Any private sewers or lateral drains which are indicated on the extract of the public sewer map as being subject to an agreement under Section 104 of the Water Industry Act 1991 are not an 'as constructed' record. It is recommended these details be checked with the developer.

Clean Water Services

Please provide a copy extract from the public water main map.

Enclosed is a map showing the approximate positions of our water mains and associated apparatus. Please note that records are not kept of the positions of individual domestic supplies.

For your information, there will be a pressure of at least 10m head at the outside stop valve. If you would like to know the static pressure, please contact our Customer Centre on 0800 316 9800. The Customer Centre can also arrange for a full flow and pressure test to be carried out for a fee.

Asset location search



Property Searches

For your guidance:

- Assets other than vested water mains may be shown on the plan, for information only.
- If an extract of the public water main record is enclosed, this will show known public water mains in the vicinity of the property. It should be possible to estimate the likely length and route of any private water supply pipe connecting the property to the public water network.

Payment for this Search

A charge will be added to your suppliers account.



Further contacts:

Waste Water queries

Should you require verification of the invert levels of public sewers, by site measurement, you will need to approach the relevant Thames Water Area Network Office for permission to lift the appropriate covers. This permission will usually involve you completing a TWOSA form. For further information please contact our Customer Centre on Tel: 0845 920 0800. Alternatively, a survey can be arranged, for a fee, through our Customer Centre on the above number.

If you have any questions regarding sewer connections, budget estimates, diversions, building over issues or any other questions regarding operational issues please direct them to our service desk. Which can be contacted by writing to:

Developer Services (Waste Water)
Thames Water
Clearwater Court
Vastern Road
Reading
RG1 8DB

Tel: 0800 009 3921
Email: developer.services@thameswater.co.uk


Clean Water queries

Should you require any advice concerning clean water operational issues or clean water connections, please contact:

Developer Services (Clean Water)
Thames Water
Clearwater Court
Vastern Road
Reading
RG1 8DB

Tel: 0800 009 3921
Email: developer.services@thameswater.co.uk

Asset Location Search Sewer Map - ALS/ALS Standard/2021 4521701



The width of the displayed area is 200 m and the centre of the map is located at OS coordinates 533636,184800

The position of the apparatus shown on this plan is given without obligation and warranty, and the accuracy cannot be guaranteed. Service pipes are not shown but their presence should be anticipated. No liability of any kind whatsoever is accepted by Thames Water for any error or omission. The actual position of mains and services must be verified and established on site before any works are undertaken.

Based on the Ordnance Survey Map with the Sanction of the controller of H.M. Stationery Office. License no. 100019345 Crown Copyright Reserved.

NB. Levels quoted in metres Ordnance Newlyn Datum. The value -9999.00 indicates that no survey information is available

Manhole Reference	Manhole Cover Level	Manhole Invert Level
6704	17.28	12.94
6702	18.23	12.53
6801	17.82	14.37
67YV	n/a	n/a
6703	17.13	15.12
781A	n/a	n/a
581C	n/a	n/a
571G	n/a	n/a
571C	n/a	n/a
571D	n/a	n/a
571E	n/a	n/a
57YQ	n/a	n/a
57XZ	n/a	n/a
5711	n/a	n/a
6705	17.81	14.93
6711	n/a	n/a
6804	19.54	n/a
681C	n/a	n/a
58WV	n/a	n/a
58XY	n/a	n/a
58XX	n/a	n/a
58XU	n/a	n/a
581A	n/a	n/a
681B	n/a	n/a
5806	19.77	19.35
581B	n/a	n/a
681D	n/a	n/a
5807	19.16	n/a
681A	n/a	n/a
5808	18.89	14.12

The position of the apparatus shown on this plan is given without obligation and warranty, and the accuracy cannot be guaranteed. Service pipes are not shown but their presence should be anticipated. No liability of any kind whatsoever is accepted by Thames Water for any error or omission. The actual position of mains and services must be verified and established on site before any works are undertaken.



ALS Sewer Map Key

Public Sewer Types (Operated & Maintained by Thames Water)

	Foul: A sewer designed to convey waste water from domestic and industrial sources to a treatment works.
	Surface Water: A sewer designed to convey surface water (e.g. rain water from roofs, yards and car parks) to rivers or watercourses.
	Combined: A sewer designed to convey both waste water and surface water from domestic and industrial sources to a treatment works.
	Trunk Surface Water
	Trunk Foul
	Trunk Combined
	Storm Relief
	Vent Pipe
	Proposed Thames Surface Water Sewer
	Gallery
	Surface Water Rising Main
	Sludge Rising Main
	Vacuum
	Foul Rising Main
	Combined Rising Main
	Proposed Thames Water Rising Main

Notes:

- 1) All levels associated with the plans are to Ordnance Datum Newlyn.
- 2) All measurements on the plans are metric.
- 3) Arrows (on gravity fed sewers) or flechs (on rising mains) indicate direction of flow.
- 4) Most private pipes are not shown on our plans, as in the past, this information has not been recorded.
- 5) 'na' or 'U' on a manhole level indicates that data is unavailable.

Sewer Fittings

A feature in a sewer that does not affect the flow in the pipe. Example: a vent is a fitting as the function of a vent is to release excess gas.

	Air Valve
	Dam Chase
	Fitting
	Meier
	Vent Column

Operational Controls

A feature in a sewer that changes or diverts the flow in the sewer. Example: A hydrobrake limits the flow passing downstream.

	Control Valve
	Drop Pipe
	Anchorage
	Weir

End Items

End symbols appear at the start or end of a sewer pipe. Examples: an Undefined End at the start of a sewer indicates that Thames Water has no knowledge of the position of the sewer upstream of that symbol, Outfall on a surface water sewer indicates that the pipe discharges into a stream or river.

	Outfall
	Undefined End
	Inlet

- 6) The text appearing alongside a sewer line indicates the internal diameter of the pipe in millimetres. Text next to a manhole indicates the manhole reference number and should not be taken as a measurement. If you are unsure about any text or symbology present on the plan, please contact a member of Property Searches on 0800 039 4540.

Other Symbols


Symbols used on maps which do not fall under other general categories: Public/Private Pumping Station

	Change of characteristic indicator (C.O.C.I.)
	Invert Level
	Summit
	Agreement
	Operational Site
	Chamber
	Tunnel
	Conduit Bridge

Other Sewer Types (Not Operated or Maintained by Thames Water)

	Foul Sewer
	Combined Sewer
	Culverted Watercourse
	Surface Water Sewer
	Gully
	Proposed
	Abandoned Sewer

Asset Location Search Water Map - ALS/ALS Standard/2021_4521701



The width of the displayed area is 200 m and the centre of the map is located at OS coordinates 533636, 184800.
 The position of the apparatus shown on this plan is given without obligation and warranty, and the accuracy cannot be guaranteed. Service pipes are not shown but their presence should be anticipated. No liability of any kind whatsoever is accepted by Thames Water for any error or omission. The actual position of mains and services must be verified and established on site before any works are undertaken.
 Based on the Ordnance Survey Map with the Sanction of the controller of H.M. Stationery Office, License no. 100019345 Crown Copyright Reserved.



ALS Water Map Key

Water Pipes (Operated & Maintained by Thames Water)

Distribution Main: The most common pipe shown on water maps. With few exceptions, domestic connections are only made to distribution mains.

Trunk Main: A main carrying water from a source of supply to a treatment plant or reservoir, or from one treatment plant or reservoir to another. Also a main transferring water in bulk to smaller water mains used for supplying individual customers.

Supply Main: A supply main indicates that the water main is used as a supply for a single property or group of properties.

Fire Main: Where a pipe is used as a fire supply, the word FIRE will be displayed along the pipe.

Metered Pipe: A metered main indicates that the pipe in question supplies water for a single property or group of properties and that quantity of water passing through the pipe is metered even though there may be no meter symbol shown.

Transmission Tunnel: A very large diameter water pipe. Most tunnels are buried very deep underground. These pipes are not expected to affect the structural integrity of buildings shown on the map provided.

Proposed Main: A main that is still in the planning stages or in the process of being laid. More details of the proposed main and its reference number are generally included near the main.

PIPE DIAMETER	DEPTH BELOW GROUND
Up to 300mm (12")	900mm (3')
300mm - 600mm (12" - 24")	1100mm (3' 8")
600mm and bigger (24" plus)	1200mm (4')

Valves

- General Purpose Valve
- Air Valve
- Pressure Control Valve
- Customer Valve

Hydrants

- Single Hydrant

Meters

- Meter

End Items

Symbol indicating what happens at the end of a water main.

- Blank Flange
- Capped End
- Emptying Pit
- Undefined End
- Manifold
- Customer Supply
- Fire Supply

Operational Sites

- Booster Station
- Other
- Other (Proposed)
- Pumping Station
- Service Reservoir
- Shaft Inspection
- Treatment Works
- Unknown
- Water Tower

Other Symbols

- Data Logger

Other Water Pipes (Not Operated or Maintained by Thames Water)

Other Water Company Main: Occasionally other water company water pipes may overlap the border of our clean water coverage area. These mains are denoted in purple and in most cases have the owner of the pipe displayed along them.

Private Main: Indicates that the water main in question is not owned by Thames Water. These mains normally have text associated with them indicating the diameter and owner of the pipe.

Terms and Conditions

All sales are made in accordance with Thames Water Utilities Limited (TWUL) standard terms and conditions unless previously agreed in writing.

1. All goods remain in the property of Thames Water Utilities Ltd until full payment is received.
2. Provision of service will be in accordance with all legal requirements and published TWUL policies.
3. All invoices are strictly due for payment 14 days from due date of the invoice. Any other terms must be accepted/agreed in writing prior to provision of goods or service, or will be held to be invalid.
4. Thames Water does not accept post-dated cheques-any cheques received will be processed for payment on date of receipt.
5. In case of dispute TWUL`s terms and conditions shall apply.
6. Penalty interest may be invoked by TWUL in the event of unjustifiable payment delay. Interest charges will be in line with UK Statute Law 'The Late Payment of Commercial Debts (Interest) Act 1998'.
7. Interest will be charged in line with current Court Interest Charges, if legal action is taken.
8. A charge may be made at the discretion of the company for increased administration costs.

A copy of Thames Water's standard terms and conditions are available from the Commercial Billing Team (cashoperations@thameswater.co.uk).

We publish several Codes of Practice including a guaranteed standards scheme. You can obtain copies of these leaflets by calling us on 0800 316 9800

If you are unhappy with our service you can speak to your original goods or customer service provider. If you are not satisfied with the response, your complaint will be reviewed by the Customer Services Director. You can write to her at: Thames Water Utilities Ltd, PO Box 492, Swindon, SN38 8TU.

If the Goods or Services covered by this invoice falls under the regulation of the 1991 Water Industry Act, and you remain dissatisfied you can refer your complaint to Consumer Council for Water on 0121 345 1000 or write to them at Consumer Council for Water, 1st Floor, Victoria Square House, Victoria Square, Birmingham, B2 4AJ.

Ways to pay your bill

Credit Card	BACS Payment	Telephone Banking	Cheque
Call 0800 009 4540 quoting your invoice number starting CBA or ADS / OSS	Account number 90478703 Sort code 60-00-01 A remittance advice must be sent to: Thames Water Utilities Ltd., PO Box 3189, Slough SL1 4WW. or email ps.billing@thameswater.co.uk	By calling your bank and quoting: Account number 90478703 Sort code 60-00-01 and your invoice number	Made payable to ' Thames Water Utilities Ltd ' Write your Thames Water account number on the back. Send to: Thames Water Utilities Ltd., PO Box 3189, Slough SL1 4WW or by DX to 151280 Slough 13

Thames Water Utilities Ltd Registered in England & Wales No. 2366661 Registered Office Clearwater Court, Vastern Rd, Reading, Berks, RG1 8DB.

Our Ref: 23548644 Your Ref: NOC/CTWSV456

Wednesday, 13 October 2021

Brian McMaster
1 Mill Place Mill Road Ind Est Linlithgow Bridge
Linlithgow
West Lothian
EH49 7TL

Dear Brian McMaster

Thank you for contacting us regarding UK Power Networks equipment at the above site. I have enclosed a copy of our records which show the electrical lines and/or electrical plant. I hope you find the information useful.

I have also enclosed a fact sheet which contains important information regarding the use of our plans and working around our equipment. Safety around our equipment is our number one priority so please ensure you have completed all workplace risk assessments before you begin any works.

Should your excavation affect our Extra High Voltage equipment (6.6 KV, 22 KV, 33 KV or 132 KV), please contact us to obtain a copy of the primary route drawings and associated cross sections.

If you have any further queries do not hesitate to contact us.

Plan Provision
0800 056 5866



This information is made available to you on the terms set out below. If you do not accept the terms of use set out in this fact sheet please do not use the plans and return them to UK Power Networks.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
2. UK Power Networks does not exclude or limit its liability if it causes the death of any person or causes personal injury to a person where such death or personal injury is caused by its negligence.
3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise how for any loss, damage, costs, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss or damage whatsoever.
4. The information about UK Power Networks electrical plant and/or electric lines provided to you belongs to and remains the property of UK Power Networks. You must not alter it in any respect.
5. The information provided to you about the electrical plant and/or electric lines depicted on the plans may NOT be a complete record of such apparatus belonging to UK Power Networks. The information provided relates to electric lines and/or electrical plant belonging to UK Power Networks that it believes to be present but the plans are not definitive: other electric lines and/or electrical plant may be present and that may or may not belong to UK Power Networks.
6. Other apparatus not belonging to UK Power Networks is not shown on the plan. It is your responsibility to make your own enquiries elsewhere to discover whether apparatus belonging to others is present. It would be prudent to assume that other apparatus is present.
7. You are responsible for ensuring that the information made available to you is passed to those acting on your behalf and that all such persons are made aware of the contents of this letter.
8. Because the information provided to you may not be accurate, you are recommended to ascertain the presence of UK Power Networks electric lines and/or electrical plant by the digging of trial holes. Trial holes should be dug by hand only.

Excavations must be carried out in line with the Health and Safety Executive guidance document HSG 47. We will not undertake this work. A copy of HSG 47 can be obtained from the Health and Safety Executives website.

All electric lines discovered must be considered LIVE and DANGEROUS at all times and must not be cut, resited, suspended, bent or interfered with unless specially authorised by UK Power Networks.

The electric line and electrical plant belonging to UK Power Networks remains so even when made dead and abandoned and any such electric line and/or electrical plant exposed shall be reported to UK Power Networks.

Where your works are likely to affect our electric lines and/or electrical plant an estimate of the price of any protective /diversionary works can be prepared by UK Power Networks Branch at Metropolitan House, Darkes Lane, Potters Bar, Herts. , EN6 1AG, telephone no. 0845 2340040




- 9 Any work near to any overhead electricity lines must be carried out by you in accordance with the Health and Safety Executive guidance document GS6 and the Electricity at Work Regulations.

The GS6 Recommendations may be purchased from HSE Books or downloaded from the Energy Networks Association's website.

If given a reasonable period of prior notice UK Power Networks will attend on site without charge to advise how and where "goal posts" should be erected. If you wish to use this service, in the first instance please telephone: 0845 6014516 between 08:30 and 17:00 Monday to Friday.

10. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.
11. If in carrying out work on land in, on, under or over which is installed an electric line and/or electrical plant that belongs to UK Power Networks you and/or anyone working on your behalf damages (however slightly) that apparatus you must inform immediately UK Power Networks by our emergency 24 hour three digit telephone number **105** providing;
- your name, address and telephone number;
 - the date, time and place at which such damage was caused;
 - a description of the electric line and/or electrical plant to which damage was caused;
 - the name of the person whom it appears to you is responsible for that damage;
 - the nature of the damage.
12. The expression "UK Power Networks" includes UK Power Networks (EPN) plc, UK Power Networks (LPN) plc, UK Power Networks (SEPN) plc, UK Power Networks and any of their successors and predecessors in title.





UK Power Networks

IF IN DOUBT - ASK!
 PHONE 0800 056 5866
 EMERGENCY - If you
 damage a cable, call the
 damage avoidance team
 (24hrs) URGENTLY

**ALWAYS LOOK UP
 BEFORE
 YOU START WORK**
 Refer to HSE
 Guidance note GS6

Map produced at 1:2500 scale are Geo-Schematics which show LV mains cables and
 overhead lines (in some cases all voltages). Prior to carrying out excavations you must
 refer to the 1:2500 records to determine the location of all known underground plant
 and equipment.

The quality and accuracy of any print will depend on your printer, your computer and its print settings. Measurements scaled from this plan may not match measurements between the same points on the ground.


1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person,
 or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using
 the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss
 of opportunity, loss of savings, loss of goodwill, loss of business, loss of use of any special or consequential loss or damage whatsoever.
 3. This plan has been provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do
 not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the
 sender of the letter.
 4. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a
 fee to a third party.

- Dig Sites Area:** - - - - - Line: - - - - -
- The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 - The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 - It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables have been determined.
 - It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
 - All cables must be treated as being live unless proved otherwise by UK Power Networks.
 - The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than for the purposes stated.
 - Please be aware that electric cables/fines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

This plan must be used with the attached 'Symbols' document.

Data Requested: 131102021
 Job Reference: 23548644
 Site Location: S33401 184630
 Requested by:
 Mr Brian McJagger
 Your Scheme/Reference:
 NOC/OTWS/VA58
 Scale: 1:1538 (When Plotted at A3)

Reproduced by permission of Ordnance Survey on behalf of HMSO. © Crown copyright and database rights 2020. All rights reserved. Ordnance Survey Licence numbers 100019626, 100019826 and 100019450. Data has been added to the Ordnance Survey base map; all proprietary rights in such additional data are and shall remain the exclusive property of © London Power Networks plc or Eastern Power Networks plc or South Eastern Power Networks plc each being a distribution licensee under section 6(1)(c) of the Electricity Act 1989 for the relevant distribution services area as that term is defined in such licensee's distribution licence. All rights in such data reserved.
 Plans generated by DigsAFE Pro™ software provided by LinesearchbeforeUdig.



UK Power Networks

ALWAYS LOOK UP BEFORE YOU START WORK
Refer to HSE Guidance note GS6

IF IN DOUBT - ASK!
PHONE 0800 056 5866
EMERGENCY - If you damage a cable or the line (24hrs) URGENTLY

Map produced at 1:500 scale are Geo-Schematics which show LV mains cables and overhead lines (in some cases all voltages). Prior to carrying out excavations you must refer to the 1:500 records to determine the location of all known underground plant and equipment.

The quality and accuracy of any print will depend on your printer, your computer and its print settings. Measurements scaled from this plan may not match measurements between the same points on the ground.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person, or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of statutory duty or the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use of any special or consequential loss or damage whatsoever.
3. This plan has been provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
4. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.


1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables have been determined.
4. It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 10 years old for any purposes other than those stated on the drawings.
7. Please be aware that electric cables/lines belong to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

This plan must be used with the attached 'Symbols' document.

Date Requested: 13/10/2021
Job Reference: 23548644
Site Location: 532401 184630
Requested by:
Mr Brian McIlwain
Your Scheme/Reference:
NOO/CTWS/V458

Scale: 1:500 (When plotted at A3)

Reproduced by permission of Ordnance Survey on behalf of HMSO. © Crown copyright and database rights 2020. All rights reserved. Ordnance Survey Licence numbers 100019626, 100019450. Data has been added to the Ordnance Survey base map; all proprietary rights in such additional data are and shall remain the exclusive property of © London Power Networks plc or Eastern Power Networks plc each being a distribution licensee under section 51(1)(c) of the Electricity Act 1989 for the relevant distribution services area as that term is defined in such licensee's distribution licence. All rights in such data reserved.
Plans generated by DigsAFE Pro™ software provided by LinesearchbeforeUdig.



UK Power Networks

IF IN DOUBT - ASK! PHONE 0800 056 5866 EMERGENCY - If you damage a power line call 999 (24hrs) URGENTLY

ALWAYS LOOK UP BEFORE YOU START WORK
Refer to HSE Guidance note GS6

Map produced at 1:500 scale are Geo-Schematics which show LV mains cables and overhead lines (in some cases all voltages). Prior to carrying out excavations you must refer to the 1:500 records to determine the location of all known underground plant and equipment.

The quality and accuracy of any print will depend on your printer, your computer and its print settings. Measurements scaled from this plan may not match measurements between the same points on the ground.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person, or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss or damage whatsoever.
 4. This plan has been provided to you on the basis of the terms of the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables have been determined.
 4. It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 10 years old.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.


Dig Sites Area: --- Line: ---

0 25 50 metres

This plan must be used with the attached 'Symbols' document.

Date Requested: 13/10/2021
 Job Reference: 23548644
 Site Location: 533401 184630
 Requested by: Mr Brian McIlwain
 Your Scheme/Reference: NOC/CTWS/V458
 Scale: 1:500 (When plotted at A3)

Reproduced by permission of Ordnance Survey on behalf of HMSO. © Crown copyright and database rights 2020. All rights reserved. Ordnance Survey Licence numbers 100019626, 100019826 and 100019450. Data has been added to the Ordnance Survey base map; all proprietary rights in such additional data are and shall remain the exclusive property of © London Power Networks plc or Eastern Power Networks plc each being a distribution licensee under section 61(1)(c) of the Electricity Act 1989 for the relevant distribution services area as that term is defined in such licensee's distribution licence. All rights in such data reserved.
 Plans generated by DigsAFE Pro™ software provided by LinesearchbeforeUdig.



UK Power Networks

IF IN DOUBT - ASK!
 PHONE 0800 056 5866
 EMERGENCY - If you
 damage a cable or see
 a fault call 999
 (24hrs) URGENTLY

ALWAYS LOOK UP
 BEFORE
 YOU START WORK
 Refer to HSE
 Guidance note G56

Map produced at 1:500 scale are Geo-Schematics which show LV mains cables and
 overhead lines (in some cases all voltages). Prior to carrying out excavations you must
 refer to the 1:500 records to determine the location of all known underground plant
 and equipment.

The quality and accuracy of any print will depend on your printer, your computer and its print settings. Measurements scaled from this plan may not match measurements between the same points on the ground.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person.
 3. Subject to paragraph 7 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use of any special or consequential loss or damage whatsoever.
 4. This plan has been provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept all or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.


Dig Sites Area: Line: Dig Sites Area: Line:

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables have been determined.
 4. It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 10 years old.
 7. Please be aware that electric cables/files belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

This plan must be used with the attached 'Symbols' document.

Data Requested: 131102021
 Job Reference: 23548644
 Site Location: S33401 184630
 Requested by: Mr Brian McIlwain
 Your Scheme/Reference: NOC/CWMS/VA58
 Scale: 1:500 (When plotted at A3)

Reproduced by permission of Ordnance Survey on behalf of HMSO. © Crown copyright and database rights 2020. All rights reserved. Ordnance Survey Licence numbers 100019626, 100019826 and 100019450. Data has been added to the Ordnance Survey base map; all proprietary rights in such additional data are and shall remain the exclusive property of © London Power Networks plc or Eastern Power Networks plc or South Eastern Power Networks plc each being a distribution licensee under section 6(1)(c) of the Electricity Act 1989 for the relevant distribution services area as that term is defined in such licensee's distribution licence. All rights in such data reserved.
 Plans generated by DigsAFE Pro™ software provided by LinesearchbeforeUdig.



UK Power Networks

ALWAYS LOOK UP BEFORE YOU START WORK
Refer to HSE Guidance note GS6

IF IN DOUBT - ASK!
PHONE 0800 056 5866
EMERGENCY - If you damage a cable call 999
Damage a cable call 0800 056 5866 (24hrs) URGENTLY

Map produced at 1:500 scale are Geo-Schematics which show LV mains cables and overhead lines (in some cases all voltages). Prior to carrying out excavations you must refer to the 1:500 records to determine the location of all known underground plant and equipment.

The quality and accuracy of any print will depend on your printer, your computer and its print settings. Measurements scaled from this plan may not match measurements between the same points on the ground.


1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person.
3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of goodwill, loss of business, loss of use of or any special or consequential loss or damage whatsoever).
4. This plan has been provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables have been determined.
4. It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 10 years old.
7. Please be aware that electric cables/fuses belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

This plan must be used with the attached 'Symbols' document.

Data Requested: 131/02021
Job Reference: 23548644
Site Location: 533401 184630
Requested by: Mr Brian McKeever
Your Scheme/Reference: NOC/CWMS/V458
Scale: 1:500 (When printed at A3)

Reproduced by permission of Ordnance Survey on behalf of HMSO. © Crown copyright and database rights 2020. All rights reserved. Ordnance Survey Licence numbers 100019626, 100019826 and 100019450. Data has been added to the Ordnance Survey base map; all proprietary rights in such additional data are and shall remain the exclusive property of © London Power Networks plc or Eastern Power Networks plc each being a distribution licensee under section 61(1)(c) of the Electricity Act 1989 for the relevant distribution services area as that term is defined in such licensee's distribution licence. All rights in such data reserved.
Plans generated by DigsAFE Pro™ software provided by LinesearchbeforeUdig.



UK Power Networks

IF IN DOUBT - ASK!
 PHONE 0800 056 5866
 EMERGENCY - If you
 damage a cable, call the
 number on the sign
 (24hrs) URGENTLY

**ALWAYS LOOK UP
 BEFORE
 YOU START WORK**
 Refer to HSE
 Guidance note GS6

Map produced at 1:500 scale as Geo-Chemicals which show LV mains cables and
 overhead lines (in some cases all voltages). Prior to carrying out excavations you must
 refer to the 1:500 records to determine the location of all known underground plant
 and equipment.

The quality and accuracy of any print will depend on your printer, your computer and its print settings. Measurements scaled from this plan may not match measurements between the same points on the ground.

Line: ——— **Dig Sites:** - - - - **Area:** - - - -


1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person, or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use of any special or consequential loss or damage whatsoever.
3. This plan has been provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
4. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

This plan must be used with the attached 'Symbols' document.

Date Requested: 13/10/2021
 Job Reference: 23548644
 Site Location: 532401 184630
 Requested by: Mr Brian McIlreath
 Your Scheme/Reference: NOC/OTWS/V458
 Scale: 1:500 (When plotted at A3)

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables have been determined.
4. It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 10 years old.
7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

Reproduced by permission of Ordnance Survey on behalf of HMSO. © Crown copyright and database rights 2020. All rights reserved. Ordnance Survey Licence numbers 100019626, 100019826 and 100019450. Data has been added to the Ordnance Survey base map; all proprietary rights in such additional data are and shall remain the exclusive property of © London Power Networks plc or Eastern Power Networks plc or South Eastern Power Networks plc each being a distribution licensee under section 61(1)(c) of the Electricity Act 1989 for the relevant distribution services area as that term is defined in such licensee's distribution licence. All rights in such data reserved.
 Plans generated by DigSAFE Pro™ software provided by LinesearchbeforeUdig.



UK Power Networks

IF IN DOUBT - ASK!
 PHONE 0800 054 5866
 EMERGENCY - If you
 damage a cable or cause
 damage to the network
 (24hrs) URGENTLY

**ALWAYS LOOK UP
 BEFORE
 YOU START WORK**
 Refer to HSE
 Guidance note GS6

Map produced at 1:500 scale are Geo-Schematics which show LV mains cables and
 overhead lines (in some cases all voltages). Prior to carrying out excavations you must
 refer to the 1:500 records to determine the location of all known underground plant
 and equipment.

The quality and accuracy of any print will depend on your printer, your computer and its print settings. Measurements scaled from this plan may not match measurements between the same points on the ground.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person,
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty
 or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using
 the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss
 of opportunity, loss of goodwill, loss of business, loss of use or any special or consequential loss or damage whatsoever.
 4. This plan has been provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do
 not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the
 sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a
 fee to a third party.

Dig Sites Area: --- Line: ---


1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables have been determined.
 4. It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 10 years old for any purpose other than the purposes stated on the drawings.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

This plan must be used with the attached 'Symbols' document.

Date Requested: 13/10/2021
 Job Reference: 23548644
 Site Location: S33401 184630
 Requested by:
 Mr Brian McJagger
 Your Scheme/Reference:
 NOC/CTWSV458
 Scale: 1:500 (When plotted at A3)

Reproduced by permission of Ordnance Survey on behalf of HMSO. © Crown copyright and database rights 2020. All rights reserved. Ordnance Survey Licence numbers 100019626, 100019826 and 100019450. Data has been added to the Ordnance Survey base map; all proprietary rights in such additional data are and shall remain the exclusive property of © London Power Networks plc or Eastern Power Networks plc each being a distribution licensee under section 61(1)(c) of the Electricity Act 1989 for the relevant distribution services area as that term is defined in such licensee's distribution licence. All rights in such data reserved.
 Plans generated by DigsAFE Pro™ software provided by LinesearchbeforeUdig.

Cross Section : 4431409



1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

Cross Section

1. UK Power Networks does not accept liability for information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not accept liability for its liability if it causes the death of any persons or causes personal injury.
 3. Subject to paragraph 2, UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss or damage whatsoever.
 4. This plan has been provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

IF IN DOUBT - ASK! PHONE
 0800 056 5866
EMERGENCY - If you damage a cable or line
 Phone 0800 783 8838 (24hrs)
URGENTLY




ALWAYS LOOK UP BEFORE YOU START WORK
 Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and are not to be used for excavation purposes. You must refer to the 1:500 records to determine the location of all known underground plant and equipment.

Cross Section : 4431410



1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

Cross Section

1. UK Power Networks does not accept liability for information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not accept liability for information provided to you is correct. You rely upon it at your own risk.
 3. Subject to paragraph 1, UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss or damage whatsoever.
 4. This plan has been provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

IF IN DOUBT - ASK! PHONE
 0800 056 5866
 EMERGENCY - If you damage a cable or line
 Phone 0800 783 8838 (24hrs)
 URGENTLY




ALWAYS LOOK UP BEFORE YOU START WORK
 Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and are not to be used for excavation purposes. Refer to the 1:500 records to determine the location of all known underground plant and equipment.

Cross Section : 6741580



Cross Section
6741580

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables have been determined.
 4. It must be assumed that there is a service cable unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damage whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.



IF IN DOUBT - ASK! PHONE
0800 0 56 5866
EMERGENCY - if you damage
a cable or line
Phone 0800 783 0628 (24-hrs)
URGENTLY



ALWAYS LOOK UP BEFORE
YOU START WORK!
Refer to HSE guidance note GS6



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and equipment. The 1:2500 scale maps are not intended to be used as a substitute for a 1:500 records to determine the location of all known underground plant and equipment.



**300x3 TRIPLEX
SPLIT INTO
SINGLE DUCTS**

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given up all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks does not warrant that the information provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 2. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.
 3. UK Power Networks does not warrant that the information provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 4. This plan has been provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.
 6. UK Power Networks does not warrant that the information provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 7. This plan has been provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.

1 - 240 3/c TO T/C 4009, TEE T/C 4269.
 2 - 240WY TO T/C 4269.

IF IN DOUBT - ASK! PHONE
 0800 056 5866
 EMERGENCY - If you damage
 a cable or line
 Phone 0800 783 8838 (24-hrs)
 URGENTLY




ALWAYS LOOK UP BEFORE
 YOU START WORK
 Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and
 to the 1:500 records to determine the location of all known underground plant and
 equipment.

Cross Section : 3615585



Cross Section
3615585

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables have been determined.
 4. It must be assumed that there is a service cable in any trench unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damage whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.


IF IN DOUBT - ASK! PHONE
0800 0 56 5866
EMERGENCY - if you damage
a cable or line
Phone 0800 783 9828 (24-hrs)
URGENTLY



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and
 to the 1:500 records to determine the location of all known underground plant and
 equipment.

ALWAYS LOOK UP BEFORE
YOU START WORK
Refer to HSE guidance note GS6

Cross Section : 3637020



Cross Section
3637020

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable in every trench unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any person or causes personal injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damages whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

IF IN DOUBT - ASK! PHONE
0800 056 5866
EMERGENCY - if you damage
a cable or line
Phone 0800 783 8838 (24hrs)
URGENTLY




ALWAYS LOOK UP BEFORE
YOU START WORK
Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and other underground infrastructure. They do not show all underground plant and equipment. Refer to the 1:500 records to determine the location of all known underground plant and equipment.

Cross Section : 3637021



1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

Cross Section
 1. UK Power Networks does not warrant the information provided in this document.
 2. UK Power Networks does not exclude or limit its liability in the event of death of any persons or causes personal injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability in any contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damage whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

IF IN DOUBT - ASK! PHONE 0800 056 5866
 EMERGENCY - If you damage a cable or line PHONE 0800 783 8838 (24hrs) URGENTLY

ALWAYS LOOK UP BEFORE YOU START WORK
 Refer to HSE Guidance note G56

Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and are not to be used for excavation purposes. To determine the location of all known underground plant and equipment.

Cross Section 2782641



1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proven otherwise.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damages whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

IF IN DOUBT - ASK! PHONE
 0800 056 5866
EMERGENCY - If you damage a cable or line URGENTLY
 Phone 0800 783 8838 (24hrs)




ALWAYS LOOK UP BEFORE YOU START WORK
 Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and equipment. The maps are not intended to be used as a substitute for a site visit. Refer to the 1:500 records to determine the location of all known underground plant and equipment.

Cross Section : 2045247



1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given up all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

Cross Section

1. UK Power Networks Ltd does not warrant that the information provided to you is correct. You rely upon that information at your own risk.
 2. UK Power Networks Ltd does not exclude or limit its liability if it causes the death of any persons or other loss or injury to a person.
 3. Subject to paragraph 2, UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss or damage whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.


IF IN DOUBT - ASK! PHONE
 0800 056 5866
EMERGENCY - If you damage a cable or line UKRGENTLY
 Phone 0800 783 8838 (24hrs)



ALWAYS LOOK UP BEFORE YOU START WORK
 Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and equipment. Refer to the 1:500 records to determine the location of all known underground plant and equipment.



ASSUMED SECTION

Cross Section
2018836

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable in each property, lamp column and street sign, etc.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damage whatsoever.
 4. This plan has been provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.


IF IN DOUBT - ASK! PHONE
0800 056 5866
EMERGENCY - If you damage a cable or line
Phone 0800 783 8838 (24hrs)
URGENTLY!



ALWAYS LOOK UP BEFORE YOU START WORK
Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and to the 1:500 records to determine the location of all known underground plant and equipment.



Cross Section

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks warrants that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damages whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.


IF IN DOUBT - ASK! PHONE
 0800 056 5866
EMERGENCY - If you damage a cable or line UKRGENTLY
 Phone 0800 783 8838 (24hrs)



ALWAYS LOOK UP BEFORE YOU START WORK
 Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and other underground infrastructure. They do not show all underground plant and equipment. Refer to the 1:500 records to determine the location of all known underground plant and equipment.



Cross Section

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon that your own risk.
 2. UK Power Networks has no liability if it causes the death of any persons or other persons or the injury of any person.
 3. Subject to paragraph 2, UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss or damage whatsoever.
 4. This plan has been provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.


IF IN DOUBT - ASK! PHONE
 0800 056 5866
 EMERGENCY - If you damage
 a cable or line
 Phone 0800 783 8638 (24hrs)
 URGENTLY



ALWAYS LOOK UP BEFORE
 YOU START WORK
 Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and
 to the 1:500 records to determine the location of all known underground plant and
 equipment.



Cross Section

1. The position of the apparatus shown on this drawing is believed to be correct but the original drawings (you refer to) may be altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

UK Power Networks does not warrant that the information provided to you is correct (you refer to) or that it is correct upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damage whatsoever.
 4. This plan has been provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

IF IN DOUBT - ASK! PHONE
 0800 056 5866
 EMERGENCY - If you damage a cable or line
 Phone 0800 783 8638 (24hrs)
 URGENTLY




ALWAYS LOOK UP BEFORE YOU START WORK
 Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and are not to be used for excavation purposes. You must refer to the 1:500 records to determine the location of all known underground plant and equipment.

Cross Section : 3465294



0.3 4c
(UNKNOWN POSITION)

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables have been determined.
 4. It must be assumed that there is a service cable unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

Cross Section

1. UK Power Networks Ltd. warrants that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks Ltd. shall not be liable to any person, persons or companies, for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss or damage whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.


IF IN DOUBT - ASK! PHONE
0800 056 5866
EMERGENCY - If you damage
a cable or line
Phone 0800 783 8638 (24hrs)
UNKNOWNLY



ALWAYS LOOK UP BEFORE
YOU START WORK!
Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and are not to be used for excavation purposes. You must refer to the 1:500 records to determine the location of all known underground plant and equipment.



0.1 3c D 0.3
 0.3 A1 4c D 0.4
 (UNKNOWN POSITION)

Gross Section

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proven otherwise by UK Power Networks.
 6. The information provided must be given up all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. You rely upon the accuracy of the information provided to you is correct.
 2. UK Power Networks does not accept any liability for the death of any person or for any personal injury to a person.
 3. Subject to the above, UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damage whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

IF IN DOUBT - ASK! PHONE
 0800 056 5866
 EMERGENCY - If you damage a cable or line
 Phone 0800 783 8638 (24hrs)
 URGENTLY




ALWAYS LOOK UP BEFORE YOU START WORK
 Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and other underground infrastructure. To determine the location of all known underground plant and equipment.

Cross Section : 2032433



1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

Cross Section

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon that at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or other personal injury to a person.
 3. Subject to the limitation of liability in UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss or damage whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

IF IN DOUBT - ASK! PHONE
 0800 056 5866
 EMERGENCY - If you damage
 a cable or line
 Phone 0800 783 8838 (24-hrs)
 URGENTLY




ALWAYS LOOK UP BEFORE
 YOU START WORK
 Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and are not intended to be used as a substitute for a site visit. You must refer to the 1:500 records to determine the location of all known underground plant and equipment.

Cross Section : 2735617



Cross Section
2735617

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damage whatsoever.
 4. This plan has been provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.


IF IN DOUBT - ASK! PHONE
0800 056 5866
EMERGENCY - If you damage
a cable or line
Phone 0800 783 8838 (24hrs)
URGENTLY



ALWAYS LOOK UP BEFORE
YOU START WORK
Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and wires. They are not intended to be used as a substitute for a site visit. For more information refer to the 1:500 records to determine the location of all known underground plant and equipment.



0.0225 3c
(UNKNOWN POSITION)
Cross Section
3465292

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damages whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

IF IN DOUBT - ASK! PHONE
0800 056 5866
EMERGENCY - If you damage
a cable or line
Phone 0800 783 8638 (24hrs)
URGENTLY




ALWAYS LOOK UP BEFORE
YOU START WORK
Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and equipment. Refer to the 1:500 records to determine the location of all known underground plant and equipment.

Cross Section : 3465290

2.2



0.1 3c D 0.3
0.3 A1 4c D 0.4
(UNKNOWN POSITION)

Gross Section


1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables have been determined.
 4. It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given up all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. You rely upon it at your own risk.
 2. UK Power Networks does not intend to exclude or limit its liability if it causes the death of any person or serious personal injury to a person.
 3. Subject to clause 2, UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damage whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

IF IN DOUBT - ASK! PHONE 0800 056 5866
 EMERGENCY - If you damage a cable or line PHONE 0800 783 8638 (24-hrs)
 URGENTLY

ALWAYS LOOK UP BEFORE YOU START WORK
 Refer to HSE Guidance note G56

Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and other underground infrastructure. You must refer to the 1:500 records to determine the location of all known underground plant and equipment.



Cross Section
2018838

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable in being live unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss or damage whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.


IF IN DOUBT - ASK! PHONE
0800 056 5866
EMERGENCY - If you damage a cable or line
PHONE 0800 783 8838 (24hrs)
URGENTLY



ALWAYS LOOK UP BEFORE YOU START WORK
Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and are not intended to be used as a substitute for a site visit. You must refer to the 1:500 records to determine the location of all known underground plant and equipment.



ASSUMED SECTION

Cross Section

2018837

1. The position of the apparatus shown on this drawing is believed to be correct but the original landowner may have been altered since the drawing is believed to be correct but the original landowner may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damages whatsoever.
 4. This plan has been provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.


IF IN DOUBT - ASK! PHONE 0800 056 5866
 EMERGENCY - If you damage a cable or line URGENTLY Phone 0800 783 8838 (24hrs)



ALWAYS LOOK UP BEFORE YOU START WORK
 Refer to HSE Guidance note GS6



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and equipment. For more information on how to refer to the 1:500 records to determine the location of all known underground plant and equipment.



Cross Section
2769721

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables have been determined.
 4. It must be assumed that there is a service cable in any trench unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability, if it causes the death of any persons or causes personal injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damage whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.


IF IN DOUBT - ASK! PHONE
0800 0 56 5866
EMERGENCY - if you damage
a cable or line
Phone 0800 783 0628 (24-hrs)
URGENTLY



ALWAYS LOOK UP BEFORE
YOU START WORK!
Refer to HSE guidance note GS6



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and equipment. To determine the location of all known underground plant and equipment, refer to the 1:500 records to determine the location of all known underground plant and equipment.



2x 300 MV

2x 125 PRO

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

Cross Section

1. You rely upon the accuracy of the information provided to you is correct.
 2. UK Power Networks does not accept liability for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damages whatsoever.
 4. This plan has been provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.


IF IN DOUBT - ASK! PHONE
 0800 056 5866
 EMERGENCY - If you damage a cable or line
 Phone 0800 783 8838 (24hrs)
 URGENTLY



ALWAYS LOOK UP BEFORE YOU START WORK
 Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and are not to be used for excavation purposes. For excavation purposes refer to the 1:500 records to determine the location of all known underground plant and equipment.



Cross Section

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given up all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damages whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.


IF IN DOUBT - ASK! PHONE
 0800 056 5866
 EMERGENCY - If you damage a cable or line
 Phone 0800 783 8838 (24hrs)
 URGENTLY



ALWAYS LOOK UP BEFORE YOU START WORK
 Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and are not to be used for excavation purposes. For more information please refer to the 1:500 records to determine the location of all known underground plant and equipment.



Cross Section 2015771

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable in every trench unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss or damage whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

IF IN DOUBT - ASK! PHONE
0800 056 5866
EMERGENCY - If you damage
a cable or line
PHONE 0800 783 8838 (24hrs)
URGENTLY




ALWAYS LOOK UP BEFORE
YOU START WORK
Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and are not to be used for excavation purposes. You must refer to the 1:500 records to determine the location of all known underground plant and equipment.

Cross Section : 3465295



Cross Section

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon the information provided to you at your own risk.
 2. UK Power Networks does not accept liability for any injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damage whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

IF IN DOUBT - ASK! PHONE
 0800 056 5866
 EMERGENCY - If you damage
 a cable or line
 Phone 0800 783 8838 (24hrs)
 UKRENTLY




Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and
 where they cross the ground surface. They do not show the exact location of
 to the 1:500 records to determine the location of all known underground plant and
 equipment.



ALWAYS LOOK UP BEFORE
 YOU START WORK!
 Refer to HSE Guidance note G56

Cross Section : 3465296



Cross Section

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon the information provided to you at your own risk.
 2. UK Power Networks does not accept liability for any injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damages whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.


IF IN DOUBT - ASK! PHONE
 0800 056 5866
EMERGENCY - If you damage a cable or line
 Phone 0800 783 8838 (24hrs)
 UKRENTLY



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and are not to be used for excavation purposes. You must refer to the 1:500 records to determine the location of all known underground plant and equipment.



ALWAYS LOOK UP BEFORE YOU START WORK
 Refer to HSE Guidance note G56



240 3c
T/C 4110
TO
TC 4607

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

Cross Section

UK Power Networks warrant that the information provided to you is correct. You rely upon it at your own risk.
 UK Power Networks do not exclude or limit its liability if it causes the death of any person, or injury to a person, or damage to property, or any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damage whatsoever, provided that you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

IF IN DOUBT - ASK! PHONE
0800 056 5866
EMERGENCY - If you damage a cable or line
Phone 0800 783 8638 (24hrs)
URGENTLY




ALWAYS LOOK UP BEFORE YOU START WORK
Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and equipment. The 1:500 records to determine the location of all known underground plant and equipment.

Cross Section : 2786958



Cross Section 2786958

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables have been determined.
 4. It must be assumed that there is a service cable unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damage whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

IF IN DOUBT - ASK! PHONE
 0800 0 56 5866
 EMERGENCY - if you damage
 a cable or line
 Phone 0800 783 9828 (24-hrs)
 URGENTLY




ALWAYS LOOK UP BEFORE
 YOU START WORK!
 Refer to HSE guidance note GS6




Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and equipment. To determine the location of LV mains cables and equipment refer to the 1:500 records to determine the location of all known underground plant and equipment.



2x 300 WW



300 TRIPLEX



300 TRIPLEX
TO SERVICES T/C

Cross Section 2002397

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damage whatsoever.
 4. This plan has been provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.


IF IN DOUBT - ASK! PHONE
0800 056 5866
EMERGENCY - If you damage
a cable or line
Phone 0800 783 8838 (24hrs)
URGENTLY



ALWAYS LOOK UP BEFORE
YOU START WORK
Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and
 LV cables in the ground. They do not show underground plant and
 equipment.
 To the 1:500 records to determine the location of all known underground plant and
 equipment.



185 WV

3x 300 WV

4x 125 PRD

Cross Section 2769721

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable in each property, lamp column and street sign, etc.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damage whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.


IF IN DOUBT - ASK! PHONE
0800 056 5866
EMERGENCY - If you damage
a cable or line
Phone 0800 783 8638 (24hrs)
URGENTLY



ALWAYS LOOK UP BEFORE
YOU START WORK
Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and wires. They are not intended to be used as a substitute for a site visit. To refer to the 1:500 records to determine the location of all known underground plant and equipment.



Gross Section

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables have been determined.
 4. It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given up all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

UK Power Networks is not liable for any information that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any person or significant personal injury to a person.
 3. Subject to paragraph 2, UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damage whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.


IF IN DOUBT - ASK! PHONE
 0800 056 5866
 EMERGENCY - If you damage a cable or line
 Phone 0800 783 8838 (24hrs)
 UKRENTLY



ALWAYS LOOK UP BEFORE YOU START WORK
 Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and other underground infrastructure. They do not show all underground plant and equipment. Refer to the 1:500 records to determine the location of all known underground plant and equipment.



**.3 4c
ASSUMED
POSITION**

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given up all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

Cross Section

1. UK Power Networks shall not be liable for the information provided to you is correct. You rely upon that information at your own risk.
 2. UK Power Networks shall not be liable or limit its liability if it causes the death of any persons or other person in any person.
 3. Subject to paragraph 2, UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss or damage whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

IF IN DOUBT - ASK! PHONE
 0800 056 5866
EMERGENCY - If you damage a cable or line
 Phone 0800 783 8838 (24hrs)
URGENTLY




ALWAYS LOOK UP BEFORE YOU START WORK
 Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and are not to be used for excavation purposes. You must refer to the 1:500 records to determine the location of all known underground plant and equipment.

Cross Section : 1122876



300WV

2 X PRD'S

Cross Section

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given up all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks are not responsible for any information that the information provided to you is correct. You rely upon that information at your own risk.
 2. UK Power Networks do not intend to provide or limit its liability if it causes the death of any persons or causes personal injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss or damage whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

IF IN DOUBT - ASK! PHONE
 0800 056 5866
 EMERGENCY - If you damage
 a cable or line
 Phone 0800 783 8838 (24-hrs)
 URGENTLY




ALWAYS LOOK UP BEFORE
 YOU START WORK
 Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and are not intended to be used for excavation purposes. For further information refer to the 1:500 records to determine the location of all known underground plant and equipment.

Cross Section : 1122871



Cross Section

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks shall not be liable for the death of any persons or claims for personal injury to a person.
 3. Subject to paragraph 2, UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damages whatsoever.
 4. This plan has been provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

IF IN DOUBT - ASK! PHONE
 0800 056 5866
 EMERGENCY - If you damage
 a cable or line
 Phone 0800 783 8638 (24-hrs)
 URGENTLY




ALWAYS LOOK UP BEFORE
 YOU START WORK
 Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and
 are not intended to be used for excavation purposes. For more information refer
 to the 1:500 records to determine the location of all known underground plant and
 equipment.

Cross Section : 1122870



Cross Section

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

UK Power Networks Ltd warrants that the information provided to you is correct. You rely upon it at your own risk and we do not include or limit its liability if it causes the death of any persons or causes personal injury to a person.
 2. UK Power Networks Ltd warrants that the information provided to you is correct. You rely upon it at your own risk and we do not include or limit its liability if it causes the death of any persons or causes personal injury to a person.
 3. Subject to the terms and conditions of the licence, UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damage whatsoever.
 4. This plan has been provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.


IF IN DOUBT - ASK! PHONE 0800 056 5866
 EMERGENCY - If you damage a cable or line UKRGENTLY Phone 0800 783 8638 (24hrs)



ALWAYS LOOK UP BEFORE YOU START WORK
 Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and other underground infrastructure. They do not show all underground plant and equipment.



1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

Cross Section

1. UK Power Networks Ltd does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks Ltd does not provide or limit its liability if it causes the death of any persons or causes personal injury to any person.
 3. Subject to paragraph 2, UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damages whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.


IF IN DOUBT - ASK! PHONE
 0800 056 5866
EMERGENCY - If you damage a cable or line UKWENTLY
 Phone 0800 783 8838 (24hrs)



ALWAYS LOOK UP BEFORE YOU START WORK
 Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and are not intended to be used as a substitute for a 1:500 records to determine the location of all known underground plant and equipment.



Cross Section
1122874

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable unless proved otherwise by UK Power Networks.
 5. All cables must be treated as being live unless proven otherwise by UK Power Networks.
 6. The information provided must be given up all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

1. UK Power Networks does not warrant that the information provided to you is correct. You rely upon it at your own risk.
 2. UK Power Networks does not exclude or limit its liability if it causes the death of any persons or causes personal injury to a person.
 3. Subject to paragraph 2 UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damages whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

IF IN DOUBT - ASK! PHONE
0800 056 5866
EMERGENCY - If you damage
a cable or line
Phone 0800 783 8838 (24hrs)
URGENTLY



ALWAYS LOOK UP BEFORE
YOU START WORK
Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and other underground infrastructure. They do not show all underground plant and equipment. Refer to the 1:500 records to determine the location of all known underground plant and equipment.



300 MW



2 x 300 kW
TRIPLEX
11 kV

1. The position of the apparatus shown on this drawing is believed to be correct but the original landmarks may have been altered since the apparatus was installed.
 2. The exact position of the apparatus should be verified - use approved cable avoidance tools prior to excavation using suitable hand tools.
 3. It is essential that trial holes are carefully made avoiding the use of mechanical tools or picks until the exact location of all the cables has been determined.
 4. It must be assumed that there is a service cable into each property, lamp column and street sign, etc.
 5. All cables must be treated as being live unless proved otherwise by UK Power Networks.
 6. The information provided must be given to all people working near UK Power Networks plant and equipment. Do not use plans more than 3 months after the issue date for excavation purposes.
 7. Please be aware that electric cables/lines belonging to other owners of licensed electricity distribution systems may be present and it is your responsibility to identify their location.

Cross Section

You rely upon the accuracy of the information provided to you is correct.
 1. UK Power Networks does not warrant that the information provided to you is correct.
 2. UK Power Networks does not warrant that the information provided to you is correct.
 3. Subject to paragraph 1, UK Power Networks has no liability to you in contract, in tort (including negligence), for breach of statutory duty or otherwise for any loss, damage, cost, claims, demands, or expenses that you or any third party may suffer or incur as a result of using the information provided whether for physical damage to property or for any economic loss (including without limitation loss of profit, loss of opportunity, loss of savings, loss of goodwill, loss of business, loss of use) or any special or consequential loss of damage whatsoever, provided to you on the basis of the terms of use set out in the covering letter that accompanies this plan. If you do not accept and/or do not understand the terms of use set out in the covering letter you must not use the plan and must return it to the sender of the letter.
 5. You are responsible for the security of the information provided to you. It must not be given, sold or made available upon payment of a fee to a third party.

IF IN DOUBT - ASK! PHONE
0800 056 5866
EMERGENCY - If you damage
a cable or line
Phone 0800 783 8838 (24-hrs)
URGENTLY



ALWAYS LOOK UP BEFORE
YOU START WORK
Refer to HSE Guidance note G56



Maps produced at 1:2500 scale are geo-schematics which show LV mains cables and
 wires in the ground. They are not intended to be used as a substitute for a
 to the 1:500 records to determine the location of all known underground plant and
 equipment.

UK Power Networks Feedback Tool

Please help UK Power Networks improve the accuracy of their network records and help make it safer for all those working around them in future.




All you need to do is:

1. Use your phone camera to scan the QR code:
2. Provide feedback on what you have found on site (good or bad)
3. Upload a photo if needed


Thank you for making the area a safer place to dig.

UK Power Networks, working with LSBUD



(c) Crown copyright and database rights 2021 Ordnance Survey 100019209
 Data updated: 01/10/21

Scale: 1:500 Date: 13/10/21 Telecoms Plan A3
 Map Centre: 533635,184806 Our Ref: 673461 - 1 Powered by digdat



brian.mcmaster@national-one-call.co.uk
NOC/CTWSV456



Important Information - please read The purpose of this plan is to identify Virgin Media apparatus. We have tried to make it as accurate as possible but we cannot warrant its accuracy. In addition, we caution that within Virgin Media apparatus there may be instances where mains voltage power cables have been placed inside green, rather than black ducting. Further details can be found using the "Affected Postcodes.pdf", which can be downloaded from this website. Therefore, you must not rely solely on this plan if you are carrying out any excavation or other works in the vicinity of Virgin Media apparatus. The actual position of any underground service must be verified by cable detection equipment, etc, and established on site before any mechanical plant is used. Accordingly, unless it is due to the negligence of Virgin Media, its employees or agents, Virgin Media will not have any liability for any omissions or inaccuracies in the plan or for any loss or damage caused or arising from the use of and/or any reliance on this plan. This plan is produced by Virgin Media Limited (c) Crown copyright and database rights 2021 Ordnance Survey 100019209.

[REDACTED]
PlanToDig
1 Mill Place Mill Road Ind Est Linlithgow Bridge
Linlithgow West Lothian
EH49 7TL

Date: 13/10/2021

Zayo Plant Protection Centre

c/o JSM Group Ltd
Plant Protection Department
Sterling House
Mutton Lane
Potters Bar
Herts, EN6 3AR

Our Reference: 23548644
Your Reference: NOC/CTWSV456

Dear Mr [REDACTED]

ZAYO GROUP UK LTD NOT AFFECTED C2 PRELIMINARY PLANT ENQUIRY


We acknowledge with thanks your request dated 13/10/2021 08:58:13 AM for information on the location of our services.

Having examined our records, we can confirm that **ZAYO GROUP UK LTD** has no owned apparatus within the search area of your enquiry detailed in the reference/location provided.

Please do not hesitate to contact us for further assistance.

Regards,

Zayo Group UK Ltd c/o JSM Group Ltd
JSM Plant Protection Department
T: 01992 655 919
zayoplantenquiries@jsmgroup.com



Date Requested: 13/10/2021

Requested by: Brian McMaster

Company: PlanToDig

Job Reference: 23548644

Your Scheme/Reference: NOC/CTWSV456

 ZAYO DUCT
 or  ZAYO CHAMBER
 Dig Sites: Line  Area 
 Scale on A4 paper: 1:1000



4th Floor, Harmsworth House
13-15 Bouverie Street
London EC4Y 8DP

The information on this document is proprietary and shall not be used, copied, reproduced or disclosed in whole or in part without written consent of Zayo Group UK Ltd. Approximate location only is shown. To determine exact location a trial hole must be dug with a Zayo Group UK Ltd Supervisor present. Zayo Group UK Ltd and JSM Construction Ltd accept no liability for errors or omissions.



JSM Group Ltd
Sterling House
Mutton Lane, Potters Bar
Hertfordshire, EN6 3AR
T: 01992 788 019



Protecting Lives, Cables & Pipes


Warning: PDF designed for colour print only with no page scaling. This information is given as a guide only and its accuracy cannot be guaranteed



In Emergency Only and if Zayo Plant or Cables damaged call: 0800 169 1646.

zayoplantenquiries@smgroup.com

CROWN COPYRIGHT. © All Rights Reserved. Ordnance Survey Licence number: 100040487.



Date Requested: 13/10/2021

Requested by: Brian McMaster

Company: PlanToDig

Job Reference: 23548644

Your Scheme/Reference: NOC/CTWSV456

 ZAYO DUCT

 or  ZAYO CHAMBER

Dig Sites: Line  Area 

Scale on A4 paper: 1:1000



4th Floor, Harmsworth House,
13-15, Bouverie Street
London, EC4Y 8DP



JSM Group Ltd
Sterling House
Mutton Lane, Potters Bar
Hertfordshire, EN6 3AR
T: 01992 788 019

zayoplantenquiries@ismgroup.com

The information on this document is proprietary and shall not be used, copied, reproduced or disclosed in whole or in part without written consent of Zayo Group UK Ltd. Approximate location only is shown. To determine exact location a trial hole must be dug with a Zayo Group UK Ltd Supervisor present. Zayo Group UK Ltd and JSM Construction Ltd accept no liability for errors or omissions.




Protecting Lives, Cables & Pipes

Warning: PDF designed for colour print only with no page scaling. This information is given as a guide only and its accuracy cannot be guaranteed



In Emergency Only and if Zayo Plant or Cables damaged call: 0800 169 1646.

CROWN COPYRIGHT © All Rights Reserved. Ordnance Survey Licence number: 100040487.




Date Requested: 13/10/2021

Requested by: Brian McMaster

Company: PlanToDig

Job Reference: 23548644

Your Scheme/Reference: NOC/CTWSV456

 ZAYO DUCT
 or  ZAYO CHAMBER
 Dig Sites: Line  Area 
 Scale on A4 paper: 1:1000



4th Floor, Harmsworth House,
13-15 Bouverie Street
London, EC4Y 8DP

The information on this document is proprietary and shall not be used, copied, reproduced or disclosed in whole or in part without written consent of Zayo Group UK Ltd. Approximate location only is shown. To determine exact location a trial hole must be dug with a Zayo Group UK Ltd Supervisor present. Zayo Group UK Ltd and JSM Construction Ltd accept no liability for errors or omissions.



JSM Group Ltd
Sterling House
Mutton Lane, Potters Bar
Hertfordshire, EN6 3AR
T: 01992 788 019



Protecting Lives, Cables & Pipes


Warning: PDF designed for colour print only with no page scaling. This information is given as a guide only and its accuracy cannot be guaranteed



In Emergency Only and if Zayo Plant or Cables damaged call: 0800 169 1646.

zayoplantenquiries@ismgroup.com

CROWN COPYRIGHT. © All Rights Reserved. Ordnance Survey Licence number: 100040487.



Date Requested: 13/10/2021

Requested by: Brian McMaster

Company: PlanToDig

Job Reference: 23548644

Your Scheme/Reference: NOC/CTWSV456

 ZAYO DUCT
 or  ZAYO CHAMBER
 Dig Sites: Line  Area 
 Scale on A4 paper: 1:1000



4th Floor, Harmsworth House,
13-15 Bouverie Street
London, EC4Y 8DP

The information on this document is proprietary and shall not be used, copied, reproduced or disclosed in whole or in part without written consent of Zayo Group UK Ltd. Approximate location only is shown. To determine exact location a trial hole must be dug with a Zayo Group UK Ltd Supervisor present. Zayo Group UK Ltd and JSM Construction Ltd accept no liability for errors or omissions.



JSM Group Ltd
Sterling House
Mutton Lane, Potters Bar
Hertfordshire, EN6 3AR
T: 01992 788 019



Protecting Lives, Cables & Pipes


Warning: PDF designed for colour print only with no page scaling. This information is given as a guide only and its accuracy cannot be guaranteed



In Emergency Only and if Zayo Plant or Cables damaged call: 0800 169 1646.

zayoplantenquiries@ismgroup.com

CROWN COPYRIGHT. © All Rights Reserved. Ordnance Survey Licence number: 100040487.



Date Requested: 13/10/2021

Requested by: Brian McMaster

Company: PlanToDig

Job Reference: 23548644

Your Scheme/Reference: NOC/CTWSV456

 ZAYO DUCT
 or  ZAYO CHAMBER
 Dig Sites: Line  Area 
 Scale on A4 paper: 1:1000



4th Floor, Harmsworth House,
13-15, Bouverie Street
London, EC4Y 8DP

The information on this document is proprietary and shall not be used, copied, reproduced or disclosed in whole or in part without written consent of Zayo Group UK Ltd. Approximate location only is shown. To determine exact location a trial hole must be dug with a Zayo Group UK Ltd Supervisor present. Zayo Group UK Ltd and JSM Construction Ltd accept no liability for errors or omissions.



JSM Group Ltd
Sterling House
Mutton Lane, Potters Bar
Hertfordshire, EN6 3AR
T: 01992 788 019



Warning: PDF designed for colour print only with no page scaling. This information is given as a guide only and its accuracy cannot be guaranteed



Protecting Lives, Cables & Pipes

In Emergency Only and if Zayo Plant or Cables damaged call: 0800 169 1646.

zayoplantenquiries@ismgroup.com

CROWN COPYRIGHT. © All Rights Reserved. Ordnance Survey Licence number: 100040487.